

STANDARDS
Australia



AS 2118.2—2010

Automatic fire sprinkler systems

Part 2: Drencher systems



Australian
STANDARDS

AS 

Drencher systems

This Australian Standard® was prepared by Committee FP-004, Automatic Fire Sprinkler Systems. It was approved on behalf of the Council of Standards Australia on 10 June 2010. This Standard was published on 20 August 2010.

The following are represented on Committee FP-004:

- Association of Consulting Engineers Australia
 - Australasian Fire and Emergency Service Authorities Council
 - Australian Building Codes Board
 - Australian Industry Group
 - Australian Institute of Building Surveyors
 - Consumers' Federation of Australia
 - Department of Defence (Australia)
 - Department of Human Services (Victoria)
 - Engineers Australia
 - Fire Protection Association Australia
 - Independent Chairperson
 - Insurance Council of Australia
 - National Fire Industry Association
 - Testing Interests (Australia)
-

This Standard was issued in draft form for comment as DR 03577.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standard up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

Automatic fire sprinkler systems

Part 2: Drencher systems

First published as AS 2118.2—1995.
Second edition 2010.

COPYRIGHT

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

Published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 978 0 7337 9608 1

PREFACE

This Standard was prepared by the Standards Australia Committee FP-004, Automatic Fire Sprinkler Systems, to supersede AS 2118.2—1995, *Automatic fire sprinkler systems—Wall wetting sprinklers (Drenchers)*.

The AS 2118 suite of sprinkler Standards has been restructured into two groups: Systems (AS 2118 series) and Component (AS 4118 series). The complete series comprises the following:

AS

- 2118 Automatic fire sprinkler systems
- 2118.1 Part 1: General systems
- 2118.2 Part 2: Drencher systems (this Standard)
- 2118.3 Part 3: Deluge systems
- 2118.4 Part 4: Sprinkler systems for accommodation buildings not exceeding four storeys in height
- 2118.5 Part 5: Home fire sprinkler systems
- 2118.6 Part 6: Combined sprinkler and hydrant systems in multi-storey buildings

4118

- 4118 Fire sprinkler systems
- 4118.1.1 Part 1.1: Components—Sprinklers and sprayers
- 4118.1.2 Part 1.2: Components—Alarm valves (wet)
- 4118.1.3 Part 1.3: Components—Water motor alarms
- 4118.1.4 Part 1.4: Components—Valve monitors
- 4118.1.5 Part 1.5: Components—Deluge and pre-action valves
- 4118.1.6 Part 1.6: Components—Stop valves and non-return valves
- 4118.1.7 Part 1.7: Components—Alarms valves (dry)
- 4118.1.8 Part 1.8: Components—Pressure-reducing valves
- 4118.2.1 Part 2.1: Piping—General

AS/NZS

- 3500 Plumbing and drainage
- 3500.1 Part 1: Water services

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendices to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

A Note to a clause in this Standard is designed to draw attention to a condition that needs to be considered when applying the clause; for example, a reminder that another Standard needs to be consulted which could conflict with the clause. On the other hand, a Commentary (see panel below) is an explanation as to why the clause was written or developed and is primarily intended to assist with how the clause would be applied in practice.

This Standard incorporates a Commentary on some Clauses. The Commentary directly follows the relevant Clause, is designated by ‘C’ preceding the clause number and is printed in italics in a panel. The Commentary is for information only and does not need to be followed for compliance with the Standard.

CONTENTS

	<i>Page</i>
FOREWORD.....	4
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	5
1.2 OBJECTIVE.....	5
1.3 APPLICATION	5
1.4 NORMATIVE REFERENCES	5
1.5 DEFINITIONS	6
1.6 TYPES OF SYSTEMS	7
SECTION 2 SYSTEM DESIGN	
2.1 GENERAL	8
2.2 OPENING INFILL	8
2.3 DESIGN FLOW FROM DRENCHERS	8
2.4 DRENCHERS IN SIMULTANEOUS OPERATION	8
2.5 DRENCHERS	8
2.6 DRENCHER SPACING AND LOCATION	9
2.7 SHIELDING	16
SECTION 3 WATER SUPPLIES	
3.1 GENERAL	17
3.2 DRENCHERS CONNECTED TO SPRINKLER SYSTEMS	17
3.3 DRENCHERS NOT CONNECTED TO SPRINKLER SYSTEMS	17
3.4 FIRE BRIGADE BOOSTER CONNECTION	18
SECTION 4 SYSTEM INSTALLATION, COMPONENTS AND PIPING	
4.1 GENERAL	19
4.2 SYSTEM ARRANGEMENTS	19
SECTION 5 COMPLESSIONING	
5.1 GENERAL	20
5.2 PRE TEST PREPARATION	20
5.3 HYDROSTATIC TEST	20
5.4 FLOW TESTS	20
5.5 RECORDING OF TEST RESULTS	20
APPENDIX A EXAMPLE OF DRENCHER SYSTEM COMPLETION CERTIFICATE ...	21

FOREWORD

Fire can spread from one building or a source of fire such as storage (fire source) to a nearby building (fire exposed) if the heat radiated by the source impinges on an unprotected opening infill (e.g. a door or window) of the fire exposed building at sufficient levels to cause failure of the infill and ignition of the contents.

The analogy of fire source and fire exposed buildings may also be applicable to internal areas of buildings such as an atrium and its bounding walls or where an egress path passes an unprotected opening in the building.

Research on the behaviour of glazing under radiant heat conditions and its ability to protect openings has shown that when water is sprayed onto a glass infill it can reduce the risk of failure and the passage of radiant heat.

The purpose of drencher systems is to provide sufficient water spray upon opening infills, such as windows, to mitigate the effects of radiant heat from nearby exposure fires.

STANDARDS AUSTRALIA

Australian Standard Automatic fire sprinkler systems

Part 2: Drencher systems

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard sets out requirements for the design, installation and commissioning of drencher systems intended to provide automatic external protection to windows, doors and other openings from exposure to fire.

C1.1 *Drencher systems may be either internal or external; however, this Standard covers external protection of fire exposed building facades only, including the bounding walls of an atrium or where egress paths pass unprotected openings in the building. Radiant heat flux levels are not considered in this Standard.*

Where a fire exposed building is protected by an automatic sprinkler system in accordance with AS 2118.1, protection from a fire source may be achieved by external sprinklers fed from that system.

1.2 OBJECTIVE

The objective of this Standard is to provide system designers and installers with a set of requirements for the design, installation and commissioning of drencher systems in order to provide protection to a building that is exposed to an external fire source or an egress path passing unprotected openings in the building.

1.3 APPLICATION

Drencher systems are intended primarily to protect a fire exposed building that is not sprinkler protected.

This Standard may also be applied to infills that open on to an atrium or where egress paths pass unprotected openings in the building. It does not apply to manually-operated systems.

Where a fire exposed building is protected by sprinklers and protection from a fire source is achieved by external sprinklers fed from the building's sprinkler system designed and installed to AS 2118.1, drencher protection in accordance with this Standard is not required.

1.4 NORMATIVE REFERENCES

The following are the normative documents referenced in this Standard:

AS

1670	Automatic fire detection and alarm systems—System design, installation and commissioning
2118	Automatic fire sprinkler systems
2118.1	Part 1: General requirements