

Australian Standard[®]

Water storage tanks for fire protection systems



This Australian Standard® was prepared by Committee FP-008, Fire Pumps and Fire Tanks. It was approved on behalf of the Council of Standards Australia on 21 March 2011. This Standard was published on 21 July 2011.

The following are represented on Committee FP-008:

- Association of Hydraulic Services Consultants Australia
 - Australasian Fire and Emergency Service Authorities Council
 - Australian Canvas and Synthetic Products Association
 - Australian Chamber of Commerce and Industry
 - Australian Industry Group
 - Consult Australia
 - Consumers Federation of Australia
 - Engineers Australia
 - Fire Protection Association Australia
 - Insurance Council of Australia
 - Pump Industry Australia
-

This Standard was issued in draft form for comment as DR 07308 and DR 10008.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

Water storage tanks for fire protection systems

First published as AS 2304—2011.

COPYRIGHT

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

Published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 978 0 7337 9898 0

PREFACE

This Australian Standard was prepared by Standards Australia Committee FP-008, Fire Pumpsets and Fire Tanks.

Technical Sub-committee FP-008-02, Fire Tanks, provided invaluable assistance in the development of this Standard, especially in the sections relating to design action (loads), tank design and tank foundations.

This Standard was developed taking into consideration local and international Standards.

Maintenance of water storage tanks for fire protection purposes is covered in Section 11 of this Standard, but will be removed by amendment when the same requirements are published in Australian Standard titled, *Routine servicing of fire protection systems and equipment*, currently under development (see Note to Clause 1.1).

The term 'informative' has been used in this Standard to define the application of the appendix to which it applies. An 'informative' appendix is only for information and guidance.

This Standard incorporates commentary on some of the clauses. The commentary directly follows the relevant Clause shown in italic font-type and enclosed in a panel. The commentary is for information only and does not need to be followed for compliance with the Standard. Commentaries explain the purpose of a Clause and give, in some cases, background information.

CONTENTS

	<i>Page</i>
FOREWORD.....	5
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	6
1.2 OBJECTIVE.....	7
1.3 NORMATIVE REFERENCES.....	7
1.4 APPLICATION	8
1.5 DEFINITIONS	8
1.6 NOTATION	11
1.7 TANK TYPES AND DESCRIPTIONS	14
SECTION 2 WATER SOURCES	
2.1 GENERAL	16
2.2 WATER SOURCES	16
SECTION 3 MATERIALS	
3.1 GENERAL	17
3.2 STRUCTURAL ELEMENTS.....	17
3.3 PIPE AND FITTINGS.....	17
3.4 CORROSION PROTECTION.....	17
3.5 GASKETS AND SEALANTS.....	17
3.6 TANK LINERS	18
SECTION 4 DESIGN ACTIONS (LOADS)	
4.1 GENERAL	20
4.2 PERMANENT ACTION.....	20
4.3 LIQUID PRESSURE ACTION.....	20
4.4 IMPOSED ACTIONS.....	22
4.5 WIND ACTION	23
4.6 EARTHQUAKE ACTION	24
4.7 SNOW AND ICE ACTIONS.....	28
4.8 COMBINATIONS OF ACTIONS.....	28
SECTION 5 TANK DESIGN	
5.1 GENERAL	30
5.2 MINIMUM STEEL THICKNESS	30
5.3 BOLTED STEEL CIRCULAR WATER STORAGE TANK DESIGN	30
5.4 BOLTED STEEL RECTANGULAR WATER STORAGE TANK DESIGN	36
SECTION 6 CYLINDRICAL TANK FOUNDATIONS	
6.1 GENERAL	42
6.2 TYPES OF FOUNDATIONS	43
6.3 TANK HOLD-DOWN.....	43

SECTION 7 ACCESSORIES	
7.1	GENERAL 45
7.2	TANK ACCESS 45
7.3	HYDRAULIC COMPONENTS 46
7.4	MISCELLANEOUS COMPONENTS 50
7.5	CAPACITIES 52
SECTION 8 BREAK TANKS	
8.1	GENERAL 53
8.2	CONSTRUCTION 53
8.3	CAPACITY 53
8.4	FILL INLETS 53
8.5	SUCTION LINE AND VORTEX INHIBITORS 55
8.6	WATER LEVEL INDICATOR 55
8.7	TANK BAFFLING 55
8.8	TANK OVERFLOW 55
SECTION 9 SHARED USE, RAINWATER AND HEATING AND COOLING TANKS	
9.1	GENERAL 56
9.2	SHARED USE 56
9.3	RAINWATER 56
9.4	HEATING AND COOLING 56
SECTION 10 COMMISSIONING 57	
SECTION 11 MAINTENANCE	
11.1	GENERAL 58
11.2	PROCEDURES AND PRECAUTIONS 58
11.3	FREQUENCY 58
11.4	INSPECTION, TEST, ROUTINE SERVICING AND RECORDS SCHEDULES 59
APPENDICES	
A	WATER CONSERVATION 64
B	TANK LINERS 66
C	WATER SOURCE AND QUALITY 67
D	COMPETENCE AND AUTHORITY TO WORK 68
E	GUIDELINE FOR USE OF DIVERS FOR TANK MAINTENANCE 69
F	EXAMPLES OF WIND BUCKLING CALCULATIONS 70
BIBLIOGRAPHY 84	

FOREWORD

This Standard has been developed to provide reliable water storage for fire protection purposes. Water storage tanks that are not designed correctly nor adequately maintained are prone to failure.

Design provisions for bolted steel tanks are covered in this Standard. Design provisions for tanks made from other materials are not covered by this Standard and may be included in future editions.

This Standard applies to suction tanks for sprinkler, hydrant and hose reel systems as well as for break tanks and dual-use fire protection storage tanks.

Steel tanks consist of a floor (either steel, concrete or liner), cylindrical or rectangular shell fabricated from steel plates joined together, and a roof, all of which rest upon a foundation. Tanks are filled with water from an outside source. Water is withdrawn in emergency situations through piping connected to a pump. Accessory items are provided to fill and drain the tank, monitor the water level, gain access for inspection and repair, provide means for accessing the water and to prevent positive or negative pressures, etc.

For tanks manufactured from materials other than bolted steel and bolted cast iron, the accessories and maintenance provisions of this Standard apply.

STANDARDS AUSTRALIA

Australian Standard
Water storage tanks for fire protection systems

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard sets out the minimum requirements for the design, construction, installation, commissioning and maintenance of bolted steel circular and rectangular water tanks for the storage of water for fire protection systems. This Standard also provides guidance on water sources and qualities that influence tank design and construction, together with water conservation measures.

NOTE: 'Maintenance' will be removed by amendment when the second edition of AS 1851 is published.

This Standard is limited to—

- (a) the tank structure;
- (b) the tank foundation; and
- (c) tank penetrations and related accessories.

The requirements cover—

- (i) bolted steel and bolted cast iron tanks with and without liners.
- (ii) all other fire service tanks' accessories (Section 7).

This Standard applies to the following systems, where applicable:

- (A) Automatic fire sprinkler systems to AS 2118.1.
- (B) Fire hydrant systems to AS 2119.1.
- (C) Fire hose reel systems to AS/NZS 1221.
- (D) Combined sprinkler and hydrant systems in multistorey buildings to AS 2118.6.
- (E) Residential sprinkler systems to AS 2118.4.
- (F) Fire pumpsets to AS 2941.

This Standard does not apply to the design and application of the following:

- (1) Plastic tanks.
- (2) Fibreglass tanks.
- (3) Agricultural and rainwater tanks.
- (4) Drinking water tanks.
- (5) Wooden tanks.
- (6) Non-ferrous metal tanks.
- (7) Bladder tanks.
- (8) Welded steel tanks.
- (9) Concrete tanks.