

Australian Standard™

Composite structures

Part 1: Simply supported beams

This Australian Standard was prepared by Committee BD-032, Composite Construction. It was approved on behalf of the Council of Standards Australia on 3 June 2003 and published on 18 August 2003.

The following are represented on Committee BD-032:

Association of Consulting Engineers Australia
Australian Building Codes Board
Australian Steel Institute
Bureau of Steel Manufacturers of Australia
Institution of Engineers Australia
Steel Reinforcement Institute of Australia
University of New South Wales
University of Adelaide

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Australia website at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.com.au, or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

Australian Standard™

Composite structures

Part 1: Simply supported beams

Formulated as AS 1480 Supplement 1—1974.
Previous edition AS 2327.1—1996.
Third edition 2003.

COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 5338 8

PREFACE

This Standard was prepared by the Standards Australia Committee BD-032, Composite Construction, to supersede AS 2327.1—1996 *Composite structures in structural steel and concrete, Part 1—Simply supported beams*.

This revision incorporates a number of technical and editorial changes. The principal differences are briefly outlined in the following:

1 *Shear connectors:*

- (a) The value of the density reduction factor (k_r), used in the calculation of the design shear capacity (f_{ds}) of shear connectors with lightweight concrete, has been changed to equal 1.0 for welded-studs (since the effect of lower concrete density is already taken into account in the calculation of nominal shear capacity (f_{vs}) using Equation 8.3.2.1(2)), and a constant value of 0.8 for channels and high-strength structural bolts.
- (b) A procedure for calculating the nominal shear capacity (f_{vs}) of channel or high-strength structural bolt shear connectors during the initial part of Construction Stage 5 when $15 \leq f'_{cj} < 20$ MPa, previously omitted from AS 2327.1, has been included, viz. at $f'_{cj} = 15$ MPa, f_{vs} equals 80% of the values given in Table 8.2 and Table 8.3 $f'_c = 20$ MPa, and linear interpolation is used for values of f'_{cj} between 15 and 20 MPa.
- (c) The Grade 300, 100 PFC (parallel flange channel) may now be used as a fully equivalent shear connector to the Grade 250, 100 TFC (channel).

2 *Open-rib and closed-rib profiles* Distinction is made between open-rib and closed-rib profile steel sheeting when designing the shear connection of the composite beam.

3 *Welded stud locations* Clause 8.4.2 clarifies that when automatically welded studs are placed in the pans of sheeting ribs deemed to be perpendicular to the steel beam, no more than two studs are permitted between adjacent sheeting ribs. New rules have been written to allow shear connectors to be placed closer to steel ribs of closed-rib profiles.

4 *New reference material* New reference material has been provided for designers regarding the design of beams with large web penetrations and design for occupant-induced vibration.

5 *Reinforcement $f_{yr} = 500$* The maximum design yield strength has been increased to 500 MPa for the longitudinal shear reinforcement in the composite slab.

The terms 'normative' and 'informative' are used in this Standard to define the application of the appendix to which they apply. A 'normative' appendix is an integral part of a Standard, whereas an 'informative' appendix is only for information and guidance.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE.....	6
1.2 GENERAL.....	6
1.3 REFERENCED DOCUMENTS.....	9
1.4 DEFINITIONS.....	10
1.5 EXISTING STRUCTURES.....	16
1.6 DESIGN INFORMATION	16
1.7 CONSTRUCTION.....	17
1.8 NOTATION.....	17
SECTION 2 MATERIALS	
2.1 STEEL.....	25
2.2 CONCRETE AND REINFORCEMENT	25
2.3 MECHANICAL PROPERTIES.....	25
SECTION 3 GENERAL DESIGN REQUIREMENTS	
3.1 DESIGN	27
3.2 LOADS AND OTHER ACTIONS.....	28
3.3 DESIGN FOR LIMIT STATES.....	28
SECTION 4 ACTIONS AND DESIGN SITUATIONS	
4.1 GENERAL.....	30
4.2 CONSTRUCTION STAGES.....	30
SECTION 5 EFFECTIVE SECTION AND DESIGN ACTION EFFECTS FOR STRENGTH DESIGN	
5.1 GENERAL.....	32
5.2 EFFECTIVE SECTION OF A COMPOSITE BEAM CROSS-SECTION	32
5.3 CALCULATION OF DESIGN ACTION EFFECTS DUE TO DESIGN LOADS	37
SECTION 6 DESIGN FOR STRENGTH	
6.1 GENERAL.....	39
6.2 DESIGN	39
6.3 POTENTIALLY CRITICAL CROSS-SECTIONS	41
6.4 CALCULATION OF DESIGN VERTICAL SHEAR CAPACITY (ϕV_u) AND DESIGN MOMENT CAPACITY (ϕM_{bv}) AS A FUNCTION OF DEGREE OF SHEAR CONNECTION (β).....	42
6.5 CALCULATION OF MINIMUM DEGREE OF SHEAR CONNECTION β_i AT POTENTIALLY CRITICAL CROSS-SECTIONS	42
6.6 DISTRIBUTION OF SHEAR CONNECTORS BETWEEN POTENTIALLY CRITICAL CROSS-SECTIONS AND BEAM ENDS	43
SECTION 7 DESIGN FOR SERVICEABILITY	
7.1 GENERAL.....	45
7.2 DEFLECTION CONTROL.....	45
7.3 CRACK CONTROL	47
7.4 VIBRATION CONTROL	47

SECTION 8 DESIGN OF SHEAR CONNECTORS

8.1	GENERAL.....	48
8.2	SHEAR CONNECTORS	48
8.3	SHEAR CAPACITY OF SHEAR CONNECTORS	50
8.4	DETAILING OF SHEAR CONNECTORS	52

SECTION 9 TRANSFER OF LONGITUDINAL SHEAR IN CONCRETE

9.1	GENERAL.....	60
9.2	DEFINITIONS.....	60
9.3	DESIGN	60
9.4	LONGITUDINAL SHEAR SURFACES	61
9.5	DESIGN LONGITUDINAL SHEAR FORCE (V^*_L).....	62
9.6	NOMINAL LONGITUDINAL SHEAR CAPACITY (V_L).....	66
9.7	TYPES 1, 2 AND 3 LONGITUDINAL SHEAR REINFORCEMENT	67
9.8	TYPE 4 LONGITUDINAL SHEAR REINFORCEMENT.....	67

SECTION 10 DESIGN FOR FIRE RESISTANCE

10.1	REQUIREMENTS.....	70
10.2	DEFINITIONS.....	70
10.3	DETERMINATION OF PERIOD OF STRUCTURAL ADEQUACY.....	71
10.4	DETERMINATION OF LIMITING TEMPERATURE OF THE STEEL.....	71
10.5	DETERMINATION OF TIME AT WHICH LIMITING TEMPERATURE IS ATTAINED FOR PROTECTED MEMBERS	71
10.6	DETERMINATION OF TIME AT WHICH LIMITING TEMPERATURE IS ATTAINED FOR UNPROTECTED MEMBERS.....	73
10.7	DETERMINATION OF PSA FROM A SINGLE TEST.....	74
10.8	THREE-SIDED FIRE EXPOSURE CONDITION.....	74
10.9	CONNECTIONS AND WEB PENETRATIONS.....	74
10.10	DETERMINATION OF PERIOD OF STRUCTURAL ADEQUACY BY OTHER CALCULATION METHODS	75

SECTION 11 CONSTRUCTION

11.1	GENERAL.....	76
11.2	CONSTRUCTION SEQUENCE AND LOADS	76
11.3	STEELWORK	76
11.4	FORMWORK AND FALSEWORK.....	76
11.5	REINFORCEMENT	77
11.6	CONCRETE	77
11.7	FIRE PROTECTION MATERIAL	77

SECTION 12 LOAD TESTING

12.1	GENERAL.....	78
12.2	PROOF TESTING	78
12.3	PROTOTYPE TESTING	79
12.4	TEST REPORTS	80

Page

APPENDICES

A	LIST OF REFERENCED DOCUMENTS.....	81
B	CALCULATION OF DEFLECTIONS BY SIMPLIFIED METHOD.....	83
C	SUGGESTED LIMITS FOR CALCULATED DEFLECTIONS.....	90
D	CALCULATION OF DESIGN MOMENT CAPACITY (ϕM_{bv}) AS A FUNCTION OF DEGREE OF SHEAR CONNECTION (β).....	91
E	FLOW CHARTS	107
F	CONSTRUCTION STAGES AND MINIMUM CONSTRUCTION LOADS.....	114
G	DESIGN FOR FIRE RESISTANCE OF CONCRETE SLABS.....	119
H	INFORMATION FOR DETERMINATION OF ACTION EFFECTS	120
I	BIBLIOGRAPHICAL REFERENCES	123

Currently in preview, click buy full version.

STANDARDS AUSTRALIA

Australian Standard Composite structures

Part 1: Simply supported beams

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard sets out minimum requirements for the design, detailing and construction of simply supported composite beams composed of a steel beam and a concrete slab interconnected with shear connectors, including applications where the slab incorporates profiled steel sheeting, as defined in Clause 1.2.

This Standard does not cover the design of composite beams—

- (a) where the elements of the steel beam are less than 3 mm thick or the value of the yield stress (f_{yb}) assumed in design exceeds 450 MPa (see Note 1);
- (b) where the strength grade of the slab concrete exceeds 40 MPa;
- (c) where the slab is precast or prestressed;
- (d) with negative design moments (see Note 2);
- (e) subjected to dynamic loads;
- (f) for road or railway bridges (see Note 3);
- (g) for fatigue.

NOTE:

- 1 This does not preclude the use of steels with a minimum yield strength greater than 450 MPa.
- 2 For the design of composite beams with negative design moments reference may be made to BS 5950:3:1990, Code of Practice for Design of Simple and Continuous Composite Beams.
- 3 For the design of composite bridge beams, reference should be made to HB 77 the AUSTRROADS Bridge Design Code.

1.2 GENERAL

1.2.1 Components

This Standard applies only to composite beams for which the components satisfy the requirements specified in Clauses 1.2.2 to 1.2.5.

1.2.2 Steel beam

The steel beam shall be entirely below, but in contact with, the soffit of the concrete slab, and shall be of structural steel, symmetrical about its vertical axis (i.e., doubly symmetric or monosymmetric), suitably proportioned (see Note) and have one of the following forms (see Figure 1.2.2)—

- (a) a hot-rolled I-section, or channel section;
- (b) a welded I-section;
- (c) a rectangular cold-formed hollow section;