

Australian Standard™

Power transformers

**Part 6: Determination of transformer
and reactor sound levels**



This Australian Standard was prepared by Committee EL/8, Power Transformers. It was approved on behalf of the Council of Standards Australia on 16 May 1994 and published on 11 July 1994.

The following interests are represented on Committee EL/8:

Australian Chamber of Commerce and Industry
Australian Electrical and Electronic Manufacturers Association
Australian Institute of Petroleum
Electricity Supply Association of Australia
Electricity Supply Engineers Association of New South Wales
Institution of Engineers, Australia
Railways of Australia Committee
Testing and Certification Australia
University of South Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Australia website at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Australian Standard*, has a full listing of revisions and amendments published each month.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.com.au, or write to the Chief Executive, Standards Australia International Ltd, PO Box 1055, Strathfield, NSW 2135.

Australian Standard™

Power transformers

Part 6: Determination of transformer and reactor sound levels

First published as part of AS C61—1931.
Second edition 1946 (endorsement of BS 171—1936 with
amendments).
Third edition 1963.
Fourth edition 1970.
Revised and redesignated in part as AS 2374.6—1982.
Second edition 1994.
Reissued incorporating Amendment No. 1 (June 2000).

COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd
PO Box 1055, Strathfield, NSW 2135, Australia
ISBN 0 7262 8995 7

PREFACE

This Standard was prepared by the Standards Australia Committee EL/8 on Power Transformers to supersede AS 2374.6—1982, *Power transformers, Part 6: Sound levels*.

This Standard incorporates Amendment No. 1 (June 2000). The changes required by the Amendment are indicated in the text by a marginal bar and amendment number against the clause, note, table, figure, or part thereof affected.

It is identical with and has been reproduced from IEC 551—1987, *Determination of transformer and reactor sound levels*, with the exception that Appendix AA has been added.

This Standard is Part 6 of a series, including:

AS

2374	Power transformers
2374.1	Part 1: General requirements
2374.2	Part 2: Temperature rise
2374.3	Part 3: Insulation levels and dielectric tests
2374.3.0	Part 3.0: General requirements
2374.3.1	Part 3.1: External clearances in air
2374.4	Part 4: Tappings and connections
2374.5	Part 5: Ability to withstand short-circuit

The principal difference between this Standard and the previous edition is that sound levels will now be expressed as sound power, not sound pressure. This is in line with current practice.

It is emphasized that care should be taken when comparing sound power levels determined from this Standard with sound pressure levels determined from the previous edition. The user is reminded that, for a given sound level, the numerical value of sound power will be significantly higher than the sound pressure reading, and that both quantities are represented in decibels (dB).

The term 'normative' has been used in this Standard to define the application of the appendix to which it applies. A 'normative' appendix is an integral part of a Standard.

As this Standard is reproduced from an international standard, the following applies:

- Its number does not appear on each page of text and its identity is shown only on the cover and title pages.
- In the source text, 'this International Standard' should read 'this Australian Standard'.
- A full point substitutes for a comma when referring to a decimal marker.

References to international Standards should be replaced by equivalent Australian Standards, as follows:

Reference to International Standards

IEC	
76	Power transformers
76-1	Part 1: General requirements
289	Reactors
651	Sound level meters

726 Dry-type power transformers

A1	1043	Electroacoustics—Instruments for the measurement of sound intensity—Measurements with pairs of pressure sensing microphones
----	------	---

ISO

	746	Acoustics—Determination of sound power levels of noise sources—Survey method
--	-----	--

A1	9614-1	Acoustics—Determination of sound power levels of noise sources using sound intensity—Part 1: Measurement at discrete points
----	--------	---

Australian Standard

AS	
2374	Power transformers
2374.1	Part 1: General requirements
1028	Power reactors and earthing transformers
1259	Acoustics—Sound level meters
1259.1	Part 1: Non-integrating
2735	Dry-type power transformers

A1	4241	Acoustics—Instruments for the measurement of sound intensity—Measurement with pairs of pressure sensing microphones
----	------	---

A1	Appendices A, B and C form an integral part of this standard.	
----	---	--

CONTENTS

Clause	<i>Page</i>
1. Scope	1
2. Definitions	1
3. Instruments	2
4. Conditions for measurement	2
5. Measurement of sound pressure levels	3
6. Calculation of surface sound pressure level and sound power level	7
7. Presentation of results	9
FIGURES	2
APPENDIX A – Test environment qualification procedure	14
APPENDIX AA – Specified sound levels for transformers	22
A1 APPENDIX B - Derivation of sound power level from sound intensity measurements	24
APPENDIX C - Determination of sound power level due to load currents	29

Currently in preview, click buy full version.

STANDARDS AUSTRALIA

Australian Standard

Power transformers

Part 6: Determination of transformer and reactor sound levels

1. Scope

This standard defines the methods by which the sound levels of transformers, reactors and their associated cooling equipment shall be determined so that compliance with any specification requirements may be confirmed and the characteristics of the noise emitted in service determined.

This standard is intended to apply to measurements made in the manufacturer's workshop since conditions may be very different when measurements are made on site because of the proximity of other objects, background extraneous noises, etc. Nevertheless, the same general rules as are given herein may be followed when on-site measurements are made.

A1 Standard measurements use the A-weighted sound pressure level as a measured variable. In case of difficult measuring conditions, sound intensity measurements are recommended. This application is described in Appendix B.

According to this standard, measurements on transformers are made under no-load. If a transformer has a very low no-load noise, the noise due to load current can also influence the sound level. Appendix C specifies the measurement conditions for the determination of the noise due to load current.

In those cases where sufficient power is available in the factory to permit full energization of reactors, the methods to be followed are the same as for transformers. Such measurements shall be made by agreement between the manufacturer and the purchaser. Alternatively, measurements may be made on site where conditions are suitable.

The methods are applicable to transformers and reactors covered by IEC Publications 76, 726 and 289, without further limitation as regards size or voltage and when fitted with their normal auxiliary equipment, inasmuch as it may influence the measurement result.

Although the following text refers only to transformers, it is equally applicable to reactors provided that it is recognized that the current taken by a reactor is dependent on the voltage applied and, consequently, that a reactor cannot be tested at no-load.

This standard provides a basis for calculation of sound power levels.

The methods of measurement and the environmental qualification procedure given in Appendix A are in accordance with ISO Standard 3746. Measurements made in conformity with this IEC standard tend to result in standard deviations which are equal to or less than 3 dB.

2. Definition

For the purpose of this standard, the following definitions apply.

2.1 Sound pressure level, L_p

The value in decibels equal to twenty times the logarithm to the base of 10 of the ratio of the sound pressure to the reference sound pressure.

Note. — For the purposes of this standard, A-weighted values of L_p are used. i.e., L_{pA} = A-weighted sound pressure level, and the reference sound pressure is 20 μ Pa.

2.2 A-weighted surface sound pressure level, \overline{L}_{pA}

The A-weighted sound pressure level in decibels averaged over the measurement surface as required in Clause 6.