

Under revision see DR 88030

# Australian Standard 2644—1983

---

## CAPACITORS FOR USE IN DISCHARGE LAMP CIRCUITS

[Title Allocated by Reference Cataloguing Authority:  
CAPACITORS. MEDIUM: PAPER, PLASTICS DIELECTRIC  
(Fluorescent; High-Pressure Mercury; Low-Pressure  
Sodium Vapour; Discharge Lamp Circuits)... NSC 5910]



**STANDARDS ASSOCIATION OF AUSTRALIA**

*Incorporated by Royal Charter*



This Australian standard was prepared by Committee LG/3, Auxiliaries for Discharge Lamps. It was approved on behalf of the Council of the Standards Association of Australia on 20 June 1983 and published on 5 September 1983.

---

The following interests are represented on Committee LG/3:

Australian Electrical and Electronic Manufacturers Association  
Association of Consulting Engineers Australia  
Confederation of Australian Industry  
Department of Public Works, N.S.W.  
Department of Transport and Construction  
Electrical Apparatus Approvals Authorities  
Electronic Importers Association  
Electricity Supply Association of Australia  
Illuminating Engineering Societies of Australia  
Public Works Department, Vic.  
Railways of Australia Committee  
Telecom Australia

---

To keep abreast of progress in industry, Australian standards are subject to continuous review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that standards users ensure that their standards are up-to-date. Full details of all SAA publications will be found in the Annual List of Australian Standards; these details are supplemented by listings in the SAA monthly journal 'The Australian Standard'. Information on the Annual List and 'The Australian Standard' may be obtained from any local office of the Association, where details are also available of the current status of individual standards. Suggestions for improvements to published standards, addressed to the head office of the Association, are welcomed.

---

*This standard was issued in draft form for comment as DR 81197.*

**AUSTRALIAN STANDARD**

# **CAPACITORS FOR USE IN DISCHARGE LAMP CIRCUITS**

**AS 2644-1983**

First published .....1983

**PUBLISHED BY THE STANDARDS ASSOCIATION OF AUSTRALIA  
STANDARDS HOUSE, 80 ARTHUR ST, NORTH SYDNEY, N.S.W.**

ISBN 0 7262 3087 1



23 AUG 1983

## PREFACE

This standard was prepared by the Association's Committee on Auxiliaries for Discharge Lamps.

It prescribes requirements for self-healing and non-self-healing capacitors having a rated capacitance greater than  $0.1 \mu\text{F}$ , and intended for use in tubular fluorescent, high-pressure mercury and low-pressure sodium vapour, discharge lamp circuits.

This standard closely follows IEC 566, Capacitors for Use in Tubular Fluorescent, High-pressure Mercury and Low-pressure Sodium Vapour, Discharge Lamp Circuits, however, some requirements of that publication have been modified to take account of local conditions. These modifications include a general reference to AS 3100 for safety requirements, the identification of the safety clauses for approvals purposes (specifically the cross-reference from AS 3168) and the mandatory requirement that discharge resistors be fitted for capacitors having a rating of more than  $0.5 \mu\text{F}$ .

It should be noted that those clauses identified as safety requirements for approvals purposes align with the recommendations of BS 4017, Specification for Capacitors for Use in Tubular Fluorescent, High-pressure Mercury and Low-pressure Sodium Vapour, Discharge Lamp Circuits. BS 4017 is identical with IEC 566.

©Copyright — STANDARDS ASSOCIATION OF AUSTRALIA 1983

Users of standards are reminded that copyright subsists in all SAA publications. No part of this publication may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing of the Standards Association of Australia.

## CONTENTS

	<i>Page</i>
<b>SECTION 1. SCOPE AND GENERAL</b>	
1.1 Scope .....	4
1.2 Referenced Documents .....	4
1.3 Definitions.....	4
<b>SECTION 2. GENERAL REQUIREMENTS</b>	
2.1 General .....	5
2.2 Terminations .....	5
2.3 Creepage Distances and Clearances .....	5
2.4 Voltage Rating .....	6
2.5 Fuses .....	6
2.6 Discharge Resistors .....	6
2.7 Marking .....	6
2.8 Safety Requirements .....	6
<b>SECTION 3. TESTS</b>	
3.1 General Test Requirements .....	7
3.2 Testing Sequence .....	7
3.3 Sealing and Heating Test .....	7
3.4 High-voltage Test Between Terminals.....	7
3.5 High-voltage Test Between Terminals and Container .....	7
3.6 Capacitance Measurement .....	7
3.7 Discharge Resistor Test .....	7
3.8 Thermal Stability Test .....	8
3.9 Self-healing Test .....	8
3.10 Damp Heat (Insulation Resistance and High Voltage Test) .....	8
3.11 Endurance Test .....	8
3.12 Destruction Test (For Self-healing Capacitors Only) .....	10
<b>APPENDICES</b>	
A Discharge Resistors .....	12
B Test Voltage .....	13
C Endurance Test .....	14
D Conformity of Production .....	15

## STANDARDS ASSOCIATION OF AUSTRALIA

**Australian Standard**  
for  
**CAPACITORS FOR USE IN DISCHARGE LAMP CIRCUITS**

## SECTION 1. SCOPE AND GENERAL

**1.1 SCOPE.** This standard specifies requirements for self-healing and non-self-healing continuously rated a.c. capacitors of up to and including 2.5 kvar and not less than 0.1  $\mu\text{F}$ , having a rated voltage not exceeding 1000 V, which are intended for use in discharge lamp circuits operating at 50 Hz a.c. and at altitudes up to 3000 m.

This standard applies to capacitors intended for connection in shunt or in series with the lamp circuit or an effective combination of these. It covers only impregnated or unimpregnated capacitors, having a dielectric of paper, plastics film or a combination of both, either metallized or with metal foil electrodes.

This standard applies in particular to capacitors for those discharge lamp circuits or ballasts, for which the relevant Australian standard or SAA approval and test specification makes cross-reference hereto.

This standard does not apply to radio-interference suppressor capacitors, the requirements for which are given in AS 3145.

**NOTES:**

1. Requirements for capacitors having a capacitance not greater than 0.1  $\mu\text{F}$  for use with fluorescent lamp ballasts are given in AS 3168.
2. Discharge lamp circuits within the scope of this standard are as follows:
  - (a) Tubular fluorescent.
  - (b) High-pressure mercury vapour.
  - (c) Low-pressure sodium vapour.
  - (d) High-pressure sodium vapour.
  - (e) Metal halide.

**1.2 REFERENCED DOCUMENTS.** The following standards are referred to in this standard:

- AS 1099 Basic Environmental Testing Procedures for Electrotechnology  
1099.2C<sub>1</sub>—Damp Heat, Steady State

- AS 3100 Approval and Test Specification for Definitions and General Requirements for Electrical Materials and Equipment
- AS 3135 Approval and Test Specification for Semi-enclosed Fuses for A.C. Circuits
- AS 3145 Approval and Test Specification for Radio Interference Suppression Devices
- AS 3168 Approval and Test Specification for Fluorescent Lamp Ballasts

**1.3 DEFINITIONS.** For the purpose of this standard, the following definitions apply:

**1.3.1 Rated voltage ( $U_n$ )**—the r.m.s. value of the sinusoidal voltage which the capacitor is designed to withstand continuously, and from which the test conditions are derived.

**1.3.2 Rated maximum temperature ( $t_c$ )**—that temperature which must not be exceeded by the hottest part of the capacitor surface during operation in service.

NOTE: The internal losses in a capacitor, though small, result in the surface temperature being above ambient air temperature and due allowance for this should be made. This temperature rise will depend upon the nature of the enclosure.

**1.3.3 Rated minimum temperature ( $t_c$  min.)**—that temperature of any part of the surface of the capacitor below which the capacitor must not be energized.

**1.3.4 Discharge resistor**—a resistor connected across the terminals of a capacitor to reduce shock hazard from the charge stored in the capacitor.