

Superseded by AS 2676.1-1992

AS 2676.1—1990

Australian Standard®

---

**Guide to the installation,  
maintenance, testing and  
replacement of secondary batteries  
in or on buildings**

**Part 1: Vented cells**

---

H



**STANDARDS AUSTRALIA** 

This Australian Standard was prepared by Committee EL/5, Secondary Batteries. It was approved on behalf of the Council of Standards Australia on 23 October 1989 and published on 11 June 1990.

---

The following interests are represented on Committee EL/5:

Australian Automobile Association  
Australian Automotive Aftermarket Association  
Australian Electrical and Electronic Manufacturers Association  
Australian Federation of Consumer Organizations  
Australian Lead Development Association  
Confederation of Australian Industry  
Department of Administrative Services—Australian Construction Services  
Department of Defence  
Electricity Supply Association of Australia  
Federal Chamber of Automotive Industries  
Railways of Australia Committee  
Telecom Australia

---

**Review of Australian Standards.** To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important, therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

---

Australian Standard®

---

**Guide to the installation,  
maintenance, testing and  
replacement of secondary batteries  
in or on buildings**

**Part 1: Vented cells**

---

First published as part of AS 2676—1983.  
Revised and redesignated in part as AS 2676.1—1989.

## PREFACE

This Standard was prepared by the Standards Australia Committee on Secondary Batteries, to partially supersede AS 2676—1983, *Installation and maintenance of batteries in buildings*.

The superseded Standard AS 2676—1983 is to be replaced by the following Standards:

- (a) AS 3011.1, *Electrical installations—Secondary batteries installed in buildings, Part 1: Vented cells*, which is a statement of minimum requirements and is intended to be suitable for reference in government regulations.
- (b) This Standard i.e. AS 2676.1—1990.
- (c) A proposed AS 3011.2 to cover sealed cells.
- (d) A proposed AS 2676.2 to cover sealed cells.

Over the last few years both the ampere-hour capacity and voltage of battery installations have increased to the point where some voltages now border on the medium and high voltage ranges. Even in extra-low voltage installations, short-circuits can cause fire and explosion because of the low internal resistance of batteries.

Tests have shown that batteries of 30 V and above are capable of producing levels of fault current that are difficult to interrupt, and that additional precautions need to be taken to reduce the possibility of accidental short-circuits.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the Head Office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

## CONTENTS

	<i>Page</i>
<b>SECTION 1 SCOPE AND GENERAL</b>	
1.1 SCOPE ....	5
1.2 REFERENCED DOCUMENTS ....	5
1.3 DEFINITIONS ....	5
<b>SECTION 2 DESIGN CONSIDERATIONS FOR D.C. SYSTEMS UTILIZING BATTERIES</b>	
2.1 GENERAL ....	8
2.2 BATTERY SIZE ....	8
2.3 METHOD OF CONNECTION ....	8
2.4 OPERATING CONDITIONS ....	8
2.5 BATTERY SHORT-CIRCUIT CURRENT ....	8
2.6 VOLTAGE DROP ....	8
2.7 CONNECTION BETWEEN BATTERY AND D.C. SWITCHBOARD ....	9
2.8 D.C. SWITCHBOARDS ....	9
2.9 TERMINALS AND CONNECTORS ....	9
2.10 D.C. SYSTEMS, EARTHING AND EARTH FAULT DETECTION ....	9
2.11 EARTH FAULT LOCATION ....	10
2.12 PROTECTION OF D.C. CIRCUITS ....	10
2.13 ALARMS ....	10
2.14 DUAL BATTERY SYSTEM ....	10
<b>SECTION 3 BATTERY ACCOMMODATION</b>	
3.1 GENERAL ....	11
3.2 LAYOUT AND LOCATION ....	11
3.3 VENTILATION ....	11
3.4 ACCESS ....	12
3.5 FLOOR LOADINGS ....	12
3.6 BATTERY ROOM FLOOR CONSTRUCTION AND FINISH ....	12
3.7 BATTERY ENCLOSURE CONSTRUCTION ....	13
3.8 LIGHTING AND POWER ....	13
3.9 SAFETY SIGNS ....	13
3.10 WATER SUPPLY ....	13
3.11 ARRANGEMENT OF CELLS ....	13
3.12 BATTERY STANDS ....	13
<b>SECTION 4 CHARGING</b>	
4.1 METHODS OF CHARGING ....	14
<b>SECTION 5 INSTALLATION AND COMMISSIONING</b>	
5.1 RECEIPT INSPECTION ....	16
5.2 UNPACKING ....	16
5.3 STORAGE ....	16
5.4 MOUNTING AND CONNECTION ....	16
5.5 COMMISSIONING ....	16
5.6 RECORDS ....	17
<b>SECTION 6 INSPECTION AND MAINTENANCE</b>	
6.1 INSPECTION ....	18
6.2 RECORDS ....	18
6.3 PILOT CELLS ....	19
6.4 MAINTENANCE ....	19
<b>SECTION 7 TESTING</b>	
7.1 GENERAL ....	21
7.2 CAPACITY TEST SCHEDULE ....	21

(continued)

	<i>Page</i>
7.3 TEST EQUIPMENT .....	21
7.4 PROCEDURE FOR BATTERY CAPACITY TESTS .....	21
7.5 BATTERY REPLACEMENT CRITERIA .....	22
<b>SECTION 8 SAFETY</b>	
8.1 GENERAL .....	25
8.2 HANDLING, MIXING AND STORING OF ELECTROLYTE .....	25
8.3 PROTECTIVE EQUIPMENT .....	25
8.4 SAFETY SIGNS .....	25
8.5 ELECTROLYTE BURNS .....	26
8.6 WATER SUPPLY .....	26
8.7 PRECAUTIONS .....	26
8.8 FIRE FIGHTING EQUIPMENT .....	27
<b>APPENDICES</b>	
A VENTILATION TO AVOID HYDROGEN CONCENTRATION IN BATTERY ROOMS AND BATTERY ENCLOSURES .....	28
B CORRECTIONS FOR THE EFFECTS OF ELECTROLYTE TEMPERATURE IN DETERMINING THE CAPACITY OF LEAD ACID BATTERIES .....	30
C INITIAL CHARGING AND COMMISSIONING OF VENTED LEAD-ACID BATTERIES .....	32
D INITIAL CHARGING AND COMMISSIONING OF NICKEL-CADMIUM ALKALINE BATTERIES .....	34
E TYPICAL D.C. SYSTEM EARTHING .....	35
F TYPICAL BATTERY STANDS .....	37
G TYPICAL SIGNS .....	39
H TYPICAL D.C. SYSTEM UTILIZING TWO BATTERIES .....	41
I A METHOD OF DETERMINING INTERNAL RESISTANCE .....	42
J TYPICAL BATTERY REPORT SHEET .....	43

## STANDARDS AUSTRALIA

## Australian Standard

Guide to the installation, maintenance, testing and replacement  
of secondary batteries buildings

## Part 1: Vented cells

## SECTION 1. SCOPE AND GENERAL

**1.1 SCOPE.** This Standard sets out recommended practices for the installation, maintenance, testing, and replacement of vented secondary batteries permanently installed in or on buildings. It is to be read in conjunction with AS 3011, Electrical installations—Secondary batteries installed in buildings, Part 1: Vented cells.

It also provides guidance to determine when batteries should be replaced.

This Standard covers secondary batteries with a nominal voltage of 24 V or greater, and a capacity exceeding 10 A.h at the one-hour rate and includes batteries comprising vented lead acid cells and alkaline batteries comprising vented cells, (such as nickel-cadmium cells).

This Standard covers requirements for components of the d.c. system of which the battery is a part, where these components comprise an essential part of the d.c. system.

**1.2 REFERENCED DOCUMENTS.** The following documents are referred to in this Standard:

AS

- 1006 Solid stem general purpose thermometers
- 1136 Low voltage switchgear and controlgear assemblies
- 1136.1 Part 1: General requirements
- 1319 Safety signs for the occupational environment
- 1668 SAA Mechanical Ventilation and Airconditioning Code
- 1668.1 Part 1: Fire precautions in buildings with air-handling systems
- 1680 Code of practice for interior lighting and the visual environment
- 1775 Low voltage switchgear and controlgear—Air-break switches isolators and fuse combination units (up to and including 2000 V a.c. and 1200 V d.c.)
- 2121 SAA Earthquake Code
- 2184 Low voltage switchgear and controlgear—Moulded-case circuit-breakers for rated voltages up to and including 600 V a.c. and 250 V d.c.
- 2191 Stationary batteries of the lead-acid Planté positive plate type
- 2562 Hydrometers—Portable syringe type for lead-acid batteries
- 2668 Water for use in secondary batteries
- 2669 Sulphuric acid for use in lead-acid batteries
- 3000 SAA Wiring Rules
- 3011 Electrical installations—Secondary batteries installed in buildings
- 3011.1 Vented cells
- 3011.1 Approval and test specification for miniature overcurrent circuit-breakers

**1.3 DEFINITIONS.** For the purpose of this Standard, the definitions below apply.

**1.3.1 Accessories**—items supplied with a battery to facilitate the continued operation of the battery.

NOTE: Such accessories include distilled water in containers, connectors, connecting bolts and nuts, hydrometers and other such items as agreed to by the purchaser and supplier.

**1.3.2 Authorized person**—the person in charge of the premises, or other person appointed or selected by the person in charge of the premises, to perform certain duties associated with the battery installation on the premises.

NOTE: In some States work on low and medium voltage equipment may only be undertaken by licensed personnel.