

Australian Standard<sup>®</sup>

**Fixed fire protection installations—  
Pumpset systems**

**STANDARDS**  
Australia



This Australian Standard® was prepared by Committee FP-008, Fire Service Pumps. It was approved on behalf of the Council of Standards Australia on 17 February 2008. This Standard was published on 30 May 2008.

---

The following are represented on Committee FP-008:

- Association of Consulting Engineers, Australia
  - Association of Hydraulic Services Consultants, Australia
  - Australasian Fire Authorities Council
  - Australian Chamber of Commerce and Industry
  - Consumers' Federation of Australia
  - Fire Protection Association, Australia
  - Insurance Council of Australia
  - Pump Industry Australia
- 

This Standard was issued in draft form for comment as DR 07193.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

---

#### **Keeping Standards up-to-date**

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting [www.standards.org.au](http://www.standards.org.au)

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at [mail@standards.org.au](mailto:mail@standards.org.au), or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

---

Australian Standard<sup>®</sup>

**Fixed fire protection installations—  
Pumpset systems**

Originally as AS 2941—1987.  
Fourth edition 2008.

**COPYRIGHT**

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia

ISBN 0 7337 8716 9

## PREFACE

This Standard was prepared by the Standards Australia Committee FP-008, Fire Service Pumps, to supersede AS 2941—2002.

Maintenance requirements for fire pumpsets are given in AS 1851, *Maintenance of fire protection systems and equipment* (Section 3: Fire pumpsets).

The symbols used in this Standard comply with those given in HB 20, *Graphical symbols for fire protection drawings*, and have been developed from ISO Standards. The typical illustrations are in diagrammatic form only.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

### Notes and Commentaries

The use of Notes in this Standard is of an advisory nature only. They provide explanations and guidance on recommended design consideration or technical procedures, as well as an informative cross-reference to other documents or publications.

*This Standard incorporates a commentary on some of the clauses. The commentary directly follows the relevant clause, is designated by ‘C’ preceding the clause number and is printed in italics in a box. The commentary is for information and guidance.*

## CONTENTS

	<i>Page</i>
FOREWORD.....	6
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE .....	7
1.2 OBJECTIVE .....	7
1.3 NORMATIVE REFERENCES.....	7
1.4 DEFINITIONS .....	7
SECTION 2 WATER SUPPLIES	
2.1 GENERAL .....	11
2.2 ACCEPTABLE SOURCES OF SUPPLY .....	11
2.3 QUALITY OF WATER.....	11
2.4 FLOODED SUCTION.....	11
2.5 SUCTION.....	11
SECTION 3 GENERAL REQUIREMENTS FOR FIRE PROTECTION PUMPSETS	
3.1 PERFORMANCE CHARACTERISTICS.....	12
3.2 PUMP TYPES .....	15
3.3 TYPES OF DRIVERS .....	17
3.4 PUMP/DRIVER CONNECTION .....	17
3.5 BASEPLATE.....	17
3.6 PIPEWORK.....	17
3.7 VALVES .....	18
3.8 VISIBILITY OF DISCHARGE .....	22
3.9 PRESSURE GAUGES.....	22
3.10 FLOW-MEASURING DEVICES.....	22
3.11 STARTING AND CONTROL .....	23
3.12 ELECTRICAL REQUIREMENTS.....	23
3.13 MARKING AND COLOUR CODING.....	24
3.14 PUMPSET MANUALS.....	26
3.15 PUMPSET CONFIGURATIONS .....	26
SECTION 4 SPECIFIC REQUIREMENTS FOR FIRE PROTECTION PUMPS	
4.1 GENERAL .....	32
4.2 END-SUCTION PUMPS.....	34
4.3 AXIALLY SPLIT CASE PUMPS (HORIZONTAL OR VERTICAL SHAFT).....	34
4.4 MULTISTAGE CENTRIFUGAL PUMPS .....	34
4.5 TURBINE TYPE CENTRIFUGAL PUMPS (VERTICAL SHAFT) .....	35
4.6 DRIVERS FOR VERTICAL TURBINE PUMPS.....	37
SECTION 5 REQUIREMENTS FOR PRESSURE MAINTENANCE PUMPS	
5.1 GENERAL .....	38
5.2 GENERAL REQUIREMENTS FOR JOCKEY PUMPS .....	38
5.3 GENERAL REQUIREMENTS FOR JACKING PUMPS.....	39
SECTION 6 FIRE HOSE REEL PUMPSETS	
6.1 GENERAL .....	41
6.2 PRE-ASSEMBLED FIRE HOSE REEL PUMPSETS .....	41
6.3 TYPES.....	41

6.4	OPERATION.....	41
6.5	ELECTRICAL.....	41
6.6	VALVES.....	42
6.7	UNIONS.....	42
6.8	MAXIMUM ALLOWABLE WORKING PRESSURE.....	42
6.9	MARKING.....	42
<b>SECTION 7 RESIDENTIAL SPRINKLER PUMPSETS</b>		
7.1	GENERAL.....	44
7.2	PRE-ASSEMBLED RESIDENTIAL SPRINKLER PUMPSETS.....	44
7.3	PUMPSET TYPE.....	44
7.4	OPERATION.....	44
7.5	ELECTRICAL.....	45
7.6	VALVES.....	45
7.7	UNIONS.....	45
7.8	MAXIMUM ALLOWABLE WORKING PRESSURE.....	45
7.9	MARKING.....	45
<b>SECTION 8 ELECTRIC DRIVERS AND CONTROLLERS</b>		
8.1	ELECTRIC DRIVERS.....	47
8.2	ELECTRIC CONTROLLERS.....	48
8.3	WIRING.....	52
<b>SECTION 9 COMPRESSION-IGNITION DRIVERS AND CONTROLLERS</b>		
9.1	DRIVER TYPE.....	53
9.2	DRIVER PERFORMANCE.....	53
9.3	DRIVER SYSTEMS.....	54
9.4	COMPRESSION-IGNITION DRIVER CONTROLLERS.....	60
9.5	ELECTRICAL CONNECTIONS ON ENGINE.....	64
9.6	SPARE PARTS.....	64
<b>SECTION 10 SHOP TESTING AND CONFORMANCE</b>		
10.1	GENERAL.....	68
10.2	HYDROSTATIC TESTS.....	68
10.3	PERFORMANCE TESTS.....	68
10.4	CONFORMANCE.....	70
<b>SECTION 11 SITING AND INSTALLATION</b>		
11.1	GENERAL.....	71
11.2	TEMPERATURE.....	71
11.3	LOCATION.....	71
11.4	LIGHTING.....	71
11.5	VENTILATION.....	71
11.6	DRAINAGE.....	71
11.7	PLINTHS.....	71
11.8	PROTECTION OF THE OVERALL SYSTEM AGAINST DAMAGE DUE TO MOVEMENT OR PRESSURE.....	72
11.9	IDENTIFICATION OF PIPEWORK.....	72
<b>SECTION 12 COMMISSIONING TESTING</b>		
12.1	GENERAL.....	73
12.2	ELECTRIC MOTOR PUMPSETS.....	73
12.3	COMPRESSION-IGNITION ENGINE PUMPSETS.....	74
12.4	AUTOMATIC PRESSURE MAINTENANCE (JOCKEY) PUMPSETS.....	76

## APPENDICES

A	NORMATIVE REFERENCES .....	77
B	BORES FOR WATER SUPPLY DEDICATED TO FIREFIGHTING .....	79
C	GUIDELINES FOR THE SELECTION OF DRIVERS .....	82
D	OPERATIONAL WARNING SIGNS (TYPICAL).....	84
E	WIRING SYSTEMS RATING .....	85
F	THE PUMPHOUSE.....	87
G	GUIDE TO EXHAUST SYSTEM SIZE SELECTION.....	88
H	TYPICAL PERFORMANCE TEST DATA SHEETS .....	90
I	TYPICAL PUMP START ARRANGEMENTS .....	92
J	BIBLIOGRAPHY.....	94

Currently in preview, click buy full version

## FOREWORD

This Standard sets out to provide requirements for pumpset systems to suit various types of fire protection systems such that a reasonable degree of protection for life and property from fire may be achieved. These requirements are based on sound engineering principles, test data and field experience.

Although the installation of a pumphouse is not a requirement of this Standard, the Committee has considered the fire pumpset and its ancillary equipment as being ideally located in a pumphouse. Requirements are established for the selection, installation and operation of fire pumps, pump drivers and associated equipment, however, the Standard does not consider the number, disposition or types of driver considered appropriate for a given fixed fire protection system. The term 'driver' is used in lieu of the term 'engine' or 'motor'.

The committee did not consider the initiation of the starting sequence outside the pumphouse to be within the scope of this Standard. Instead, it has considered the processing of signals entering the pumphouse.

The Standard provides minimum performance requirements for pumpsets including motors, engines, fire pump controllers, batteries and related ancillaries. The Standard requires that pumpsets be shop-tested as an assembly, that is, the pump driver and fire pump controller are to be checked as a working combination (and appropriate test confirmed) prior to dispatch from the pumpset assembler's works. Further testing will be required following final installation on site, and the Standard requires the incorporation of a flow-measuring device at each pumpset, unless provided elsewhere, to facilitate commissioning and subsequent periodic testing.

The Standard requires that each pump be provided with circulation relief to protect the pump from damage when exposed to extended periods of operation at or near shut-off head. It also requires that some pumps be provided with a pressure-relief/flow control valve to protect downstream piping from overpressurization and protect the pump against suction and discharge recirculation. Circulation and pressure-relief flow control requirements are addressed in Section 3.

This edition requires automatic overspeed shutdown facilities on compression-ignition (diesel) engine-driven pumpsets. It includes new provisions for optional variable speed control on both compression-ignition engine and electric motor pump drivers. The increasing use of electronic engine management systems has also been recognized with the incorporation of new requirements for such systems that control the fuel injection process.

## STANDARDS AUSTRALIA

## Australian Standard

## Fixed fire protection installations—Pumpset systems

## SECTION 1 SCOPE AND GENERAL

**1.1 SCOPE**

This Standard specifies requirements for pumpset systems for use with fixed fire protection installations such as sprinkler, hydrant, water spray, and hose reel systems. It covers water supplies and specific requirements for pumps, drivers, fire pump controllers, and auxiliary equipment. Requirements for installation and acceptance testing for electrical and compression-ignition drivers are also included.

## NOTES:

- 1 Some special fire pump installations (e.g., at petrochemical and petroleum plants and small rural installations) may require variations from the requirements of this Standard.
- 2 Pumpsets covered by this Standard are generally represented in Figures 3.5 and 3.7.

**1.2 OBJECTIVE**

The objective of this Standard is to provide designers, manufacturers, installers and testers with minimum requirements for the design, manufacture, installation and commissioning testing of fire pumpsets.

**1.3 NORMATIVE REFERENCES**

The documents referenced in this Standard for normative purposes are listed in Appendix A.

NOTE: Documents referenced for informative purposes are listed in Appendix J, Bibliography.

**1.4 DEFINITIONS**

For the purposes of this Standard, the definitions below apply.

**1.4.1 Approved**

Listed in the 'Register of accredited products', issued by CSIRO—MIT, as complying with the requirements of this Standard; or approved for fire protection duty by an internationally recognized testing laboratory and approval body such as—

- (a) Factory Mutual (FM);
- (b) Underwriters Laboratories (UL);
- (c) Loss Prevention Council (LPC);
- (d) Verband der Schadenverhütung (VdS);

**1.4.2 Circulation relief**

Prevention of overheating by providing a flow of water to waste when the pump is operating with no discharge.