

PP2 ED.

AS 3011.1—1990

3011 Electrical installations—Secondary batteries installed in buildings
3011.1—1992 Vented cells
(In Professional Package 24) 6pp CC
Specifies requirements for the installation of vented secondary batteries permanently installed in buildings.
Committee ELS. Supersedes AS 3011.1—1990. Publication date 1992-03-16.
ISBN 0 7262 7305 8

Australian Standard®

Electrical installations — Secondary
batteries installed in buildings

Part 1: Vented cells



This Australian Standard was prepared by Committee EL/5, Secondary Batteries. It was approved on behalf of the Council of Standards Australia on 23 October 1989 and published on 11 June 1990.

The following interests are represented on Committee EL/5:

Australian Automobile Association
Australian Automotive Aftermarket Association
Australian Electrical and Electronic Manufacturers Association
Australian Federation of Consumer Organizations
Australian Lead Development Association
Confederation of Australian Industry
Department of Administrative Services—Australian Construction Services
Department of Defence
Electricity Supply Association of Australia
Federal Chamber of Automotive Industries
Institution of Engineers Australia
Railways of Australia
Telecom Australia

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

Australian Standard®

**Electrical installations—Secondary
batteries installed in buildings**

Part 1: Vented cells

First published as Part of AS 2676—1983.
Revised and redesignated in part as AS 3011—1987.
AS 3011—1987 revised and redesignated AS 3011.1—1990.

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
STANDARDS HOUSE, 80 ARTHUR ST, NORTH SYDNEY NSW

ISBN 0 7262 5998 5

PREFACE

This Standard was prepared by the Standards Australia Committee on Secondary Batteries to supersede AS 3011—1987. It is to be read in conjunction with AS 2676.1, *Guide to the installation, maintenance, testing and replacement of secondary batteries in or on buildings, Part 1: Vented cells*.

This Standard is intended as a statement of minimum requirements and is intended to be suitable for reference in Government regulations.

This Standard covers the installation of vented cells only. The Standards Australia Committee on Secondary Batteries proposes—

- (a) a Part 2 of AS 3011 to cover sealed cells; and
- (b) a Part 2 of AS 2676 covering sealed cells.

Over the last few years both the ampere-hour capacity and voltage of battery installations have increased to the point where some voltages now border on the medium and high-voltage range. Even in extremely low voltage installations the low internal resistances of batteries under short-circuit conditions can cause severe injuries to staff working on a battery or cell, or cause fire and explosion.

Recent tests have shown that batteries of 30 V and above may present problems in breaking fault currents and that additional precautions need to be taken to reduce the possibility of accidental short-circuits.

In preparing this Standard the Committee considered the requirements of both vented lead-acid cells and vented alkaline cells.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the Head Office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
SECTION 1. SCOPE AND GENERAL	
1.1 SCOPE	4
1.2 REFERENCED DOCUMENTS	4
1.3 DEFINITIONS	4
SECTION 2 GENERAL REQUIREMENTS	
2.1 GENERAL	5
2.2 BATTERY ROOM REQUIREMENTS	5
2.3 BATTERY ENCLOSURE REQUIREMENTS	5
SECTION 3 INSTALLATION	
3.1 GENERAL	7
3.2 CONNECTIONS	7
3.3 PROTECTION	7
APPENDIX A. BATTERY ROOM LAYOUT, MANDATORY DIMENSION	8

STANDARDS AUSTRALIA

Australian Standard

Electrical installations—Secondary batteries installed in buildings

Part 1: Vented cells

SECTION 1. SCOPE AND GENERAL

1.1 SCOPE. This Standard sets out essential requirements for the installation of vented secondary batteries, with a nominal voltage exceeding 24 V and a capacity exceeding 10 A.h at the 1-h rate, permanently installed in or on buildings, structures or premises for ensuring safety from fire and electric shock.

1.2 REFERENCED DOCUMENTS. The following documents are referred to in this Standard:

AS

1136 Low voltage switchgear and controlgear assemblies

1136.1 Part 1: General requirements

1775 Low voltage switchgear and controlgear—Air-break switches, isolators and fuse combination units (up to and including 1000 V a.c. and 1200 V d.c.)

2676 Guide to the installation, maintenance, testing and replacement of secondary batteries in buildings

2676.1 Part 1: Vented cells

3000 SAA Wiring Rules

1/21 (IEV 486)(Central Office)1246/289 Draft—Chapter 4.5: Storage batteries

1.3 DEFINITIONS. For the purpose of this Standard, the following definitions apply:

1.3.1 Authorized person—the person in charge of the premises, or other person appointed or selected by the person in charge of the premises, to perform certain duties associated with the battery installation on the premises.

NOTE: In some States work on low and medium voltage equipment may only be undertaken by licensed personnel.

1.3.2 Battery enclosure—an enclosure containing batteries that are suitable for use in an area other than a battery room or an area restricted to authorized personnel.

1.3.3 Battery room—a room specifically intended for the installation of batteries that normally have no other protective enclosure.

1.3.4 Charge (of a battery)—an operation during which a battery receives, from an external circuit, electrical energy which is converted into chemical energy.

1.3.5 Nominal voltage—a suitable approximate value of voltage used to identify a type of battery.

***1.3.6 Secondary cell or battery**—an electrochemical system capable of storing under chemical form the electrical energy received and which can give it back by reconversion.

***1.3.7 Secondary cell**—an assembly of electrodes and electrolytes which constitutes the basic unit of a battery.

***1.3.8 Secondary battery**—two or more cells electrically connected and used as a source of energy.

* As defined in 1/21 (IEV 486)(Central Office)1246/289.