

See also Seminar papers AS 3190

Australian Standard®

**Approval and test specification—
Residual current devices
(current-operated earth-leakage
devices)**

H

**STANDARDS AUSTRALIA**

This Australian Standard was prepared by Committee EL/4, Electrical Accessories. It was approved on behalf of the Council of Standards Australia on 23 May 1990 and published on 29 June 1990.

The following interests are represented on Committee EL/4:

Australian Electrical and Electronic Manufacturers Association
Confederation of Australian Industry
Department of Public Works, N.S.W.
Electrical Contractors Association of Australia
Electricity Supply Association of Australia
Plastics Industry Association
Railways of Australia Committee
Regulatory Authorities (Electrical)
Telecom Australia

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

Australian Standard®

**Approval and test specification—
Residual current devices
(current-operated earth-leakage
devices)**

First published as AS 3190—1974.
Second edition 1980.
Third edition 1983.
Fourth edition 1990.

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
STANDARDS HOUSE, 80 ARTHUR ST, NORTH SYDNEY NSW

ISBN 0 7262 6365 6

PREFACE

This Standard was prepared by the Standards Australia Committee on Electrical Accessories to supersede AS 3190—1983, *Approval and test specification for current-operated (core balance) earth-leakage devices*.

It is one of a series of Approval and Test Specifications issued by Standards Australia. These Specifications are accompanied by a general specification AS 3100, containing definitions and general requirements for electrical materials and equipment. The purpose of these Specifications is to outline conditions which must be met to secure approval for the sale and use of electrical equipment in Australia. Only safety matters and related conditions are covered.

This Standard was revised to incorporate Amendment No. 1, April 1985 (which affected Clauses 2.3, 3 and 4.2 and Appendix C) and introduces other technical and editorial changes such as—

- Retitling and use of the generic and internationally accepted term 'residual current device (rcd)' in lieu of the former 'current-operated (core balance) earth-leakage devices', in line with current Australian and overseas practice.
- Introduction of classifications (and tests/requirements) for portable rcd's for household use, and for general industrial use.
- Introduction of tests/requirements for Class L portable rcd's for alignment with AS 3100, *Approval and test specification—Electrical portable outlet devices*.
- Alteration of some existing tests/requirements, e.g. the test facility percentage of rated residual current.
- Amendment of existing, and inclusion of new definitions and marking requirements, including user instructions.
- Introduction of tests/requirements for reliability and ageing of electronic components in line with the latest International Electrotechnical Commission (IEC) documents.
- Allowance for the future introduction (at this stage, under consideration) of tests/requirements for resistance to unwanted tripping due to impulse voltages.
- Introduction of rcd's with selective tripping time delay characteristics, via a new Type IV classification.
- Provision for tripping tests at rated and high residual currents with amended tripping times specified.

This Standard supersedes AS 3190—1983 (including Amendment No. 1, April 1985) on publication, with the exception of the indicated passages in Clauses 6.7.1 and 6.7.5. Also, it should be noted that Clauses 8.1.2 and 9.17 and Appendix D form part of this Specification 12 months from date of publication.

Attention is drawn to Appendix E which details the additional tests/requirements for approval of portable rcd's in New Zealand. For such compliance in New Zealand, portable rcd's are required to comply with the appropriate requirements of this Specification, except as varied by Appendix E.

It is generally accepted that Type III and Type IV rcd's (see Clause 5.1) do not provide adequate personal protection however, they are within the scope of this Specification.

Standards Australia points out that this Specification does not purport to include all the necessary provisions of a contract.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the Head Office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
1 SCOPE	4
2 APPLICATION	4
3 REFERENCED DOCUMENTS	4
4 DEFINITIONS	5
5 CLASSIFICATION	5
6 DESIGN AND CONSTRUCTION	6
7 ELECTRICAL REQUIREMENTS	8
8 MARKING	9
9 TESTS	12
APPENDICES	
A REQUIREMENTS FOR TYPE I RCDs	21
B IMPULSE WITHSTAND TEST	22
C HIGH-FREQUENCY DISTURBANCE TEST	23
D RELIABILITY	25
E ADDITIONAL TESTS/REQUIREMENTS FOR APPROVAL OF PORTABLE RCDs IN NEW ZEALAND	29

STANDARDS AUSTRALIA

Australian Standard

Approval and test specification—Residual current devices
(Current-operated earth-leakage devices)

1 SCOPE This Specification applies to residual current devices and residual current relays (of the current-operated type), with a rated residual current not exceeding 300 mA, designed for operation at low or medium voltage, having a rated load current not exceeding 100 A a.c., and intended to isolate supply or initiate a tripping signal in the event of a current flow to earth in the protected circuit, in excess of a predetermined level.

This Specification does not apply to residual current units whose design is dedicated for use with a (particular) circuit-breaker, other than a miniature overcurrent circuit-breaker as defined in Appendix A of AS 3111.

NOTE: It is intended that residual current units associated with circuit-breakers rated in excess of 100 A, either integrally or as an added unit, be covered by a separate Standard.

It is not intended that this Specification apply to residual current devices or other earth-leakage devices for the protection of Supply Authority distribution systems, or for protection of equipment in mines covered by AS 2081.

2 APPLICATION

2.1 General requirements of AS 3100 This Specification shall be read in conjunction with AS 3100, and the appropriate provisions of AS 3100 shall apply to the construction of the rcd or relay and the insulation and safeguarding of parts that normally carry current.

2.2 Specific requirements of this Specification An rcd or relay shall be deemed to comply with this Specification only if—

- (a) *of Types II, III and IV*, it complies with all the appropriate requirements of this Specification and passes the relevant tests specified herein; and
- (b) *of Type I*, it complies with all the appropriate requirements of this Specification and passes the relevant tests specified herein, except as varied by Appendix A.

Unless a specific requirement is stated for a portable rcd, it shall be understood that any requirement given herein for an rcd applies to a portable rcd.

2.3 Requirements of other Specifications Equipment and components incorporated in an rcd or relay which are dependent upon for safety, shall comply with the appropriate requirements of any relevant Approval and test specification, unless such requirements are varied herein.

Portable residual current devices which incorporate a control or conditioning function shall, in addition to the requirements of this Specification, comply with the relevant requirements of AS 3197.

3 REFERENCED DOCUMENTS The documents below are referred to in this Specification.

STANDARDS

AS	
1099	Basic environmental testing procedures for electrotechnology
1099.2Db	Damp heat, cyclic (12 + 12 hours)
1099.2.3	Section 3—Guidance for damp heat tests
1931	High voltage testing techniques
1931.1	Part 1: General definitions, test requirements, test procedures and measuring devices
1939	Classification of degrees of protection provided by enclosures for electrical equipment
2081	Electrical equipment for coal and shale mines—Electrical protection devices
2481	All-or-nothing electrical relays (instantaneous and timing relays)
3000	SAA Wiring rules