

DUP  
Under revision see DR 95337

SUPERSEDED BY AS/NZS 3191:1996

Australian Standard®

---

**Approval and test specification—  
Electric flexible cords**

---

This Australian Standard was prepared by Committee EL/3, Electric Wires and Cables. It was approved on behalf of the Council of Standards Australia on 6 May 1994 and published on 22 August 1994.

---

The following interests are represented on Committee EL/3:

Australian Electrical and Electronic Manufacturers Association  
Department of Defence, Australia  
Electrical regulatory authorities  
Electricity Supply Association of Australia  
Ministry of Commerce, New Zealand  
New Zealand Electrical Contractors Association  
New Zealand Electrical and Electronic Manufacturers Federation  
Office of Energy, N.S.W.  
Railways of Australia Committee  
Testing interests

---

*Review of Australian Standards.* To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

---

*This Standard was issued in draft form for comment as DR 93273.*

Australian Standard®

---

**Approval and test specification—  
Electric flexible cords**

---

AS 3191—1991 first published as part of  
AS C147—1950.  
Second edition 1955.  
Third edition 1967.  
Fourth edition 1969.  
Fifth edition 1972.  
Revised and redesignated in part as AS 3191—1974.  
AS C147—1972 withdrawn 1976.  
Second edition AS 3191—1981.  
Third edition 1991.  
Fourth edition 1994.

## PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL/3 on Electric Wires and Cables to supersede AS 3191—1991, *Approval and test specification—Electric flexible cords*.

It specifies construction and test criteria for flexible cords insulated with PVC, crosslinked elastomers, glass fibre or thermoplastic fluoropolymers which, dependent on cord type, are designed for working voltages up to and including 250/250 V, 250/440 V or 0.6/1 kV.

This Standard is one of a series of approval and test specifications issued by Standards Australia. The specifications are accompanied by a general specification, AS 1100, containing definitions and general requirements for electric materials and equipment. The purpose of these specifications is to outline the conditions which must be met to secure approval for the sale and use of electrical equipment in Australia. Only safety matters and conditions closely allied thereto are covered. For guidelines on purchasing flexible cords, see Appendix A.

This Standard differs from the 1991 edition as follows:

- (a) The V-105 insulation in Table 1.1, while having retained the criteria, has now been redesignated as V-90 HT (i.e. a higher temperature endurance version of V-90) insulation and permits conductor operating temperature up to a maximum of 105°C for limited periods (see Note 1 to Table 1.1).

Accordingly, the V-105 insulated cables in Table 2.2 and Clause 2.10.8 have been similarly redesignated as V-90 HT insulated.

- (b) Marking Clauses 2.8.1(c) and 2.8.3(e) have been extended for R-S-150 insulated and GP-90-CSP or GP-90-CPE sheathed cords. Marking for V-90 HT has been added.
- (c) V-105 insulation has been deleted from Clause 2.10.10.

The term 'informative' has been used in this Standard to define the application of the appendix to which it applies. An 'informative' appendix is only for information and guidance.

### © Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

## CONTENTS

*Page***SECTION 1 SCOPE AND GENERAL**

1.1	SCOPE .....	6
1.2	REFERENCED DOCUMENTS .....	6
1.3	DEFINITIONS .....	6
1.4	MAXIMUM CONTINUOUS CONDUCTOR TEMPERATURE .....	7
1.5	VOLTAGE DESIGNATION .....	7

**SECTION 2 PVC OR CROSSLINKED ELASTOMER INSULATED FLEXIBLE CORDS**

2.1	CONDUCTORS .....	8
2.2	INSULATION .....	8
2.3	LAY-UP OF CORES .....	11
2.4	FILLERS AND BINDERS .....	11
2.5	SCREENS .....	11
2.6	SHEATH .....	12
2.7	NON-METALLIC BRAID .....	13
2.8	MARKING .....	14
2.9	TESTS .....	15
2.10	CONSTRUCTION AND DIMENSIONS .....	15

**SECTION 3 GLASS FIBRE INSULATED FLEXIBLE CORDS**

3.1	CONDUCTORS .....	34
3.2	INSULATION .....	34
3.3	LAY-UP OF CORES .....	34
3.4	FILLERS .....	34
3.5	GLASS FIBRE PROTECTIVE BRAID .....	35
3.6	MARKING .....	35
3.7	TESTS .....	35
3.8	CONSTRUCTION AND DIMENSIONS .....	35

**SECTION 4 THERMOPLASTIC FLUOROPOLYMER INSULATED FLEXIBLE CORDS**

4.1	CONDUCTORS .....	39
4.2	INSULATION .....	39
4.3	MARKING OF COILS OR REELS .....	39
4.4	TESTS .....	39
4.5	CONSTRUCTION AND DIMENSIONS .....	41

**APPENDICES**

A	PURCHASING GUIDELINES .....	42
B	NOTES ON CALCULATION OF DIMENSIONS OF FLEXIBLE CORDS ...	43

## TABLES

Page

1.1	MAXIMUM CONTINUOUS CONDUCTOR TEMPERATURE . . . . .	7
2.1	TESTS AND CRITERIA FOR CROSSLINKED ELASTOMER INSULATION . . . . .	9
2.2	TESTS AND CRITERIA FOR PVC INSULATION . . . . .	10
2.3	TESTS AND CRITERIA FOR CROSSLINKED ELASTOMER SHEATHS . . . . .	13
2.4	TESTS AND CRITERIA FOR PVC SHEATHS . . . . .	14
2.5	TESTS ON PVC OR CROSSLINKED ELASTOMER INSULATED CORD—CRITERIA, CATEGORY AND REFERENCE . . . . .	16
2.6	DIMENSIONS OF 250/250 V CROSSLINKED ELASTOMER INSULATED, TEXTILE BRAIDED 2 AND 3 CORE FLEXIBLE CORDS . . . . .	17
2.7	DIMENSIONS OF 250/440 V CROSSLINKED ELASTOMER INSULATED AND SHEATHED ORDINARY DUTY 2, 3, 4 AND 5 CORE CIRCULAR FLEXIBLE CORDS . . . . .	18
2.8	DIMENSIONS OF 250/250 V CROSSLINKED ELASTOMER INSULATED, UNPROTECTED SINGLE CORE FLEXIBLE CORDS . .	19
2.9	DIMENSIONS OF 250/440 V CROSSLINKED ELASTOMER INSULATED, SHEATHED, SCREENED AND OVERALL SHEATHED 2, 3 AND 4 CORE CIRCULAR FLEXIBLE CORDS . . . . .	20
2.10	DIMENSIONS OF 250/440 V R-S-150 CROSSLINKED ELASTOMER INSULATED AND GP-150-S SHEATHED ORDINARY DUTY 2 AND 3 CORE CIRCULAR FLEXIBLE CORDS . . . . .	21
2.11	DIMENSIONS OF 250/250 V R-S-150 CROSSLINKED ELASTOMER INSULATED, GLASS FIBRE BRAIDED, SINGLE, 2 AND 3 CORE FLEXIBLE CORDS . . . . .	22
2.12.1	DIMENSIONS OF 250/440 V ORDINARY DUTY PVC INSULATED, UNPROTECTED SINGLE CORE FLEXIBLE CORDS . . . . .	23
2.12.2	DIMENSIONS OF 6/1 kV HEAVY DUTY PVC INSULATED, UNPROTECTED SINGLE CORE FLEXIBLE CORDS . . . . .	23
2.13	DIMENSIONS OF 250/250 V PVC INSULATED, UNPROTECTED, PARALLEL WEBBED 2 CORE FLAT FLEXIBLE CORDS . . . . .	24
2.14	DIMENSIONS OF 250/440 V PVC INSULATED AND SHEATHED, ORDINARY DUTY 2, 3, 4 AND 5 CORE CIRCULAR FLEXIBLE CORDS . . . . .	25
2.15	DIMENSIONS OF 250/440 V PVC INSULATED AND SHEATHED, ORDINARY DUTY 2 CORE FLAT FLEXIBLE CORDS . . . . .	26
2.16	DIMENSIONS OF 250/250 V PVC INSULATED AND SHEATHED, LIGHT DUTY 2 CORE FLAT, AND 2 OR 3 CORE CIRCULAR FLEXIBLE CORDS . . . . .	27
2.17	DIMENSIONS OF 250/250 V PVC INSULATED, TEXTILE BRAIDED 2 AND 3 CORE FLEXIBLE CORDS . . . . .	28
2.18	DIMENSIONS OF 250/440 V PVC INSULATED, SHEATHED, SCREENED AND OVERALL SHEATHED 2, 3 AND 4 CORE CIRCULAR FLEXIBLE CORDS . . . . .	29

2.19	DIMENSIONS OF 0.6/1 kV CROSSLINKED ELASTOMER INSULATED AND SHEATHED, HEAVY DUTY SINGLE CORE FLEXIBLE CORDS .....	30
2.20	DIMENSIONS OF 0.6/1 kV PVC INSULATED AND SHEATHED, HEAVY DUTY SINGLE CORE FLEXIBLE CORDS .....	31
2.21	DIMENSIONS OF 0.6/1 kV CROSSLINKED ELASTOMER INSULATED AND SHEATHED, HEAVY DUTY 2, 3, 4 AND 5 CORE CIRCULAR FLEXIBLE CORDS .....	32
2.22	DIMENSIONS OF 0.6/1 kV PVC INSULATED AND SHEATHED, HEAVY DUTY 2, 3, 4 AND 5 CORE CIRCULAR FLEXIBLE CORDS .....	33
3.1	TESTS ON GLASS FIBRE INSULATED CORD—CRITERIA, CATEGORY AND REFERENCE .....	36
3.2	DIMENSIONS OF 0.6/1 kV GLASS FIBRE INSULATED AND GLASS BRAID PROTECTED SINGLE, 2 AND 3 CORE FLEXIBLE CORDS ..	37
3.3	DIMENSIONS OF 0.6/1 kV GLASS FIBRE INSULATED, UNPROTECTED, SINGLE CORE FLEXIBLE CORDS .....	38
4.1	TESTS ON THERMOPLASTIC FLUOROPOLYMER INSULATED CORD—CRITERIA, CATEGORY AND REFERENCE .....	40
4.2	DIMENSIONS OF 250/250 V THERMOPLASTIC FLUOROPOLYMER INSULATED, UNPROTECTED, SINGLE CORE FLEXIBLE CORDS ..	41

## STANDARDS AUSTRALIA

**Australian Standard**  
**Approval and test specification—**  
**Electric flexible cords**

## SECTION 1 SCOPE AND GENERAL

**1.1 SCOPE** This Standard specifies construction, dimensions and tests for flexible cords insulated with PVC, crosslinked elastomers, glass fibre or thermoplastic fluoropolymers which, dependent on cord type, are designed for working voltages up to and including 250/250 V, 250/440 V or 0.6/1 kV.

NOTE: This Standard is intended to apply only to flexible cords of the types and sizes which are included. It is not intended, however, that other types or sizes of flexible cord should be precluded from use, and regulatory authorities will consider the issue of Certificate of Suitability for connection to the supply mains under the non-declared scheme for other types and sizes as they are developed. Any application for such certification should be accompanied by a description of the flexible cord.

**1.2 REFERENCED DOCUMENTS** The following documents are referred to in this Standard:

AS

1125 Conductors in insulated electric cables and flexible cords

1660 Methods of test for electric cables, cords and conductors

3000 SAA Wiring Rules

SAA

MP49 Register of colours of manufacturers' identification threads for electric cables and flexible cords

**1.3 DEFINITIONS** For the purposes of this Standard, the definitions in the referenced Standards and those below apply.

**1.3.1 Approximate value**—a value which is neither guaranteed nor checked.

**1.3.2 Core**—the conductor with its insulation but not including any protective covering.

**1.3.3 Flexible cord**—a flexible cable, of which no wire exceeds 0.31 mm diameter and no conductor exceeds a 4 mm<sup>2</sup> cross-sectional area, and having not more than five cores.

**1.3.4 Maximum continuous conductor temperature**—the maximum temperature at which the conductor of the cord may be operated continuously, and is the temperature resulting from the combined effect of the ambient temperature and the current loading on the conductor.

**1.3.5 Multicore cord**—a cord comprising two or more cores.

**1.3.6 Pitch circle diameter**—the diameter of a circle which passes through the midpoints of the laid-up cores.

**1.3.7 Routine tests**—tests made by the manufacturer on all completed cord to demonstrate its integrity.

**1.3.8 Sample tests**—tests made on samples of completed cord, or components taken from completed cord, to verify that the finished product meets the design specification.

**1.3.9 Special tests**—tests made by the manufacturer on samples of completed cord, or components taken from a completed cord, at a specified frequency, to verify that the finished product meets the design specifications.