

Under Revision see DR 95231

SUPERSEDED BY AS/NZS 3198:1996

AS 3198—1990

Australian Standard®

**Approval and test specification—
Electric cables—XLPE insulated—
For working voltages up to and
including 0.6/1 kV**

Currently in preview, click to buy full version

G



This Australian Standard was prepared by Committee EL/3, Electric Wires and Cables. It was approved on behalf of the Council of Standards Australia on 19 March 1990 and published on 6 August 1990.

The following interests are represented on Committee EL/3:

Australian Electrical and Electronic Manufacturers Association
Department of Defence
Department of Minerals and Energy, New South Wales
Electrical Contractors Associations of Australia
Electrical Regulatory Authorities
Electricity Supply Association of Australia
Railways of Australia Committee
Regulatory Authorities
Testing Interests

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

Australian Standard®

**Approval and test specification—
Electric cables—XLPE insulated—
For working voltages up to and
including 0.6/1 kV**

First published as AS 3198—1977.
Second edition 1990.

PREFACE

This Standard was prepared by Standards Australia Committee on Electric Wires and Cables to supersede AS 3198—1977, *Approval and test specification for XLPE insulated electric cables for working voltages, up to and including 0.6/1 kV*.

This Standard is one of a series of approval and test specifications issued by Standards Australia. These specifications are accompanied by a general specification, AS 3100, containing definitions and general requirements for electric materials and equipment. The purpose of these specifications is to outline the conditions which must be met to secure approval for the sale and use of electrical equipment in Australia. Only safety matters and conditions closely allied thereto are covered. For guidance on details for enquiry and order, see Appendix C.

This Standard differs from the 1977 edition as follows:

- (a) A range of halogen free cables featuring low smoke emission, and low flame propagation properties in fire conditions has been included. Additional insulation and sheath materials have been specified for these cables together with an appropriate range of tests and criteria.
- (b) Major changes have been made to the tables of tests and criteria for insulation, non-metallic outer sheaths and cable.
- (c) The provisions for cables with metallic layers have been considerably expanded.
- (d) Cables with copper-clad aluminium conductors have been deleted.
- (e) The approximate overall diameters quoted in the tables of dimensions have been recalculated and except for single core cables with solid sectoral conductors, tables no longer provide dimensions for cables with solid aluminium conductors.
- (f) The provision for interlocked steel tape armour has been deleted.
- (g) Appendix A specifies the fictitious calculation method for the determination of the dimensions of protective coverings.

In the preparation of this Standard, consideration was given to IEC 502* and acknowledgement is made of the assistance received from that source.

The dimensions and sheath thickness are identical with the values in IEC 502.

The nominal cross-sectional areas of the conductors specified herein are identical with the values recommended in IEC 228.†

* IEC 502, Extruded solid dielectric insulated power cables for rated voltages from 1 kV to 30 kV.

† IEC 228, Conductors of insulated cables.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the Head Office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
1 SCOPE	4
2 REFERENCED DOCUMENTS	4
3 DEFINITIONS	4
4 VOLTAGE DESIGNATION	5
5 MAXIMUM CONTINUOUS CONDUCTOR TEMPERATURE	5
6 CONDUCTORS	5
7 INSULATION	5
8 LAY UP OF CORES	7
9 FILLERS, BARRIER TAPES AND BINDERS	7
10 BEDDING	8
11 METALLIC LAYERS	9
12 SEPARATION SHEATH	9
13 ARMOUR	9
14 METAL SHEATH	10
15 NON-METALLIC SHEATH	10
16 SERVING	12
17 MARKING	12
18 CONSTRUCTION AND DIMENSIONS	12
19 TESTS	13
APPENDICES	
A THE FICTITIOUS CALCULATION METHOD FOR THE DETERMINATION OF THE DIMENSIONS OF PROTECTIVE COVERINGS	22
B ROUNDING OF NUMBERS	26
C PURCHASING GUIDELINES	27
D NOTES ON CALCULATION OF DIMENSIONS OF CABLE	28
TABLES	
1 TESTS AND CRITERIA FOR INSULATION	7
2 APPROXIMATE THICKNESS OF BEDDING	8
3 DIAMETER OF ROUND GALVANIZED ARMOUR WIRE	9
4 THICKNESS OF STEEL ARMOUR TAPE	9
5 AVERAGE THICKNESS OF LEAD-ALLOY SHEATH	10
6 TESTS AND CRITERIA FOR NON-METALLIC AND SEPARATION SHEATHS	11
7 TESTS ON CABLES—CRITERIA, CATEGORY AND REFERENCE	13
8 CONSTRUCTION AND DIMENSIONS OF 0.6/1 kV INSULATED AND NON-METALLIC SHEATHED SINGLE-, 2-, 3- AND 4-CORE CIRCULAR CABLES	14
9 CONSTRUCTION AND DIMENSIONS OF 0.6/1 kV INSULATED, BEDDED, GALVANIZED STEEL SINGLE WIRE ARMoured 2-, 3- AND 4-CORE CIRCULAR CABLES WITH OR WITHOUT OPTIONAL FURTHER PROTECTION....	15
10 CONSTRUCTION AND DIMENSIONS OF 0.6/1 kV INSULATED LEAD-ALLOY SHEATHED SINGLE-, 2-, 3- AND 4-CORE CIRCULAR CABLES WITH OR WITHOUT OPTIONAL FURTHER PROTECTION	17
11 CONSTRUCTION AND DIMENSIONS OF 0.6/1 kV INSULATED, LEAD-ALLOY SHEATHED, GALVANIZED STEEL SINGLE WIRE ARMoured 2-, 3- AND 4-CORE CIRCULAR CABLES WITH OR WITHOUT OPTIONAL FURTHER PROTECTION	19
12 CONSTRUCTION AND DIMENSIONS OF 0.6/1 kV INSULATED (UNPROTECTED) SINGLE-CORE CIRCULAR CABLES FOR USE BY ELECTRICITY SUPPLY AUTHORITIES ONLY	21

STANDARDS AUSTRALIA

Australian Standard

Approval and test specification—Electric cables—XLPE insulated—For working voltages up to and including 0.6/1 kV

1 SCOPE. This Standard specifies construction, dimensions and tests for cables insulated with two types of cross-linked polyethylene (XLPE), one of which has reduced combustion propagation characteristics. The cables are intended for use in electrical installations at working voltages up to and including 0.6/1 kV.

Except where otherwise specified in tables of construction and dimensions, cables covered by this Standard are suitable for use as underground cables.

It does not apply to specialized XLPE insulated cables for which there are separate Australian Standards, e.g. Concentric wire neutral cables, Neutral screened cables, Aerial bundled cables and the like.

In addition to providing detailed requirements for cables of the types and sizes in the tables of construction and dimensions, this Standard provides the basis of requirements for other types and sizes in the range of materials covered by this Standard.

NOTE: Purchasing guidelines are contained in Appendix C.

2 REFERENCED DOCUMENTS. The documents below are referred to in this Specification:

AS

- 1125 Conductors in insulated electric cables and flexible cords
- 1178 Concentric wire neutral cables—XLPE insulated—For electricity supply at working voltages of 0.6/1 kV
- 1660 Methods of test for electric cables, cords and conductors
- 2122 Combustion propagation characteristics of plastics
- 2893 Electric cables—Lead and lead alloy sheaths—Composition
- 3000 SAA Wiring Rules
- 3100 Approval and test specification—Dimensions and general requirements for electrical materials and equipment
- 3155 Approval and test specification—Neutral screened cables for working voltages of 0.6/1 kV
- 3560 Electric cables—Aerial bundled—Voltages up to and including 0.6/1kV.

SAA

- MP49 Register of colours of manufacturers' identification threads for electric cables and flexible cords

BS

- 1442 Specification for galvanized mild steel wire for armouring cables

3 DEFINITIONS. For the purposes of this Specification the relevant definitions given in the referenced standards and those below apply:

3.1 Core (of a cable)—the conductor with its insulation but not including any protective covering.

3.2 Multicore cable—a cable comprising two or more cores.

3.3 Maximum continuous conductor temperature—the maximum temperature at which the conductor of the cable may be operated continuously and which is the temperature resulting from the combined effect of the ambient temperature and the current loading of the conductor.

3.4 Voltage designation—for cables for a.c. systems, the rated voltages U_0 and U expressed in the form U_0/U ; or for cables for d.c. systems, the rated voltage U_0 :

where

U_0 = is the r.m.s. power frequency voltage to earth of the supply system or d.c. voltage of the supply system for which the cable is designed; and

U = is the r.m.s. power frequency voltage between phases of the supply system and for which the cable is designed.