

Australian Standard[®]

**Low-voltage switchgear and
controlgear assemblies**

**Part 3: Particular requirements
for low-voltage switchgear and
controlgear assemblies intended
to be installed in places where
unskilled persons have access
for their use — Distribution
boards**

This Australian Standard was prepared by Committee EL/6, Industrial Switchgear and Controlgear. It was approved on behalf of the Council of Standards Australia on 17 October 1994 and published on 5 January 1995.

The following interests are represented on Committee EL/6:

Australian-British Chamber of Commerce
Australian Electrical and Electronic Manufacturers Association
Bureau of Steel Manufacturers of Australia
Electrical Contractors Association of Australia
Electrical Supply Association of Australia
Independent Electrical Switchboard Manufacturers Association (Australia)
Institution of Engineers, Australia
Ministry of Commerce, NZ
Railways of Australia Committee
Water Board, Sydney - Illawarra - Blue Mountains
WorkCover Authority of New South Wales

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

Australian Standard[®]

**Low-voltage switchgear and
controlgear assemblies**

**Part 3: Particular requirements
for low-voltage switchgear and
controlgear assemblies intended
to be installed in places where
unskilled persons have access
for their use — Distribution
boards**

First published as AS 3439.3—1995.

PREFACE

This Standard was prepared by the Joint Standards Australia/ Standards New Zealand Committee EL/6 on Industrial Switchgear and Controlgear as an Australian Standard.

It is the result of a consensus among representatives on the Joint Committee to produce it as an Australian Standard.

This Standard is Part 3 of the following series:

AS

3439 Low-voltage switchgear and controlgear assemblies

Part 1: Type-tested and partially type-tested assemblies

Part 2: Particular requirements for busbar trunking systems (busways)

Part 3: Particular requirements for low-voltage switchgear and controlgear assemblies intended to be installed in places where unskilled persons have access for their use — Distribution boards

Part 4*: Particular requirements for assemblies for construction sites (ACS)

With the exception of Appendix AA, this Standard is equivalent in technical content but not in full presentation to IEC 439-3—1990, *Low-voltage switchgear and controlgear assemblies*, Part 3: *Particular requirements for low-voltage switchgear and controlgear assemblies intended to be installed in places where unskilled persons have access for their use — Distribution boards*, including Amendment 1.

Appendix AA lists the variations between this Standard and IEC 439-3. For the purposes of this Standard, the IEC text is amended, supplemented or replaced as set out in Appendix AA. These changes are indicated by a marginal bar against the relevant clause, note, table, figure or part thereof affected.

The changes required by Amendment 1 have been made and are indicated by double marginal bars against each clause, table, figure or part thereof.

The clauses of this Standard modify or replace the corresponding clauses of AS 3439.1. Where there is no corresponding clause or sub-clause, the clause or sub-clause of AS 3439.1 applies.

As this Standard is reproduced from an international Standard, the following applies:

- Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- In the source text, 'this International Standard' should read 'this Australian Standard'.
- A full point substitutes for a comma when referring to a decimal marker.

The term 'normative' has been used in this Standard to define the application of the appendix to which it applies. A 'normative' appendix is an integral part of a Standard.

References to international Standards should be replaced by equivalent Australian Standards, as follows:

<i>Reference to International Standard</i>	<i>Australian Standard</i>
IEC	AS
68 Basic environmental testing procedures	1099.2.3 Basic environmental testing procedures for electrotechnology —
68-2-3 Part 2: Tests — Test Ca: Damp heat, steady state	Test Ca — Damp heat, steady state

* In course of preparation.

IEC		AS	
68-2-63	Part 2: Tests — Test Eg: Impact, spring hammer	—	
269	Low-voltage fuses	2005	Low voltage fuses — Fuses with enclosed fuse-links
269-3	Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household and similar applications)	2005.30	Part 30: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household and similar applications)
529	Degrees of protection provided by enclosures (IP Code)	1939	Degrees of protection provided by enclosures for electrical equipment (IP Code)
695	Fire hazard testing	2420	Fire test methods for solid insulating materials and non-metallic enclosures used in electrical equipment
695-2-1	Part 2: Test methods— Glow-wire test and guidance		
947	Low-voltage switchgear and controlgear	3947	Low voltage switchgear and controlgear
947-1	Part 1: General rules	3947.1	Part 1: General rules
ISO			
4046	Paper, board, pulp and related terms — Vocabulary	—	

Referenced documents listed in Appendix AA:

AS	
3135	Approval and test specification for semi-enclosed fuses for a.c. circuits
3439	Low-voltage switchgear and controlgear assemblies
3439.1	Part 1: Type-tested and partially type-tested assemblies
3865	Calculation of the effects of short-circuit currents
IEC	
269	Low-voltage fuses
269-3	Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household and similar applications)
439	Low-voltage switchgear and controlgear assemblies
439.3	Part 3: Particular requirements for low-voltage switchgear and controlgear assemblies intended to be installed in places where unskilled persons have access for their use — Distribution boards
890	A method of temperature-rise assessment by extrapolation for partially type-tested assemblies (PTTA) of low-voltage switchgear and controlgear

CONTENTS

	<i>Page</i>
Clause	
1 General	1
2 Definitions	1
3 Classification of assemblies	3
4 Electrical characteristics of assemblies	3
5 Information to be given regarding the assembly	4
6 Service conditions	4
7 Design and construction	5
8 Test specifications	8
Appendix AA List of variations between this Standard and IEC 439-1	18

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

AUSTRALIAN STANDARD

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES**Part 3: Particular requirements for low-voltage switchgear and controlgear assemblies intended to be installed in places where unskilled persons have access for their use — Distribution boards****1 General**

1.1 Scope

Replace the note by:

This standard gives supplementary requirements for such enclosed distribution boards (DBU), which are stationary, type tested assemblies (TTA) for indoor use, containing protective devices and intended for use either in domestic (household) applications or in other places where unskilled persons have access for their use. Control and/or signalling devices may also be included. They are for use on a.c., with a nominal voltage to earth not exceeding 300 V. The outgoing circuits contain short-circuit protective devices, each having a rated current not exceeding 125 A with a total incoming load current not exceeding 250 A.

NOTE — The nominal voltage to earth in an IT system is taken as the nominal voltage of the system.

Unskilled persons normally have access to these assemblies, e.g. for switching operations and for replacing fuse-links.

2 Definitions2.1 *General definitions*2.1.1.2 *Partially type tested assembly (TTA)*

Not applicable.

2.1.9 *Test situation*

Not applicable.

2.1.10 *Distribution board*

An assembly containing switching or protective devices (e.g. fuses or miniature circuit-breakers) associated with one or more outgoing circuits fed from one or more incoming circuits, together with terminals for the neutral and protective circuit conductors. It may also include signalling and other control devices. Means of isolation may be included in the board or may be provided separately.