

Australian Standard[®]

**Capillary fittings of copper and copper
alloy for non-pressure sanitary
plumbing applications**

STANDARDS
Australia



This Australian Standard® was prepared by Committee WS-002, Sanitary Plumbing Fittings. It was approved on behalf of the Council of Standards Australia on 23 February 2007.

This Standard was published on 8 June 2007.

The following are represented on Committee WS-002:

- Australian Industry Group
 - Australian Stainless Steel Development Association
 - Brisbane Water
 - Building Officials Institute of New Zealand
 - Certification Interests (Australia)
 - Master Plumbers, Gasfitters and Drainlayers New Zealand
 - Plastics Industry Pipe Association of Australia
 - Queensland Brassware Industry Advisory Panel
 - South Australian Water Corporation
 - Testing Interests (Australia)
 - Water Corporation Western Australia
-

This Standard was issued in draft form for comment as DR 06366.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through public comment.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

STANDARDS AUSTRALIA

RECONFIRMATION

OF

AS 3517–2007

**Capillary fittings of copper and copper alloy for non-pressure
sanitary plumbing applications**

RECONFIRMATION NOTICE

Major stakeholders of this publication have reviewed the content of this publication and in accordance with Standards Australia procedures for reconfirmation, it has been determined that the publication is still valid and does not require change.

Certain documents referenced in the publication may have been amended since the original date of publication. Users are advised to ensure that they are using the latest versions of such documents as appropriate, unless advised otherwise in this Reconfirmation Notice.

Approved for reconfirmation in accordance with Standards Australia procedures for reconfirmation on 29 August 2018.

NOTES

Currently in preview, click buy full vers.

Australian Standard[®]

Capillary fittings of copper and copper alloy for non-pressure sanitary plumbing applications

Originally published as AS 3517—1987.
Third edition, 2007.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 0 7337 8269 8

PREFACE

This Standard was prepared by the Standards Australia Committee WS-002, Sanitary Plumbing Fittings, to supersede AS 3517—1995.

The objective of this Standard is to provide manufacturers basic design requirements for non-pressure fittings used in sanitary plumbing applications.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

Currently in preview, click buy full version

CONTENTS

	<i>Page</i>
1 SCOPE.....	4
2 REFERNCED DOCUMENTS	4
3 DEFINITIONS.....	4
4 DESIGNATION OF SIZES	4
5 MARKING	4
6 DESIGN.....	5
7 MATERIALS.....	5
8 DIMENSIONS.....	6
9 PLATING AND OTHER SURFACE FINISHES.....	14
10 FREEDOM FROM DEFECTS.....	14
11 PERFORMANCE REQUIREMENTS	14
 APPENDICES	
A LIST OF REFERENCED DOCUMENTS	15
B METHODS OF SPECIFYING SIZES AND TYPES OF FITTINGS.....	16
C TYPICAL RANGE OF FITTINGS.....	18
D TORQUE TEST.....	20
E AIR/VACUUM TEST	22
F PRESSURE TEST	24

STANDARDS AUSTRALIA

Australian Standard**Capillary fittings of copper and copper alloy for non-pressure sanitary plumbing applications****1 SCOPE**

This Standard specifies requirements for copper and copper alloy capillary fittings for use in non-pressure sanitary plumbing applications with tubes complying with AS 1432 and AS 3795 in the range of nominal sizes from DN 32 to DN 225. It covers cast, hot-pressed, shell-moulded, and tubular fittings with socket/spigot capillary connection ends.

This Standard does not apply to fittings for use in pressure applications, including pumping mains and flushing systems in sanitary plumbing systems (see AS 3688), nor to waste fittings (see AS 1589).

NOTE: Illustrations used in this Standard are diagrammatic only and have been chosen without prejudice.

2 REFERENCED DOCUMENTS

The documents referred to in this Standard are listed in Appendix A.

3 DEFINITIONS

For the purpose of this Standard, the definitions given in AS/NZS 3500.0 and the one below apply.

3.1 Component

That part, or a sub-assembly of parts, that contributes to the construction of a total assembly by choice or design which will offer various means of fitment for the application of the major element of this product, whether produced by the same manufacturer or not.

4 DESIGNATION OF SIZES

The size by which a fitting is designated shall be the nominal size of the tube with which it is to be used. The method of specifying the sizes of fittings shall be in accordance with Appendix B.

NOTE: Designated sizes do not necessarily indicate exact dimensions as these details are given in the relevant table herein.

5 MARKING**5.1 Space for WaterMark or mark of certifying body**

Provision shall be made on every fitting for the WaterMark or mark of the certifying body. The area shall be of sufficient size to accommodate the mark. Continuously threaded product shall be exempt from this requirement. Indented marks shall be applied in such a way as not to deform or otherwise damage the fitting. Manufacturers may agree with the certifying body whether or not the mark will be applied to individual components in a fitting that passes the required tests.