

Under Revision 200 DR 93144

Dup

Superseded by AS 3565.1-1994

AS 3565—1988



**Standards
Association of
Australia**



Australian Standard[®] 3565—1988

METERS FOR COLD POTABLE WATER



This Australian Standard was prepared by Committee WS/24, Meters for Cold Potable Water. It was approved on behalf of the Council of the Standards Association of Australia on 16 June 1988 and published on 3 October 1988.

The following interests are represented on Committee WS/24:

Australian Electrical and Electronic Manufacturers Association
Confederation of Australian Industry
Department of Local Government, Queensland
Engineering and Water Supply Department, South Australia
Hunter District Water Board
Melbourne and Metropolitan Board of Works
Water Board, Sydney
Water Authority of Western Australia

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all SAA publications will be found in the Catalogue of SAA Publications; this information is supplemented each month by SAA's journal 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of the Association, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 86102.

AUSTRALIAN STANDARD

**METERS FOR COLD
POTABLE WATER**

AS 3565—1988

First published as AS 3565—1988.

**PUBLISHED BY THE STANDARDS ASSOCIATION OF AUSTRALIA
STANDARDS HOUSE, 80 ARTHUR ST, NORTH SYDNEY, N.S.W.**

ISBN 0 7262 5180 1

PREFACE

This Standard was prepared by the Association's Committee on Meters for Cold Potable Water.

Attention is drawn to the fact that there may be legal requirements applying to water meters and that these requirements take precedence over the requirements of this Standard.

CONTENTS

	<i>Page</i>
SECTION 1. SCOPE AND GENERAL	
1.1 SCOPE	3
1.2 REFERENCED DOCUMENTS	3
1.3 DEFINITIONS	3
1.4 DESIGNATION OF SIZE	3
1.5 DESIGNATION OF CAPACITY	3
1.6 DIMENSIONS AND TOLERANCES	3
1.7 MARKING	4
SECTION 2. MATERIALS AND COMPONENTS	
2.1 MATERIALS	6
2.2 END CONNECTIONS	6
2.3 REGISTER	6
2.4 CALIBRATION ADJUSTMENT DEVICE	8
2.5 PROTECTIVE DEVICES	8
2.6 FROST PROTECTION	8
SECTION 3. METROLOGICAL CHARACTERISTICS	
3.1 MAXIMUM PERMISSIBLE ERROR	9
3.2 METROLOGICAL CLASSES	9
SECTION 4. OPERATING REQUIREMENTS	
4.1 PRESSURE LOSS	9
4.2 WORKING TEMPERATURE	9
4.3 WORKING PRESSURE	9
4.4 NON-RETURN VALVES	9
4.5 REVERSE FLOW	9
4.6 STRAINER	9
4.7 EXTERNAL MAGNET	9
APPENDICES	
A INSTALLATION GUIDELINES	10
B TEST METHODS AND EQUIPMENT GUIDELINES	12

© Copyright — STANDARDS ASSOCIATION OF AUSTRALIA

Users of Standards are reminded that copyright subsists in all SAA publications and software. Except where the Copyright Act allows and except where provided for below no SAA publications or software may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from the Standards Association of Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the Head Office of the Association.

SAA will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to SAA.

SAA will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by SAA at any time.

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard

METERS FOR COLD POTABLE WATER

SECTION 1. SCOPE AND GENERAL

1.1 SCOPE. This Standard specifies requirements for volumetric chamber-type meters and turbine-type meters used for measuring the volume of cold potable water in residential, commercial and industrial applications and which have nominal flow rates not greater than 40 kL/h and not greater than 250 kL/h, respectively.

The Standard is applicable to meters which are self-contained and capable of continuously determining, within the accuracy limits set out in the Standard, the volume of water which has flowed through them and which are continuously indicating the volume on a cumulative basis.

NOTE: Installation guidelines are given in Appendix A. Test methods and equipment guidelines are given in Appendix B.

1.2 REFERENCED DOCUMENTS. The documents below are referred to in this Standard.

AS

1722 Pipe threads of Whitworth form
Part 2: Fastening pipe threads (AS 1722.2)

2129 Flanges for pipes, valves and fittings

2345 An accelerated laboratory test method for assessment of the susceptibility of brass to dezincification

ISO

4064 Measurement of water flow in closed conduits—
Meters for cold potable water
Part 1: Specification (ISO 4064/1)
Part 3: Test methods and equipment (ISO 4064/3)

BS

6920 Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water

1.3 DEFINITIONS. For the purpose of this Standard, the following definitions apply:

1.3.1 Flow rate (q)—the volume of water passing through the meter in unit time expressed in kilolitres per hour (kL/h).

1.3.2 Volume (V)—the quantity of water which has passed through the meter, expressed in kilolitres (kL).

1.3.3 Nominal flow rate (q_n)—the designated flow rate at which the meter will operate continuously, within the limits of maximum permissible error (see Clause 3.1), expressed in kilolitres per hour (kL/h). Designated values of q_n and corresponding nominal meter sizes are shown in Figures 1.1 and 1.2.

NOTE: The nominal flow rate is used for the purpose of designating the capacity of the water meter. At the nominal flow rate, water meters are required to have a maximum pressure loss not exceeding those specified in Table 4.1.

1.3.4 Maximum continuous flow rate (q_{cmax})—the flow rate at which the meter will operate continuously for 500 h, within the limits of maximum permissible

error (see Clause 3.1), expressed in kilolitres per hour (kL/h), and always greater than or equal to the nominal flow rate (q_n).

1.3.5 Maximum intermittent flow rate (q_{imax})—the flow rate at which the meter will operate within the limits of maximum permissible error (see Clause 3.1) for a period of not less than 1 h without damage, expressed in kilolitres per hour (kL/h), and equal to at least twice that of the nominal flow rate (q_n).

1.3.6 Minimum flow rate (q_{min})—the lowest flow rate at which the meter is required to give indications within the maximum permissible error (see Clause 3.1), expressed in kilolitres per hour (kL/h).

NOTE: The relationship between q_{min} and q_n is used to determine the metrological class of water meters (see Clause 3.2 and Table 3.1).

1.3.7 Minimum registration flow rate (q_{reg})—the flow rate at which the meter will commence to register, regardless of meter accuracy.

1.3.8 Flow rate range (q_{min} to q_{imax})—the range established by the minimum and maximum (intermittent) flow rates.

1.3.9 Pressure loss—the reduction in pressure at a given flow rate caused by the presence of the water meter in the pipeline, expressed in kilopascals (kPa).

1.3.10 Working temperature—the water temperature immediately upstream of the water meter, expressed in degrees Celsius ($^{\circ}\text{C}$).

1.3.11 Working pressure—the hydrostatic pressure immediately upstream of the water meter, expressed in kilopascals (kPa).

1.4 DESIGNATION OF SIZE. The size designation of a water meter shall be the same as that of the pipe for which it is intended, expressed in millimetres (mm).

1.5 DESIGNATION OF CAPACITY. The capacity of a water meter shall be designated by the nominal flow rate (q_n), expressed in kilolitres per hour (kL/h).

1.6 DIMENSIONS AND TOLERANCES.

1.6.1 General. Dimensions for the following meter characteristics are given in Figure 1.1 (for volumetric chamber-type meters and turbine-type meters) and in Figure 1.2 (for turbine-type meters with removable mechanisms):

- (a) Overall height h_1 .
- (b) Overall width b .
- (c) Height from base of meter to centreline of pipe connection threads or flange bore h_2 .
- (d) Overall length (without connections) L .