

Australian Standard<sup>®</sup>

---

**ELECTRIC CABLES—  
AERIAL BUNDLED—  
POLYMERIC INSULATED—  
VOLTAGES 6.25/11(12) kV AND  
12.7/22(24) kV**

**Part 1—METALLIC SCREENED**

---

This Australian Standard was prepared by Committee EL/3, Electric Wires and Cables. It was approved on behalf of the Council of the Standards Association of Australia on 14 September 1988 and published on 3 October 1988.

---

The following interests are represented on Committee EL/3:

Australian Electrical and Electronic Manufacturers Association  
Civil Aviation Authority (Commonwealth)  
Confederation of Australian Industry  
Department of Defence  
Department of Mineral Resources, New South Wales  
Electrical regulatory authorities  
Electrical Contractors Associations of Australia  
Electricity Supply Association of Australia  
Railways of Australia Committee  
Testing interests

Additional interests participating in preparation of Standard:

Australian Porcelain Insulators Association  
Electrical and Radio Federation of Victoria

---

**Review of Australian Standards:** To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

---

*This Standard was issued in draft form for comment as DR 88076.*

Australian Standard<sup>®</sup>

---

**ELECTRIC CABLES—  
AERIAL BUNDLED—  
POLYMERIC INSULATED—  
VOLTAGES (35/11(12) kV AND  
12.7/22(24) kV**

**Part 1—METALLIC SCREENED**

---

First published as AS 3599.1—1988.

PUBLISHED BY STANDARDS AUSTRALIA  
(STANDARDS ASSOCIATION OF AUSTRALIA)  
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 5275 1

## PREFACE

This Standard was prepared by the Association's Committee on Electric Wires and Cables and is based on requirements laid down by the Electricity Supply Association of Australia. The Standard applies to aerial bundled cables (ABC) intended for electricity supply at working voltages of 6.35/11 kV and 12.7/22 kV.

For reasons of standardization and rationalization, this Standard provides for the construction, dimensions, and test requirements of only a limited range of individually screened three-core cables.

This Standard is complementary to the range of cables covered in AS 1429, *Polymeric insulated cables for electricity supply at working voltages 1.9/3.3 kV up to and including 19/33 kV*, and is compatible with the appropriate requirements specified therein.

## © Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

## CONTENTS

	<i>Page</i>
1 SCOPE .....	4
2 REFERENCED DOCUMENTS .....	4
3 DEFINITIONS .....	4
4 DESIGNATED VOLTAGES .....	6
5 MAXIMUM CONDUCTOR TEMPERATURES .....	6
6 PHASE CABLE CONDUCTORS .....	6
7 CONDUCTOR SCREEN .....	6
8 INSULATION .....	6
9 INSULATION SCREEN .....	6
10 METALLIC SCREEN .....	7
11 SEPARATOR TAPE(S) .....	7
12 SHEATH .....	7
13 PHASE IDENTIFICATION .....	7
14 BUNDLED CABLE IDENTIFICATION .....	7
15 WATER BLOCKING (OPTIONAL) .....	7
16 SUPPORT CATENARY .....	7
17 LAYING UP .....	9
18 PREPARATION FOR DELIVERY .....	9
19 MARKING OF DRUMS .....	9
20 TESTS .....	9
21 DIAMETER OF DRUM BARRELS AND INSTALLATION BENDING RADII FOR CABLES .....	13
22 HIGH VOLTAGE D.C. TEST AFTER INSTALLATION .....	13
 APPENDICES	
A PARTIAL DISCHARGE TEST .....	14
B IMPULSE TESTS ON CABLES .....	16
C TEST FOR EFFECTIVENESS OF WATER BLOCKING .....	17
D CABLE DATA AND RECOMMENDATIONS .....	19
E ITEMS TO BE SPECIFIED BY THE PURCHASER OR SUBJECT TO AGREEMENT BETWEEN THE PURCHASER AND MANU- FACTURER .....	23

## STANDARDS ASSOCIATION OF AUSTRALIA

## Australian Standard

ELECTRIC CABLES—AERIAL BUNDLED—POLYMERIC INSULATED—  
VOLTAGES 6.35/11(12) kV AND 12.7/22(24) kV

## PART 1: METALLIC SCREENED

**1 SCOPE.** This Standard specifies the construction, dimensions, and test requirements for cross-linked polyethylene (XLPE) insulated, individually metallic screened, high density polyethylene (HDPE) sheathed, catenary supported, three phase cables, aerial bundled cable (ABC) (see Figure 1), for electricity supply.

Additionally, it provides cable data and recommendations to assist in the selection of the appropriate cables (see Appendix D).

**2 REFERENCED DOCUMENTS.** The documents below are referred to in this Standard.

## AS

- 1018 Partial discharge measurements
- 1049 Telecommunication cables—Insulation and sheath—Polyethylene
- 1125 Conductors in insulated electric cables and flexible cords
- 1222 Steel conductors and stays for overhead power transmission purposes
  - 1222.1 Part 1: Galvanized (SC/GZ)
  - 1222.2 Part 2: Aluminium clad (SC/AC)
- 1429 Polymeric insulated cables for electricity supply at working voltages 1.9/3.3 kV up to and including 19/33 kV
- 1660 Methods of test for electric cables, cords and conductors
- 1931 High voltage testing techniques
  - 1931.1 Part 1: General definitions, test requirements, test procedures and measuring devices
- 2857 Timber drums for insulated electric cables and bare conductors

## IEC

- 287 Calculation of the continuous current rating of cables (100% load factor)

**3 DEFINITIONS.** For the purpose of this Standard, the following definitions apply.

**3.1 Core (of a cable)**—an assembly comprising a conductor, semiconductive conductor screen, insulation and semiconductive insulation screen.

**3.2 Conductor screen**—a layer or layers of non-metallic semiconductive material applied directly over the conductor.

**3.3 Insulation screen**—a layer or layers of non-metallic semiconductive material applied directly over the insulation of each core.

**3.4 Metallic screen**—a screen of copper wires applied over each core.

**3.5 Phase cable**—an assembly comprising a core, tapes, metallic screen and sheath, which together form one phase of the bundled cable (see Figure 2).

**3.6 Direction of lay**—the slope of the conductor wires; screen wires, phase cable, or the like when the phase cable or, in the case of complete cable, the cable bundle is held vertically.

It is right-hand when the slope is in the direction of the central part of the letter Z, and left-hand when the slope is in the direction of the central part of the letter S.

**3.7 Support catenary**—steel conductor provided to support the three laid-up phase cables.

**3.8 Length of lay**—the axial distance of one complete turn of the helix formed by a cable component, e.g. a wire of the metallic screen or a phase cable.

**3.9 Maximum conductor temperature**—the maximum temperature at which the conductor of the cable may be operated, and it is the temperature resulting from the combined effect of the ambient conditions and the current loading of the conductor.

**3.10 Voltage designation.** The rated voltages are expressed in the form  $U_0/U_m$  where—

$U_0$  = the r.m.s. power frequency voltage to earth of the supply system for which the cable is designed

$U$  = the r. m. s. power frequency voltage between phases of the supply system for which the cable is designed

$U_m$  = the maximum r.m.s. power-frequency voltage between any two conductors for which cables and accessories are designed. It is the highest voltage that can be sustained under normal operating conditions at any time and at any point in a system. It excludes temporary voltage variations due to fault conditions and sudden disconnection of large loads.

**3.11 Routine tests**—tests made by the manufacturer on all production lengths of completed bundled cable to demonstrate its integrity.

**3.12 Special tests**—tests made by the manufacturer on samples of completed bundled cable or components taken from completed bundled cable, at a specified frequency so as to verify that the finished product meets the design specification.

**3.13 Type tests**—tests made by a manufacturer before supplying on a general commercial basis a type of cable covered by this Standard, in order to demonstrate satisfactory performance characteristics to meet the intended application. These tests are of