

Australian Standard[®]

**Mechanical fittings for low
voltage aerial bundled cables**

This Australian Standard was prepared by Committee EL/10, Overhead Lines. It was approved on behalf of the Council of Standards Australia on 21 March 1990 and published on 16 July 1990.

The following interests are represented on Committee EL/10:

- Australian Electrical and Electronic Manufacturers Association
 - Australian Porcelain Insulators Association
 - Confederation of Australian Industry
 - Electrical and Radio Federation of Victoria
 - Electricity Supply Association of Australia
 - Railways of Australia Committee
-

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 89068.

Australian Standard®

**Mechanical fittings for low
voltage aerial bundled cables**

First published as AS 3766—1990.

PREFACE

This Standard was prepared by the Standards Australia Committee on Overhead Lines with the close cooperation of representatives from the Electricity Supply Association of Australia and Australian manufacturers of overhead power line fittings.

The Standard sets out performance and general requirements for fittings designed specifically for use with the insulated aerial cables, manufactured to AS 3560, *Electric cables — Aerial bundled — Voltages up to and including 0.6/1 kV*. The particular fittings covered by this Standard are as follows:

- (a) Strain clamps.
- (b) Tension joints.
- (c) Suspension clamps.
- (d) Pole fittings.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	4
1.2 REFERENCED DOCUMENTS	4
1.3 DEFINITIONS	4
1.4 GENERAL REQUIREMENTS	5
1.5 GENERAL REQUIREMENTS FOR TESTS	5
1.6 DIMENSIONS AND TOLERANCES	5
1.7 CABLE PARAMETERS	6
1.8 MARKING	6
SECTION 2 STRAIN CLAMPS	
2.1 DESIGN	8
2.2 CLAMPING TO CABLE	8
2.3 ASSEMBLY	8
2.4 INSULATION	8
2.5 TESTS, GENERAL	8
2.6 MARKING	10
SECTION 3 TENSION JOINTS	
3.1 DESIGN	11
3.2 INSULATION	11
3.3 WATERPROOFING	11
3.4 TESTS, GENERAL	11
3.5 HEATING CYCLE TEST	12
3.6 SHORT-TIME CURRENT TEST	12
3.7 HOLDING STRENGTH TEST	12
3.8 INSULATION INTEGRITY TESTS	13
3.9 MARKING	13
SECTION 4 SUSPENSION CLAMPS	
4.1 DESIGN	15
4.2 CLAMPING TO CABLE	15
4.3 ASSEMBLY	15
4.4 INSULATION	15
4.5 TESTS	15
4.6 MARKING	18
SECTION 5 POLE FITTINGS	
5.1 GENERAL	19
5.2 HOOK FORM	19
5.3 DESIGN REQUIREMENTS FOR HOOK BOLTS	20
5.4 DESIGN REQUIREMENTS FOR HOOKNUTS	20
5.5 DESIGN REQUIREMENTS FOR HOOK BRACKETS	20
5.6 DESIGN REQUIREMENTS FOR SUPPORT BRACKETS	21
5.7 DESIGN REQUIREMENTS FOR SUPPORTED HOOKS	21
5.8 DESIGN REQUIREMENTS FOR LINKS	22
5.9 DESIGN REQUIREMENTS FOR EXTENSIBLE LINKS	22
5.10 DESIGN REQUIREMENTS FOR YOKES	22
5.11 TESTS	22
5.12 MARKING	22
SECTION 6 ELECTRICAL TESTS	
6.1 GENERAL	23
6.2 TEMPERATURE CYCLE TEST	23
6.3 HIGH VOLTAGE TESTS ON INSULATION	23
APPENDICES	
A FITTING DESIGN PHILOSOPHY	24
B PURCHASING GUIDELINES	24

STANDARDS AUSTRALIA

Australian Standard

Mechanical fittings for low voltage aerial bundled cables

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE. This Standard sets out performance and general requirements for mechanical fittings and dedicated pole fittings to support low voltage aerial bundled cables manufactured in accordance with AS 3560.

This Standard allows specified components to fail under external mechanical overloads. The design philosophy for this controlled failure mechanism is defined in Appendix A.

NOTE: Appendix B contains the information which should be supplied by the purchaser at the time of enquiry and order.

1.2 REFERENCED DOCUMENTS. The following documents are referred to in this Standard:

AS	
1110	ISO metric hexagon precision bolts and screws
1111	ISO metric hexagon commercial bolts and screws
1112	ISO metric hexagon nuts, including thin nuts, slotted nuts and castle nuts
1154	Insulator and conductor fittings for overhead power lines
1154.1	Part 1: Performance and general requirements
1214	Hot-dip galvanized coatings on threaded fasteners (ISO metric four thread series)
1390	Metric cup head bolts
1442	Carbon steels and carbon-manganese steels — Hot-rolled bars and semi-finished products
1650	Hot-dipped galvanized coatings on ferrous articles
1660	Methods of test for electric cables, cords and conductors
1660.2	Part 2: Insulation, extruded semi-conductive screens and non-metallic sheaths
3100	Approval and test specification — Definitions and general requirements for electrical materials and equipment
3560	Electric cables — Aerial bundled voltages up to and including 0.6/1 kV.
3902	Quality systems for production and installation

1.3 DEFINITIONS. For the purposes of this Standard the definitions given in AS 3560 and the following apply.

1.3.1 Aerial bundled cable (ABC) — a cable manufactured in accordance with AS 3560.

1.3.2 Cable — complete laid-up assembly of the required number of cores.

1.3.3 Component — individual item forming part of a fitting.

1.3.4 Conductor — assembly of stranded, laid-up wires without insulation.

1.3.5 Controlled failure fitting — any fitting for which both minimum and maximum failing loads are specified (see Appendix A).

1.3.6 Core (of a cable) — conductor with its insulation.

1.3.7 Fitting — complete assembly which can be applied to secure an aerial bundled cable.

1.3.8 Mains — the supply authority's electrical circuit, formed in this case by one or more aerial bundled cables.

1.3.9 Maximum failing load (MaxFL) — the highest value of mechanical load under which a fitting or component may fail.

1.3.10 Minimum breaking load (MBL) — the lowest value of mechanical load at which the core, or cable as appropriate, may break.

1.3.11 Minimum failing load (MinFL) — the lowest value of mechanical load under which a fitting or component may fail.

1.3.12 Nominated cable tension (NCT) — the value of tension in an aerial bundled cable given in Table 1.1.

1.3.13 Secondary damage — damage to the cable after a mechanical fitting failure.