

Australian Standard[®]

**Guide to the effects of temperature
on electrical equipment**

This Australian Standard was prepared by Committees EL/6, Industrial Switchgear and Controlgear, and EL/7, Power Switchgear. It was approved on behalf of the Council of Standards Australia on 9 January 1990 and published on 16 July 1990.

The following interests are represented on Committees EL/6 and EL/7:

Australian—British Chamber of Commerce
Australian Electrical and Electronic Manufacturers Association
Bureau of Steel Manufacturers of Australia
Confederation of Australian Industry
Electricity Contractors Association of Australia
Independent Electrical Switchboard Manufacturers Association
Institution of Engineers, Australia
Railways of Australia Committee
Testing Authorities
Water Board, Sydney
Workcover Authority, New South Wales

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important, therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

Australian Standard[®]

**Guide to the effects of temperature
on electrical equipment**

First published as AS 3768—1990.

Incorporating:
Amdt 1—1995

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 6125 4

PREFACE

This Standard was prepared jointly by the Standards Australia Committees on Industrial Switchgear and Controlgear and Power Switchgear, as a guide for engineers responsible for the determination of temperatures of components forming parts of electrical equipment.

It is based on the Central Office draft of IEC Technical report 943 (1989) *Guide for the specification of permissible temperature and temperature rise for parts of electrical equipment, in particular for terminals*, but is presented differently to make it easier to read and extract information relevant to particular applications.

A considerable amount of explanatory material for the development of the equations has not been included in this guide and reference should be made to IEC 943 for any further details.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
SECTION 1. SCOPE AND GENERAL	
1.1 SCOPE	3
1.2 REFERENCED DOCUMENTS	3
1.3 DEFINITIONS	3
1.4 NOTATION	5
SECTION 2. TEMPERATURES AND TEMPERATURE-RISES OF EQUIPMENT COMPONENTS	
2.0 GENERAL	6
2.1 TEMPERATURE AND TEMPERATURE-RISE LIMITS	6
2.2 COMMENTS ON TABLE 2.1	6
2.3 VARIATIONS IN THE TEMPERATURE OF THE MEDIUM (FLUID) SURROUNDING THE COMPONENT	10
SECTION 3. EFFECT OF TEMPERATURE ON CONTACT LIFE	
3.1 MECHANISM OF CONTACT AGEING	12
3.2 CONTACT MATERIALS, THEIR USE AND PRECAUTIONS TO BE TAKEN ..	12
3.3 EFFECT OF THERMAL CYCLING	13
SECTION 4. TEMPERATURE-RISES OF CONDUCTORS CONNECTING ELECTRICAL EQUIPMENT	
4.1 TEMPERATURE-RISE (ΔT_s) OF A CONDUCTOR WITH RESPECT TO ITS FLUID ENVIRONMENT TEMPERATURE (T_c)	15
4.2 TEMPERATURE-RISE (ΔT_o) IN THE VICINITY OF CONTACTS AND CONNECTION TERMINALS	18
SECTION 5. CURRENT RATINGS OF CABLES AND BUSBARS AND TEMPERATURE AND TEMPERATURE RISE OF TERMINALS CONNECTED THERETO	
5.1 CONNECTING CABLES AND JACKS FOR TEMPERATURE-RISE TESTS ON EQUIPMENT	23
5.2 CURRENT RATINGS OF CIRCUIT CONDUCTORS FOR ELECTRICAL INSTALLATIONS	23
5.3 TEMPERATURE RISE OF BUSBARS	23
5.4 TEMPERATURE AND TEMPERATURE RISE OF EQUIPMENT TERMINALS—INFLUENCE ON CONNECTED CONDUCTORS	23
SECTION 6. THERMAL DETERIORATION OF ELECTRICAL INSULATION MATERIALS	
6.1 GENERAL	30
6.2 CABLE INSULATION	30
6.3 CURRENT RATING OF INSULATED CONDUCTORS	31
APPENDICES	
A RECOMMENDED CLAMPING TORQUES FOR BOLTED (SCREWED) TERMINALS AND CONNECTIONS	33
B CHARACTERISTICS OF CONDUCTOR AND CONTACT METALS	34
C TEMPERATURE—RISES OF A 10 mm SQUARE COPPER BAR CARRYING 335 A ..	35
D DERIVATION OF THE TEMPERATURE RISE OF A CONDUCTOR IN THE VICINITY OF A TERMINAL, WITH COOLING BY RADIATION AND NATURAL CONVECTION	36
E CALCULATION OF TEMPERATURE-RISE AT THE JUNCTION OF TWO 1 CM SQUARE COPPER BARS	40
F SYMBOLS AND UNITS USED IN THIS STANDARD	42

STANDARDS AUSTRALIA

Australian Standard

Guide to the effects of temperature on electrical equipment

SECTION 1. SCOPE AND GENERAL

1.1 SCOPE. This guide is intended for use by engineers responsible for the determination of the effects of temperatures and temperature-rises of electrical equipment.

It applies more particularly to electrical contacts, connections and terminals.

It does not apply to the windings of rotating electrical machines or transformers.

This Standard presents an overview of the following:

- (a) Calculations of the temperature-rises of contacts, connections and terminals.
- (b) Permissible temperatures and temperature-rises for various electrical components.

1.2 REFERENCED DOCUMENTS. The following documents are referred to in this Standard:

AS

- 1078 Guide to loading of oil-immersed transformers
- 1154 Insulator and conductor fittings for overhead power lines
- 1154.1 Part 1: Performance and general requirements
- 1852 International electrotechnical vocabulary—
- 1852(441) Switchgear, controlgear and fuses
- 1939 Classification of degrees of protection provided by enclosures for electrical equipment
- 2768 Electrical insulating materials—Evaluation and classification based on thermal endurance
- 3000 SAA Wiring Rules
- 3008 Electrical installations—Selection of cables
- 3008.1 Part 1: Cables for alternating voltages up to and including 0.6/1 kV
- 3300 Approval and test specification—General requirements for household and similar electrical appliances

BS

- 4579 Specification for performance of mechanical and compression joints in electrical cable and wire connectors
- 4579.1 Part 1: Compression joints in copper conductors
- 4579.2 Part 2: Compression joints in nickel, iron and plated copper conductors
- 4579.3 Part 3: Mechanical and compression joints in aluminium conductors

IEC

- 216 Guide for the determination of thermal endurance properties of electrical insulating materials
- 216.1 Part 1: General guidelines for ageing and evaluation of test results
- 287 Calculation of the continuous current rating of cables (100% load factor)
- 943 Draft-Guide for the specification of permissible temperatures and temperature rises for parts of electrical equipment, in particular for terminals

- Approval test Fifty seventh chief engineers conference, April, 1972, classification C. The UK
- Engineering Electricity Council. Type approval tests for connections and terminations for
- Recommendation aluminium conductors of insulated power cables.
- C79

1.3 DEFINITIONS. For the purpose of this Standard the definitions given in AS 1852(441) and the following apply:

1.3.1 Ambient air temperature (T_a)—temperature, determined under prescribed conditions, of the air surrounding the complete equipment.

NOTES:

1. For equipment installed inside an enclosure, it is the temperature of the air outside the enclosure.
2. The value of the ambient temperature may be influenced by the heat generated by the equipment, around which it is measured.
3. Standard values of ambient air temperature (T_{an}) in this guide are—
 - (a) the weighted annual mean ambient air temperature (T_{an1}) = 20°C; and
 - (b) the maximum ambient temperature (T_{an2}) = 40°C.