

Australian Standard™

Measurement of water flow in open channels

Part 6.5: Measuring devices, instruments and equipment— Water level measuring devices

[ISO title: Measurement of liquid flow in open channels—Water level measuring device 1]



Standards Australia

This Australian Standard was prepared by Committee CE-024, Measurement of Water Flow in Open Channels and Closed Conduits. It was approved on behalf of the Council of Standards Australia on 25 September 2000 and published on 12 March 2001.

The following interests are represented on Committee CE-024:

Australian Water and Wastewater Association
Department of Natural Resources, Qld
Institute of Instrumentation and Control Australia
Department of Land and Water Conservation, New South Wales
Department of Public Works and Services, New South Wales
South Australian Water Corporation
Sydney Water Corporation
University of New South Wales
University of Adelaide
University of Technology, Sydney

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Australia website at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Australian Standard*, has a full listing of revisions and amendments published each month.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.com.au, or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

Australian Standard™

Measurement of water flow in open channels

**Part 6.5: Measuring devices, instruments and equipment—
Water level measuring devices**

Originated as AS 3778.6.5—1992.
Second edition 2001.

COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 3662 9

PREFACE

This Standard was prepared by the Standards Australia Committee CE-024, Measurement of Water Flow in Open Channels and Closed Conduits.

This Standard is identical to and is reproduced from ISO 4373:1995, *Measurement of liquid flow in open channels—Water level measuring devices*.

This Standard is Part 6.5 of AS 3778, *Measurement of water flow in open channels*, which is published in parts as follows:

AS

3778		Measurement of water flow in open channels
3778.1	Part 1:	Vocabulary and symbols
3778.2	Part 2:	General
3778.2.1	Part 2.1:	Guidelines for the selection of methods of measurement
3778.2.2	Part 2.2:	Establishment and operation of a gauging station
3778.2.3	Part 2.3:	Determination of the stage-discharge relation
3778.2.4	Part 2.4:	Estimation of uncertainty of a flow-rate measurement
3778.2.5	Part 2.5:	Guidelines for the selection of flow gauging structures
3778.3	Part 3:	Velocity-area method
3778.3.1	Part 3.1:	Measurement by current meters and floats
3778.3.2	Part 3.2:	Measurement by moving boat method
3778.3.3	Part 3.3:	Measurement by slope-area method
3778.3.4	Part 3.4:	Collection and processing of data and determination of errors in measurement
3778.3.5	Part 3.5:	Investigation of total error
3778.3.6	Part 3.6:	Measurement of flow in tidal channels
3778.3.7	Part 3.7:	Measurement by ultrasonic (acoustic) method
3778.3.8	Part 3.8:	Electromagnetic method using a full-channel-width coil
3778.4	Part 4:	Measurement using flow gauging structures
3778.4.1	Part 4.1:	Thin-plate weirs
3778.4.2	Part 4.2:	Rectangular broad-crested weirs
3778.4.3	Part 4.3:	Round-nose horizontal broad-crested weirs
3778.4.4	Part 4.4:	V-shaped broad-crested weirs
3778.4.5	Part 4.5:	Triangular profile weirs
3778.4.6	Part 4.6:	Flat-top weirs
3778.4.7	Part 4.7:	Rectangular, trapezoidal and U-shaped flumes
3778.4.8	Part 4.8:	Trapezoidal profile weirs
3778.4.9	Part 4.9:	Pashall and Saniiri flumes
3778.4.10	Part 4.10:	End-depth method for estimation of flow in rectangular channels with a free overfall
3778.4.11	Part 4.11:	End-depth method for estimation of flow in rectangular channels with a free overfall (approximate method)
3778.5	Part 5:	Dilution method
3778.5.1	Part 5.1:	Constant-rate injection method for the measurement of steady flow
3778.5.2	Part 5.2:	Integration method for the measurement of steady flow
3778.6	Part 6:	Measuring devices, instruments and equipment
3778.6.1	Part 6.1:	Rotating element current-meters
3778.6.2	Part 6.2:	Direct depth sounding and suspension equipment
3778.6.3	Part 6.3:	Calibration of rotating element current meters in straight open tanks
3778.6.4	Part 6.4:	Echo sounders for water depth measurements
3778.6.5	Part 6.5:	Water level measuring devices (this Standard)
3778.6.6	Part 6.6:	Cableway system for stream gauging
3778.6.7	Part 6.7:	Ultrasonic (acoustic) velocity meters
3778.6.8	Part 6.8:	Position fixing equipment for hydrometric boats

Under arrangements made between Standards Australia and the international Standards bodies, ISO and IEC, as well as certain other Standards organizations, users of this Australian Standard are advised of the following:

- (a) Copyright is vested in Standards Australia.
- (b) The number of this Standard is not reproduced on each page, its identity is shown only on the cover and title pages.
- (c) In the source text ‘this International Standard’ should read ‘this Australian Standard’.
- (d) A full point should be substituted for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to equivalent Australian Standards, as follows:

<i>Reference to International Standard</i>		<i>Australian Standard</i>	
ISO		AS	
772	Liquid flow measurement in open channels—Vocabulary and symbols	3778	Measurement of water flow in open channels:
		3778.1	Part 1: Vocabulary and symbols

CONTENTS

	<i>Page</i>
1 Scope	1
2 Normative references	1
3 Definitions	1
4 Accuracy of stage measurements	1
5 Gauge datum	1
6 Environment	2
7 Direct water-level indicating devices	2
8 Indirect water-level indication devices	8
9 Recording devices	15
10 Errors	18
Annex	
A Stilling wells and inakers	21

AUSTRALIAN STANDARD

Measurement of water flow in open channels

Part 6.5:

Measuring devices, instruments and equipment—Water level measuring devices**1 Scope**

This International Standard specifies the functional requirements and operational procedures for stage detecting, encoding and recording devices for measuring water levels in open channels. Because of the widespread use of stilling wells in the measurement of water levels, information on stilling wells is given in annex A to this International Standard.

2 Normative references

The following standards contain provisions which, through reference in this text, constitute provisions of this International Standard. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this International Standard are encouraged to investigate the possibility of applying the most recent editions of the standards indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

ISO 772:—¹⁾, *Measurement of liquid flow in open channels — Vocabulary and symbols*

ISO 1100-1:1981, *Liquid flow measurement in open channels — Part 1: Establishment and operation of a gauging station*.

ISO 1100-2:1982, *Liquid flow measurement in open channels — Part 2: Determination of the stage-discharge relation*.

3 Definitions

For the purposes of this International Standard, the

¹⁾ To be published. (Revision of ISO 772:1988)

definitions given in ISO 772 and the following definitions apply.

3.1 encoding: Method by which a data signal is changed into a suitable set of bits for data recording.

3.2 parity check: Addition of an extra bit to a data signal so that the total number of bits in a sample are either always even or always odd.

4 Accuracy of stage measurements

For the measurement of stage with respect to a gauge datum, an uncertainty of ± 10 mm may be satisfactory in some installations; in others, uncertainty of ± 3 mm or better may be required. However, in no case should the uncertainty be more than ± 10 mm or 0,1% of the range, whichever is greater. Exceptions can be made if sediment or unstable channel conditions make it impossible to obtain a complete and reliable record with standard equipment, and where special equipment must be used to obtain a complete record but with greater uncertainty (for example, see 8.2).

This clause applies in all cases, unless specifically stated otherwise.

5 Gauge datum

The stage of a stream or lake is the height of the water surface above an established datum plane. The datum of the gauge may be a recognized datum, such as mean sea level, or an arbitrary datum plane selected for the convenience of using gauge readings of relatively low numbers. ISO 1100-1 contains additional requirements regarding gauge datum, gauge zero and benchmarks.