



Industrial and commercial gas-fired appliances

STANDARDS
Australia

Currently in preview, click buy full version

This Australian Standard® was prepared by Committee AG-011, Industrial and Commercial Gas-Fired Appliances. It was approved on behalf of the Council of Standards Australia on 3 December 2014.

This Standard was published on 18 February 2015.

The following are represented on Committee AG-011:

- Australian Petroleum Production and Exploration Association
 - Energy Networks Association
 - Engineers Australia
 - Gas Appliance Manufacturers Association of Australia
 - Gas Energy Australia
 - Gas Technical Regulators Committee
 - Master Plumbers and Mechanical Services Association of Australia
-

This Standard was issued in draft form for comment as DR AS 3814.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standards up-to-date

Australian Standards are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using the current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

**Industrial and commercial gas-fired
appliances**

Original as AG 501—1984.
Previous edition AS 3814—2009.
Third edition AS 3814:2015.

COPYRIGHT

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

Published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 978 1 74342 979 2

PREFACE

This Standard was prepared by Standards Australia Committee AG-011, Industrial and Commercial Gas-Fired Appliances, to supersede AS 3814—2009, *Industrial and commercial gas-fired appliances*.

The objective of this Standard is to provide uniform minimum requirements for the safe operation of gas-fired industrial appliances and other large appliances used for commercial applications which are not covered by any other Standard.

This Standard should not be regarded as a design specification or as an instruction manual—it has been prepared with due regard for gas rules and regulations now in force. In its preparation, primary consideration has been given to—

- (a) the prevention of injury to persons; and
- (b) the prevention of fire hazards, and explosions associated with fuel use and processes, particularly where they could lead to a risk of injury of persons.

Additionally, consideration has been given to—

- (i) the prevention of damage to property;
- (ii) continuity of satisfactory operation of appliances and equipment;
- (iii) the provision of satisfactory permanent access for service; and
- (iv) relevant international and overseas standards.

This Standard has been further revised to remove ambiguities and to place the responsibility for safety of gas-fired industrial appliances, and other large appliances used for industrial and commercial applications firmly on the original equipment manufacturer. To this end, the original equipment manufacturer has been given a wide definition in this revision.

The main features of this revision are the following:

- (1) The requirements for hazard and risk assessment have been expanded in line with international practice, including a new informative Appendix K as well as a list of significant hazards covered by this Standard in new informative Appendix M.
- (2) The section on programmable electronic systems has been extensively revised to align it more appropriately with AS 61508 the related application Standards, AS IEC 61511 and AS 62061.
- (3) An informative Appendix N on the guidance for verifying that an appliance meets the safety requirements and/or measures in accordance with this Standard.
- (4) Included is an informative Appendix L for the review of PES designs by way of a checklist.
- (5) The robust nature of gas engines has been reflected in the revision of Section 5.8 and the uncertainties relating to applicability of many other sections of this Standard to gas engines have been removed.
- (6) In line with other international standards, the concept of a gas turbine purge credit has been introduced to enable designers and operators to establish and maintain a 'purged' condition for heat recovery steam generators (HRSGs) for an extended period of time between restarts.

The user should be aware that in many jurisdictions in Australia, this Standard is deemed as a 'prescribed or preferred standard', to which compliance is mandatory. Although Australian and New Zealand standards mostly do not do so, all the Australian and New Zealand Technical Regulators agree that this Standard should include appropriate requirements for particular components to be certified by a recognized third party assessment body.

Notes have been integrated into the text of this Standard. They provide additional information and guidance intended to assist the understanding or use of this Standard. The notes do not contain requirements or any information considered indispensable for the use of this Standard.

The term 'informative' has been used in this Standard to define the application of the appendices to which it applies. An 'informative' appendix is only for information and guidance.

Currently in preview, click buy full version.

CONTENTS

	<i>Page</i>
FOREWORD.....	6
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE.....	7
1.2 APPLICATION	8
1.3 REFERENCED DOCUMENTS.....	9
1.4 DEFINITIONS.....	12
SECTION 2 REQUIREMENTS FOR DESIGN AND CONSTRUCTION	
2.1 GENERAL REQUIREMENTS.....	25
2.2 CONTROLS, BURNER AND SAFETY DEVICE ACCESS.....	27
2.3 BURNER FLAME VISIBILITY.....	27
2.4 TEMPERATURES OF SURFACES AND COMPONENTS	28
2.5 RESTRICTION ON ELECTRICAL CONNECTIONS	28
2.6 ACCESSIBILITY OF MANUAL CONTROLS.....	28
2.7 ACCESS FOR MAINTENANCE	28
2.8 MATERIALS.....	28
2.9 GAS PIPEWORK AND VALVE TRAINS.....	29
2.10 GAS PRESSURE REGULATION.....	32
2.11 GAS OVER-PRESSURE PROTECTION.....	33
2.12 GAS LOW-PRESSURE PROTECTION.....	34
2.13 GAS PRESSURE TEST POINTS.....	35
2.14 GAS FILTER.....	35
2.15 SAFETY SHUT OFF SYSTEMS.....	36
2.16 COMBUSTION AIR SUPPLY — GENERAL REQUIREMENTS	43
2.17 COMBUSTION AIR FOR ATMOSPHERIC BURNERS.....	43
2.18 FORCED AND INDUCED DRAUGHT BURNERS.....	44
2.19 DAMPERS	45
2.20 APPLIANCE PRE-FUELLING.....	46
2.21 PROCESS CONTROLS	48
2.22 IGNITION SYSTEMS.....	49
2.23 PILOT BURNERS.....	49
2.24 MAIN BURNERS.....	50
2.25 FLAME SAFEGUARD SYSTEMS.....	51
2.26 BLEED LINES	54
2.27 APPLIANCE/BURNER CONTROLS AND SAFETY INSTRUMENTED SYSTEMS	55
2.28 GAS/AIR RATIO CONTROL.....	58
SECTION 3 OPERATION	
3.1 APPLIANCE OPERATION DETAILS	62
3.2 IGNITION	62
3.3 MAIN BURNERS.....	64
3.4 INTERLOCKS AND LIMIT DEVICES	65
3.5 OPERATION SEQUENCES	67
3.6 COMBUSTION CONDITIONS	68
3.7 COMMISSIONING.....	69

	<i>Page</i>
SECTION 4 MARKINGS AND INSTRUCTIONS	
4.1 MARKINGS	70
4.2 INSTRUCTIONS.....	71
SECTION 5 SPECIAL APPLICATION REQUIREMENTS	
5.1 GENERAL.....	72
5.2 HIGH INPUT GAS-FIRED APPLIANCES.....	72
5.3 AIR-GAS MIXING MACHINES AND MIXING BLOWERS	73
5.4 SPECIAL ATMOSPHERES AND ATMOSPHERE GENERATORS	75
5.5 PROCESS AFTER-BURNERS	77
5.6 STEAM AND HOT WATER BOILERS	78
5.7 DIRECT-FIRED AIR HEATERS AND CURTAINS	80
5.8 STATIONARY GAS ENGINES AND TURBINES	80
5.9 INCINERATORS AND CREMATORS	90
5.10 ROTARY PROCESS EQUIPMENT AND OVENS—DIRECT-FIRED	91
5.11 SMOKE OVENS—DIRECT-FIRED	93
5.12 WATER HEATERS.....	94
5.13 MULTI-FUEL FIRING SYSTEMS	95
APPENDICES	
A TYPICAL INFORMATION AND TECHNICAL DATA	96
B TYPICAL PROCEDURE FOR THE APPROVAL OF INDUSTRIAL AND COMMERCIAL APPLIANCES.....	101
C TYPICAL VALVE TRAIN ARRANGEMENTS.....	102
D FLAME SAFEGUARD SELECTION	111
E PRO-FORMA LETTER TO THE GAS TECHNICAL REGULATOR FROM A CONTRACTOR/COMPANY CERTIFYING THE TESTS CONDUCTED ON THE PES	113
F GAS/AIR RATIO CONTROL PROGRAMMABLE ELECTRONIC SYSTEMS....	114
G MAINTENANCE AND CHECKS OF SAFETY DEVICES.....	117
H TYPICAL OPERATING SEQUENCE FOR AN AUTOMATIC FORCED OR INDUCED DRAUGHT BURNER WITH INTERRUPTED PILOT.....	123
I TYPICAL COMMISSIONING PROCEDURE.....	126
J TYPICAL FIELD CHECKLIST	129
K GUIDANCE ON RISK ASSESSMENT ON A TYPE B APPLIANCE AND ITS INSTALLATION	139
L PES DESIGN AND REVIEW CHECKLIST EXAMPLES.....	149
M LIST OF SIGNIFICANT HAZARDS	153
N VERIFICATION OF SAFETY REQUIREMENTS AND/OR MEASURES.....	166

FOREWORD

Explosions are the main hazard on the firing side of the equipment covered by this Standard, the basic cause being ignition of a combustible mixture in the combustion chamber or associated ductwork. The magnitude and intensity of the explosion will depend on both the quantity of combustibles present and the proportion of air with which the combustibles are mixed.

Explosions could be the result of one or more of the following:

- (a) Improper design of equipment or control systems.
- (b) Equipment or control system malfunction, including valve leakage.
- (c) Interruption and restoration of gas or air supply causing loss of flame followed by delayed ignition of the resultant accumulation of a combustible mixture.
- (d) Flame failure on a burner and subsequent ignition of the resultant accumulation of a combustible mixture.

The presence of a well-trained, reliable and competent operator provides a major contribution to safety.

STANDARDS AUSTRALIA

Australian Standard

Industrial and commercial gas-fired appliances

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

1.1.1 General

This Standard provides minimum requirements for the design, construction and safe operation of Type B appliances that use any gas as a gaseous fuel to produce flame heat, light, power or special atmosphere in any combination of these gases either together or with other fuels.

Construction requirements given relate only to matters affecting gas fitting or to any interconnection between the gas-firing system and the safety requirements of the appliance.

NOTES:

- 1 Additional information regarding safety principles for industrial appliances is given in AS 1375.
- 2 Where an Australian design standard exists for an appliance and is not called up in this Standard, the OEM should confirm compliance to that standard before installing (if no other authority exists).

This Standard does not cover all the requirements for the safety of the process carried out in the appliance. Other statutory and regulatory requirements might be applicable to the appliances or installations, or both, that fall within the scope of this Standard. It is the installer/original equipment manufacturer's responsibility to ensure that appliances and installations comply with these requirements.

Installation requirements for appliances covered by this Standard are detailed in AS/NZS 5601.1.

1.1.2 Exclusions from Standard

The following appliances are excluded from this Standard:

- (a) Manually operated bunsen type burners.
- (b) Simple atmospheric burners that are not fitted into a combustion chamber and burn in an open ventilated space under the control of an operator.
- (c) Petroleum, petrochemical and natural gas industries flares for general refinery and petrochemical service complying with ISO 25457 and ISO 23251.
- (d) Petroleum and natural gas industries pressure-relieving and depressurizing systems complying with ISO 23251.
- (e) Engines other than stationary engines.
- (f) Refrigeration systems that utilize gas as a refrigerant.
- (g) Any vaporizing liquid fuel burners (refer to AS 1375).