

AS 3859—1991

IEC 479-1 (1984)

IEC 479-2 (1987)

Australian Standard[®]

**Effects of current passing through
the human body**

This Australian Standard was prepared by Committee EL/1, Wiring Rules. It was approved on behalf of the Council of Standards Australia on 18 September 1990 and published on 11 February 1991.

The following interests are represented on Committee EL/1:

Association of Consulting Engineers, Australia
Australian Consumers Association
Australian Electrical and Electronic Manufacturers Association
Confederation of Australian Industry
Department of Administrative Services
Electrical Contractors Associations of Australia
Electrical Regulatory Authorities
Electrical Trades Union of Australia
Electricity Supply Association of Australia
Institute of Electrical Inspectors
Institution of Engineers, Australia
Insurance Council of Australia
Telecom Australia

Additional interests participating in preparation of Publication:

Prince Henry Hospital, N.S.W.
University of Queensland

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 89200.

Australian Standard[®]

**Effects of current passing through
the human body**

First published as SAA MP30—1976.
SAA MP30—1976 revised and redesignated
AS 3859—1991.

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 6573 X

PREFACE

This Standard was prepared by the Standards Association Committee on Wiring Rules and supersedes MP 30—1976.

It is identical with and has been reproduced from IEC Publication 479, *Effects of current passing through the human body*, 479-1(1984) Part 1: *General aspects*, and 479-2 (1987) Part 2: *Special aspects*.

Under arrangements made between Standards Australia and the International Standards Bodies, ISO and IEC, as well as certain other Standard organizations, users of this Australian Standard are advised of the following:

- (a) Copyright is vested in Standards Australia.
- (b) The number of this Standard is not reproduced on each page; its identity is shown only on the cover and title pages.
- (c) Where any cross-references to page numbers appear within the text, these relate to page numbering in the International Standard and are to be disregarded.
- (d) Where any cross-reference to Part 1 or Part 2 appears within the text it relates to Chapters 1 to 3 or Chapters 4 to 5 respectively.

This Standard provides basic guidance on the effects of shock currents on the human body for use in the establishment of electrical safety requirements. However, care should be exercised in the application of the information and due consideration should be given to the notes to each Table and Figure. Attention is drawn to Clause 4.6 of Chapter 2 which indicates that 50 V r.m.s. is a voltage below which no hazard has been proven to exist.

For the purpose of this Standard, the text of IEC 479-1, and 479-2 is modified as follows:

- (i) *References*: Replace references to other publications by references to Australian Standards as follows.

<i>Reference to IEC Standards</i>	<i>Australian Standard</i>
IEC	AS
50 International Electrotechnical Vocabulary	1852 International Electrotechnical Vocabulary
50(551) Chapter 551: Power Electronics	1852(551) Power Electronics
50(801) Chapter 801: Acoustics and Electro-acoustics	1852(551) Acoustics and Electro-acoustics

- (ii) An Australian note has been added to Clause 4.4 of Chapter 2.
- (iii) An Australian Appendix B giving information on the physiology of electrocution has been added.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
INTRODUCTION	5
CHAPTER 1: ELECTRICAL IMPEDANCE OF THE HUMAN BODY	
Clause	
1. General	6
2. Scope	6
3. Definitions	6
4. Characteristics of the impedance of the human body	7
5. Values of the total impedance of the human body (Z_T)	8
6. Value of the initial resistance of the human body (R_i)	3
CHAPTER 2: EFFECTS OF ALTERNATING CURRENT IN THE RANGE OF 15 Hz TO 100 Hz	
1. General	11
2. Scope	11
3. Definitions	11
4. Effects of current	12
5. Application of heart-current factor	13
CHAPTER 3: EFFECTS OF DIRECT CURRENT	
1. General	17
2. Scope	17
3. Definitions	17
4. Effects of current	18
CHAPTER 4: EFFECTS OF ALTERNATING CURRENT WITH FREQUENCIES ABOVE 100 Hz	
1. General	20
2. Scope	20
3. Definitions	20
4. Effects of alternating current in the frequency range above 100 Hz up to and including 1 000 Hz	20
5. Effects of alternating current in the frequency range above 1 000 Hz up to and including 10 000 Hz	21
6. Effects of alternating current in the frequency range above 10 000 Hz	21
CHAPTER 5: EFFECTS OF SPECIAL WAVEFORMS OF CURRENT	
1. General	24
2. Scope	24
3. Definitions	24
4. Effects of alternating current with d.c. components	24
5. Effects of alternating current with phase control	26
6. Effects of alternating current with multicycle control	27

CHAPTER 6: EFFECTS OF UNIDIRECTIONAL SINGLE IMPULSE
CURRENTS OF SHORT DURATION

1. General	31
2. Scope	31
3. Definitions	31
4. Effects of unidirectional impulse currents of short duration	32
APPENDIX A — Measurements made on living and dead human beings and the statistical analysis of the results	39
AUSTRALIAN APPENDIX B - Physiology of electrocution	40
BIBLIOGRAPHY	42

Currently in preview, click buy full version

STANDARDS AUSTRALIA

Australian Standard**Effects of current passing through the human body**

INTRODUCTION

In order to avoid errors in the interpretation of this report it must be emphasized that the data given herein are mainly based on experiments with animals as well as on information available from clinical observations. Only a few experiments with shock currents of short duration have been carried out on living human beings.

On the evidence available, mostly from animal research, the values are so conservative that the report applies to persons under normal physiological conditions, including children irrespective of age and weight.

This report is intended to provide basic guidance on the effects of shock currents on the human body for use in the establishment of electrical safety requirements.

There are, however, other aspects to be taken into account, such as probability of faults, probability of contact with live or faulty parts, ratio between touch voltage and fault voltage, experience gained, technical feasibilities and economics. These parameters have to be considered carefully when fixing safety requirements, for example operating characteristics of protective devices for electrical installations.

The form of report has been adopted, as it summarizes results so far achieved which are being used by Technical Committee No.64 as a basis for fixing requirements for protection against shock. These results are considered important enough to justify an IEC publication, which may serve also as a guide to other IEC Committees and countries having need of such information.

The first edition of Publication 479 was issued in 1974 and was based on an extensive search in literature and on the evaluation of replies received to a questionnaire. However since that date, new research work has been conducted on this subject. The study of this work and a more precise analysis of preceding publications have allowed a better understanding of the effects of electric current on living organisms and, in particular, on man.

This specifically applies to the limits of ventricular fibrillation which is the main cause of deaths by electric current, and the analysis of all results of recent research work on cardiac physiology and on the fibrillation threshold taken together, has made it possible to better appreciate the influence of the main physical parameters, and especially of the duration of the current flow.

Recent research work has also been conducted on the other physical accident parameters, especially the waveform and frequency of the current and the impedance of the human body. This revision of Publication 479 was therefore considered necessary and should be viewed as the logical development and evolution of the first edition.

CHAPTER 1: ELECTRICAL IMPEDANCE OF THE HUMAN BODY

1. General

For a given current path through the human body, the danger to persons depends mainly on the magnitude and duration of the current flow. However, the time/current zones specified in the following chapters are, in many cases, not directly applicable in practice for designing protection against electric shock, the necessary criterion being the admissible limit of touch voltage (i.e., the product of the current through the body and the body impedance) as a function of time. The relationship between current and voltage is not linear because the impedance of the human body varies with the touch voltage, and data on this relationship is accordingly required.

The different parts of the human body—such as the skin, blood, muscles, other tissues, and joints—present to the electric current a certain impedance composed of resistive and capacitive components.

The values of these impedances depend on a certain number of factors and, in particular, on the current path, on the touch voltage, the duration of the current flow, the frequency, the degree of moisture of the skin, the surface area of contact, the pressure exerted and on the temperature.

The impedance values indicated in this report result from a close examination of the experimental results available from measurements carried out principally on corpses and on some living persons.

2. Scope

This chapter indicates values for the electrical impedance of the human body as a function of the touch voltage, the frequency, the degree of moisture of the skin and the current path.

Note. — The values given in Clause 5 refer to frequencies of 50/60 Hz; values for higher frequencies and for direct current are under consideration.

3. Definitions

3.1 *Internal impedance of the human body (Z_i)*

Impedance between two electrodes in contact with two parts of the human body, after removing the skin from under the electrodes.

3.2 *Impedance of the skin (Z_p)*

Impedance between an electrode on the skin and the conductive tissues underneath.

3.3 *Total impedance of the human body (Z_T)*

Vectorial sum of the internal impedance and the impedances of the skin (see Figure 1, page 14).

3.4 *Initial resistance of the human body (R_i)*

Resistance limiting the peak value of the current at the moment when the touch voltage occurs.