

Australian Standard™

**Water supply—Valves for the control of
heated water supply temperatures**

**Part 1: Thermostatic mixing valves—
Materials design and performance
requirements**

This Australian Standard was prepared by Committee WS-026, Valves Primarily for Use in Warm and Hot Water Systems. It was approved on behalf of the Council of Standards Australia on 18 November 2004.
This Standard was published on 28 January 2005.

The following are represented on Committee WS-026:

AUSTAP
Australian Chamber of Commerce and Industry
Australian Industry Group
Australian Association of Certification Bodies
Building Research Association of New Zealand
Business New Zealand
SAI Global
Department of Health (South Australia)
Gas Appliance Manufacturers Association of Australia
Housing Industry Association
Institute of Hospital Engineering Australia
Master Plumbers and Mechanical Contractors Association NSW
Master Plumbers, Gasfitters and Drainlayers New Zealand
NSW Health Department
Water Corporation Western Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia, GPO Box 5420, Sydney, NSW 2001.

Australian Standard™

**Water supply—Valves for the control of
heated water supply temperatures**

**Part 1: Thermostatic mixing valves—
Materials design and performance
requirements**

Originally as AS 4032—1992.
Previous edition AS 4032—2002.
Revised and redesignated as AS 4032.1—2005.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 6454 1

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee WS-026, Valves Primarily for Use in Warm and Hot Water Systems, to supersede AS 4032.1—2002, *Thermostatic mixing valves*.

After consultation with stakeholders in both countries, Standards Australia/Standards New Zealand decided to develop this Standard as an Australian Standard rather than an Australian/New Zealand Standard.

This revision includes provision for electronically controlled valves, requirements for hot water shut-off performance and increased sizes up to 50 mm

This Standard is Part 1 of a suite of Standards that covers valves for the control of hot water temperatures as follows:

AS

4032 Water supply—Valves for the control of heated water supply temperatures

4032.1 Part 1: Thermostatic mixing valves—Materials, design and performance requirements (this Standard)

4032.2 Part 2: Tempering valves and end-of-line temperature-activated devices

4032.3 Part 3: Requirements for field testing, maintenance or replacement of thermostatic mixing valves, tempering valves and end-of-line temperature control devices

The objective of this Standard is to provide manufacturers, system designers, relevant authorities and others with performance requirements for thermostatic mixing valves, which give a level of protection to users against exposure to high or excessive fluctuations in mixed-water temperatures caused by variations, including shut-off, in the cold or hot water supply.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

Statements expressed in mandatory terms in notes, tables and figures are deemed to be requirements of this Standard.

This Standard necessarily deals with existing conditions, but is not intended to discourage innovation or to exclude material, equipment and methods that may be developed in the future. Revisions will be made from time to time in view of such developments, and amendments to this edition will be made only when absolutely necessary.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	5
1.2 APPLICATION	5
1.3 REFERENCED DOCUMENTS	5
1.4 DEFINITIONS	5
1.5 DESIGNATION	5
1.6 PRODUCT DATA	6
1.7 MARKING	7
1.8 INSTRUCTIONS	8
SECTION 2 MATERIALS	
2.1 SCOPE OF SECTION	9
2.2 CORROSION-RESISTANT METALLIC MATERIALS	9
2.3 COPPER	9
2.4 COPPER ALLOY	9
2.5 DEZINCIFICATION-RESISTANT (DR) COPPER ALLOY	9
2.6 STAINLESS STEEL	9
2.7 PLASTIC MATERIALS	10
2.8 OTHER COMPONENT MATERIALS	10
SECTION 3 DESIGN AND MANUFACTURE	
3.1 GENERAL	11
3.2 END CONNECTORS	11
3.3 LIMITATION OF TEMPERATURE ADJUSTMENT	11
3.4 ELECTRONIC VALVES	11
3.5 CROSS-FLOW PREVENTION DEVICES AND STRAINERS	11
3.6 ISOLATING VALVES	12
3.7 TMV WITH INTEGRAL OUTLET TAPS	12
SECTION 4 PERFORMANCE REQUIREMENTS	
4.1 GENERAL	13
4.2 PRODUCT IN CONTACT WITH DRINKING WATER	13
4.3 TORQUE TESTS	13
4.4 WATERTIGHTNESS AT AMBIENT TEMPERATURE	13
4.5 THERMAL SHUT-OFF	13
4.6 SENSITIVITY OF TEMPERATURE ADJUSTMENT	14
4.7 MIXED WATER TEMPERATURE OVERSHOOT ON STARTING FROM AMBIENT	14
4.8 TEMPERATURE STABILITY OF MIXED WATER	14
4.9 WATERTIGHTNESS AT OPERATING TEMPERATURE	15
4.10 ENDURANCE OF CONTROL SYSTEM AND OPERATING MECHANISM	15
4.11 SEQUENCE	15
APPENDICES	
A MEANS OF DEMONSTRATING COMPLIANCE WITH THIS STANDARD	17
B LIST OF REFERENCED DOCUMENTS	21

C	INSTALLATION, COMMISSIONING, FIELD TESTING AND MAINTENANCE INSTRUCTIONS	23
D	TEMPERATURE STOP/OVERRIDE CONTROL TORQUE TEST	25
E	WATERTIGHTNESS TEST	27
F	THERMAL SHUT-OFF TEST FOR COLD WATER AND HOT WATER ISOLATION	30
G	SENSITIVITY OF TEMPERATURE ADJUSTMENT TEST	36
H	MIXED WATER TEMPERATURE OVERSHOOTING ON STARTING FROM AMBIENT	38
I	TEMPERATURE STABILITY OF MIXED WATER TEST	43
J	ENDURANCE TESTING OF THERMOSTATIC ELEMENT/SENSOR AND OPERATING MECHANISM TEST	48
K	APPARATUS FOR TEST RIGS	51
L	PIPEWORK FOR TEST RIGS	52
M	TYPICAL TEST RIG FOR PERFORMANCE TESTS	54

Currently in preview, click buy full version.

STANDARDS AUSTRALIA**Australian Standard****Water supply—Valves for the control of heated water supply temperatures****Part 1: Thermostatic mixing valves—Materials design and performance requirements****SECTION 1 SCOPE AND GENERAL****1.1 SCOPE**

This Standard specifies requirements for the design, construction, testing, performance and means of compliance for metallic-bodied thermostatic mixing valves—

- (a) of nominal sizes not larger than DN 50;
- (b) for use with hot water at a supply temperature not exceeding 65 °C; and
- (c) for use with hot and cold water with working pressure not exceeding 1400 kPa.

When used for ablutionary purposes, thermostatic mixing valves complying with this Standard provide the user with reasonable protection against scalding or excessive temperature fluctuations due to variations of pressures and temperatures of the hot and cold water supplies, including shut-off of either the cold or hot water supply.

NOTES:

- 1 Diagrams in this Standard are typical and chosen without prejudice.
- 2 Thermostatic mixing valves require routine maintenance and performance testing in accordance with AS 4032.3.

1.2 APPLICATION

The operating range of the valve shall be nominated by the manufacturer.

Thermostatic mixing valves, when adjusted to an outlet temperature not exceeding 45 °C, are intended for use in health care, aged, childcare, people with disabilities or any other similar at risk situations.

Thermostatic mixing valves, when adjusted to an outlet temperature not exceeding 50 °C, may be used for other applications.

Means for demonstrating compliance with this Standard shall be as given in Appendix A.

1.3 REFERENCED DOCUMENTS

The documents referred to in this Standard are listed in Appendix B.

1.4 DEFINITIONS

For the purpose of this Standard, the definitions in AS/NZS 3500.0 and the ones below apply.