

AS 4078—1992

ISO 5923:1989(E)

Reconfirmed 2018

Australian Standard<sup>®</sup>

---

**Fire protection—Fire extinguishing  
media—Carbon dioxide**

---

This Australian Standard was prepared by Committee FP/3, Fire Extinguishers. It was approved on behalf of the Council of Standards Australia on 15 September 1992 and published on 14 December 1992.

---

The following interests are represented on Committee FP/3:

Australian Assembly of Fire Authorities  
Australian Association of Rural Fire Authorities  
Australian Fire Protection Association  
Commonwealth Fire Board  
Department of Administrative Services—Australian Construction Services  
Department of Consumer Affairs, New South Wales  
Department of Defence  
Federal Bureau of Consumer Affairs  
Fire Protection Industry Association of Australia  
Insurance Council of Australia  
Ministry of Consumer Affairs, Victoria  
Telecom Australia  
Western Australian Fire Brigades Board  
WorkCover Authority of New South Wales

---

**Review of Australian Standards.** To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

STANDARDS AUSTRALIA

RECONFIRMATION

OF

AS 4078–1992

Fire protection–Fire extinguishing media–Carbon dioxide

RECONFIRMATION NOTICE

Technical Committee FP-003 has reviewed the content of this publication and in accordance with Standards Australia procedures for reconfirmation, it has been determined that the publication is still valid and does not require change.

Certain documents referenced in the publication may have been amended since the original date of publication. Users are advised to ensure that they are using the latest versions of such documents as appropriate, unless advised otherwise in this Reconfirmation Notice.

Approved for reconfirmation in accordance with Standards Australia procedures for reconfirmation on 19 October 2018.

The following are represented on Technical Committee FP-003:

Association of Accredited Certification Bodies  
Australasian Fire and Emergency Service Authorities Council  
Australian Building Codes Board  
Australian Industry Group  
Australian Institute of Building Surveyors  
CSIRO  
Fire Protection Association Australia  
Fire Protection Association New Zealand  
Institute of Fire Engineers (New Zealand)  
Insurance Council of Australia Limited  
National Fire Industry Association  
TestSafe Australia

NOTES

Currently in preview, click buy full vers.

Australian Standard<sup>®</sup>

---

**Fire protection—Fire extinguishing  
media—Carbon dioxide**

---

First published as AS 4078—1992.

PUBLISHED BY STANDARDS AUSTRALIA  
(STANDARDS ASSOCIATION OF AUSTRALIA)  
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 7870 X

## PREFACE

This Standard was prepared by the Standards Australia Committee on Fire Extinguishers. It is identical with and has been reproduced from ISO 5923:1989 (E), *Fire protection—Fire extinguishing media—Carbon dioxide*.

Under arrangements made between Standards Australia and the international bodies, ISO and IEC, as well as certain other Standards organizations, users of this Australian Standard are advised of the following:

- (a) Copyright is vested in Standards Australia.
- (b) The number of this Standard is not reproduced on each page, its identify is shown only on the cover and title pages.
- (c) There may be dual language sections, but English is always one of the languages reproduced.
- (d) Where any cross-references to page numbers appear within the text, these relate to page numbering in the International Standard and are to be disregarded.

This Standard is one of a series giving specifications for fire extinguishing media in common use and which are in need of specification for firefighting purposes. These specifications are designed to establish that the medium in question has at least a minimum useful firefighting capability and can therefore be reasonably sold for fire extinguishing purposes.

For the purposes of this Australian Standard, the ISO text should be modified as follows:

- (a) *Terminology* The words 'Australian Standard' should replace the words 'International Standard' wherever they appear.
- (b) *Decimal marker* Substitute a full point for a comma as a decimal marker.
- (c) *References* Replace reference to other publications by reference to Australian Standards as follows:

| <i>References to International Standard</i> |   | <i>Australian Standard</i> |   |
|---|---|----------------------------|---|
| ISO   |   | AS                         |   |
| 385-1:                                      | Laboratory glassware—Burettes   | 2162                       | Code of practice for the use of volumetric glassware        |
| Part 1:                                     | General requirements  |                            |   |
| Part 2:                                     | Burettes for which no waiting time is specified                         | 2165                       | Burettes and bulb burettes                                  |
| Part 3:                                     | Burettes for which a waiting time of 30 s is specified                  |                            |   |
| 648:  | Laboratory glassware—One-mark pipettes                                  | 2166                       | One-mark pipettes   |
| 2591-1                                      | Test sieving  |                            |   |
| Part 1:                                     | Method using test sieves of woven wire cloth and perforated metal plate | 1152                       | Test sieves   |
| 3310-1                                      | Test sieves—Technical requirements and testing                          |                            |   |
| Part 1:                                     | Test sieves of metal wire cloth   | 1152                       | Test sieves   |
| 4703:                                       | Refillable seamless steel gas cylinders                                 | 2030                       | SAA Gas Cylinders Code                                      |
|   |   | 2030.1                     | Part 1: Cylinders for compressed gases other than acetylene |

## CONTENTS

|   | <i>Page</i> |
|---|-------------|
| 1 Scope .....   | 4           |
| 2 Normative references .....                                  | 4           |
| 3 Definition .....  | 4           |
| 4 Requirements .....  | 4           |
| 5 Sampling .....  | 4           |
| 6 Methods of test .....                                       | 5           |
| 7 Packaging and labelling .....                               | 5           |
| Annex A Determination of water content .....                  | 6           |
| Annex B Determination of oil content .....                    | 7           |
| Annex C Determination of total sulfur compounds content ..... | 10          |
| Annex D General properties .....                              | 12          |
| Annex E Safety precautions for handling .....                 | 13          |
| Annex F Compatibility .....                                   | 14          |
| Annex G Toxicology .....                                      | 15          |

## © Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

# Fire Protection—Fire extinguishing media—Carbon dioxide

## 1 Scope

This International Standard specifies requirements for carbon dioxide for use as a fire extinguishing medium.

## 2 Normative references

The following standards contain provisions which, through reference in this text, constitute provisions of this International Standard. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this International Standard are encouraged to investigate the possibility of applying the most recent editions of the standards indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

ISO 385-1: 1984, *Laboratory glassware — Burettes — Part 1: General requirements.*

ISO 385-2: 1984, *Laboratory glassware — Burettes — Part 2: Burettes for which no waiting time is specified.*

ISO 385-3: 1984, *Laboratory glassware — Burettes — Part 3: Burettes for which a waiting time of 30 s is specified.*

ISO 648: 1977, *Laboratory glassware — One-mark pipettes.*

ISO 2591-1: 1988, *Test sieves — Part 1: Method using test sieves of woven wire cloth and perforated metal plate.*

ISO 3310-1: 1982, *Test sieves — Technical requirements and testing — Part 1: Test sieves of metal wire cloth.*

ISO 705: 1983, *Refillable seamless steel gas cylinders.*

## 3 Definition

For the purposes of this International Standard, the following definition applies.

**carbon dioxide:** The chemical compound CO<sub>2</sub> used as a fire extinguishing medium.

## 4 Requirements

Carbon dioxide shall comply with the requirements of table 1, when tested by the appropriate method of test specified in clause 6.

Table 1 — Requirements<sup>1)</sup>

| Property   | Requirement |
|--|-------------|
| Purity, % (V/V) min.   | 99,5        |
| Water content, % (m/m) max.  | 0,015       |
| Oil content, ppm by mass, max.   | 5           |
| Total sulphur compounds content, expressed as sulphur, ppm by mass, max. | 5,0         |

<sup>1)</sup> Carbon dioxide obtained by converting dry ice to liquid will usually comply with these requirements unless it has been properly processed to remove excess water and oil.

## 5 Sampling

### 5.1 General

Samples of carbon dioxide needed to perform all the tests required by this International Standard shall be taken from the same manufacturing lot, using identical sampling procedures.

NOTE — Attention is drawn to the need to design equipment for handling carbon dioxide such that it is either capable of withstanding the pressures involved or protected from them.

### 5.2 Sampling equipment

Rigid metal connections or flexible reinforced nylon hose should be used throughout the sampling equipment and shall be kept as short as possible. All components shall have a design pressure of not less than 137 bar.

### 5.3 Procedure

#### 5.3.1 General

Two methods of sampling are specified:

- a) direct sampling, in which the sample is passed to an evaporator and then directly to the analytical apparatus;