

Australian Standard[®]

**Secondary batteries for use with
stand-alone power systems**

Part 1: General requirements

[Defence Title allocated by Codification and Standardisation Authority:
BATTERIES RECHARGEABLE
NATO Supply Classification 6140]

This Australian Standard was prepared by Committee EL/5, Secondary Batteries. It was approved on behalf of the Council of Standards Australia on 2 October 1992 and published on 15 March 1993.

The following interests are represented on Committee EL/5:

Australian Automobile Association
Australian Automotive Aftermarket Association
Australian Chamber of Commerce and Industry
Australian Electrical and Electronic Manufacturers Association
Australian Federation of Consumer Organizations
Australian Lead Development Association
Department of Defence
Electricity Supply Association of Australia
Federal Chamber of Automotive Industries
Institution of Engineers, Australia
Telecom Australia

Additional interests participating in preparation of Standard:

Civil Aviation Authority
Department of Administrative Services — Australian Construction Services

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important, therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

Australian Standard[®]

**Secondary batteries for use with
stand-alone power systems**

Part 1: General requirements

First published as AS 4086.1—1993.

PREFACE

This Standard was prepared by the Standards Australia Committee on Secondary Batteries.

A distinguishing feature of stand-alone power systems is the unpredictability of and limitation on the amount of charging power available and hence on the charge-discharge cycles imposed on the battery. Batteries for use in stand-alone power systems have different requirements to those designed for use in other applications, in particular low self-discharge, long life under the charging cycle associated with stand-alone systems, and the ability to operate over a wide temperature range.

Batteries in stand-alone power systems are often supplied with power from a number of sources, such as photovoltaic arrays, wind generators, water generators and diesels, combined to form a hybrid system.

This Standard is the first part of a two-part Standard on stand-alone batteries, the two parts of which are—

- (a) this Standard; and
- (b) a proposed second part covering the installation and maintenance of stand-alone batteries.

In the preparation of this Standard reference was made to a draft Standard, Rechargeable Batteries for photovoltaic solar energy systems, prepared by IEC Committee 21, Secondary Cells and Batteries.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	4
1.2 REFERENCED DOCUMENTS	4
1.3 DEFINITIONS	4
1.4 INFORMATION TO BE PROVIDED BY THE MANUFACTURER	5
1.5 MARKING	5
SECTION 2 FUNCTIONAL CHARACTERISTICS AND REQUIREMENTS	
2.1 CAPACITY	7
2.2 CYCLE LIFE	7
2.3 RESISTANCE TO OVERCHARGE	7
2.4 CHARGE RETENTION	7
2.5 CHARGE-DISCHARGE EFFICIENCY	7
2.6 CAPACITY RECOVERY FOLLOWING OVER-DISCHARGE	7
2.7 MECHANICAL ENDURANCE	8
2.8 INTERNAL RESISTANCE	8
2.9 ELECTROLYTE LEVEL INDICATION	8
SECTION 3 TEST CONDITIONS	
3.1 ACCURACY OF MEASURING INSTRUMENTS	9
3.2 PREPARATION OF TEST BATTERIES	9
3.3 TEST SEQUENCE	9
APPENDICES	
A CAPACITY TEST METHOD (120 HOUR DISCHARGE RATE)	10
B CAPACITY TEST METHOD (10 HOUR DISCHARGE RATE)	11
C CYCLE LIFE TEST METHOD	12
D OVERCHARGE RESISTANCE TEST METHOD	13
E CHARGE RETENTION TEST METHOD	14
F CHARGE-DISCHARGE EFFICIENCY TEST METHOD	15
G CAPACITY RECOVERY TEST METHOD	17
H MECHANICAL ENDURANCE TEST METHODS	18
I INTERNAL RESISTANCE TEST METHOD	19

STANDARDS AUSTRALIA

Australian Standard

Secondary batteries for use with stand-alone power systems

Part 1: General requirements

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE This Standard specifies requirements for secondary batteries for use with stand-alone power systems.

Stand-alone power systems are those that are not connected to the power distribution system of an electricity supply authority. Stand-alone systems are supplied with power from one or a combination of the following sources: a photovoltaic array, a wind generator, a water generator or a diesel generator.

This Standard specifies requirements for all types of batteries including lead-acid and nickel cadmium and covers both vented and sealed cells.

The Standard includes tests designed to verify the capacity, efficiency and life of batteries (see Appendices A to I).

1.2 REFERENCED DOCUMENTS The following documents are referred to in this standard:

AS	
1042	Direct-acting indicating electrical measuring instruments and their accessories
1099	Basic environmental testing procedures for electrical technology
1099.2.6	Method 2.6: Test F_c —Vibration (sinusoidal)
1099.2.29	Method 2.29: Test E_b —Bump and guidance
1099.2.31	Method 2.31: Test E_c —Drop and topple, primarily for equipment
1104	Informative symbols for use on electrical and electronic equipment
2700	Colour standards for general purposes

1.3 DEFINITIONS For the purpose of this Standard, the definitions below apply.

1.3.1 Battery—a unit consisting of one or more cells connected in a series, parallel, or series-parallel arrangement to supply the voltage and current requirements of a connected load.

1.3.2 Capacity (C)—the quantity of electricity in ampere hours (A.h) which a fully charged battery can deliver under specified conditions.

The capacity of a cell or battery is denoted by the symbol C . As the capacity varies with rate of discharge, the symbol C is followed by a numerical suffix giving the rate of discharge. Thus C_{120} is the capacity in ampere hours (A.h) at the 120 hour rate of discharge. The specified temperature is usually 25°C. The final voltage depends on battery type and conditions of service.

Capacity is specified as follows:

- Actual capacity**—the quantity of electricity in ampere hours (A.h) that can be withdrawn from a cell or battery for a specified set of operating conditions including discharge rate, temperature, initial state of charge, age, and final voltage.
- Rated capacity**—the quantity of electricity in ampere hours (A.h), declared by the manufacturer which a battery can deliver after a full charge under specified conditions.

NOTE: The specified conditions are rate of discharge final voltage and temperature.

1.3.3 Cell—the basic electrochemical unit used to store electrical energy.

1.3.4 Charge-discharge rate—the current at which a battery is charged or discharged. This can be expressed in amperes or as a multiple of the battery's rated capacity. For example, if a battery is rated at 100 A.h at the 10 hour rate of discharge and is being discharged at 50 A, its discharge rate can be expressed as 0.1 C_{10} .

1.3.5 Charging—conversion of electrical energy into chemical potential energy within a cell by the passage of a direct current in the direction opposite to that of discharge.

1.3.6 Cycle—one discharge-charge sequence to a specified depth of discharge.

1.3.7 Cycle life—the number of cycles to a specified depth of discharge at a fixed temperature that a cell or battery can undergo before failing to meet its efficiency performance criteria.

1.3.8 Depth of discharge (DOD)—the ampere hours removed from a fully charged battery at a specified discharge rate. Depth of discharge is expressed as a percentage of the battery's rated capacity. For example, the removal of 25 A.h from a 100 A.h battery results in a 25% depth of discharge.