

Australian Standard[®]

Telecommunication overvoltages

Part 1: Protection of persons

This Australian Standard was prepared by Committee TE/20, Telecommunications Overvoltage Protection. It was approved on behalf of the Council of Standards Australia on 17 October 1994 and published on 5 March 1995.

The following interests are represented on Committee TE/20:

AUSTEL

Australian Chamber of Commerce and Industry

Australian Electrical and Electronic Manufacturers Association

Australian Information Industry Association

Electricity Supply Association of Australia

Optus Communications

Telecom Australia

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcome. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 94004.

Australian Standard[®]

Telecommunication overvoltages

Part 1: Protection of persons

First published as AS 4262.1—1995.

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 9398 9

PREFACE

This Standard was prepared by the Standards Australia/Standards New Zealand Committee on Telecommunications Overvoltage Protection to provide information for the protection of users and equipment from overvoltage surges associated with telecommunication systems.

The objective of this Standard is to provide owners, installers and users of telecommunication equipment with information on—

- (a) the basic principles involved in the protection of users of telecommunication facilities from the effects of nearby electrical disturbances such as lightning strikes; and
- (b) how the effect of these electrical disturbances can be significantly reduced through the use of surge suppression devices;

in order to allow them to make their own decision regarding both the need for and the type of protection that should be fitted.

This Standard is the result of a consensus among Australian and New Zealand representatives on the Joint Committee to produce it as an Australian Standard.

The rapidly changing situation in the telecommunications area has produced a need for a range of documents that explains and describes practices that have not previously been publicly available. The continued trend towards using the latest technology has also brought with it the need to ensure the reliable operation of telecommunication equipment based on this technology. This problem is intended to be addressed in AS 4262.2 *Telecommunication overvoltages, Part 2: Protection of equipment*.

The term 'informative' has been used in this Standard to define the application of the appendix to which it applies. An 'informative' appendix is only for information and guidance.

© Copyright — STANDARDS AUSTRALIA

Users of Standards Australia are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
FOREWORD	4
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	5
1.2 APPLICATION	5
1.3 REFERENCED DOCUMENTS	5
1.4 DEFINITIONS	5
SECTION 2 PRINCIPLES	
2.1 GENERAL CONSIDERATIONS FOR PROTECTION	7
2.2 PROTECTION OF USERS	9
SECTION 3 ANALYSIS OF PROTECTION AGAINST LIGHTNING OVERVOLTAGES	
3.1 GENERAL	12
3.2 FACTORS AFFECTING LIGHTNING INCIDENT PROBABILITY	12
SECTION 4 PROTECTION SYSTEMS	
SECTION 5 INSTALLATION METHODS	
5.1 GENERAL	17
5.2 MDF/IDF INSTALLATIONS	17
5.3 DOMESTIC AND NON-MDF/IDF INSTALLATIONS	17
5.4 INSTALLATIONS NOT CONNECTED TO THE SUPPLY AUTHORITY MAINS	17
APPENDICES	
A SOURCES OF OVERVOLTAGE AND MODES OF ENTRY	21
B LIGHTNING HAZARDS AND SELF-HELP PROTECTION	25

FOREWORD

This Standard sets out guidelines for the protection of users of telecommunication facilities from the effects of overvoltages.

It examines the significant factors requiring consideration due to lightning induced overvoltages. Sources of overvoltages, other than lightning, are power frequency disturbances caused by induction, direct contact and earth potential rise (EPR), electrostatic discharge (ESD) and abnormal test conditions. For information on sources of overvoltages, see Appendix A.

Whilst there are a number of possible sources of overvoltages, this Standard is primarily concerned with lightning initiated overvoltages as they represent the most common and severe source of overvoltage that the equipment user may be exposed to. Sources of overvoltage other than lightning are not expected to exceed the minimum required withstand voltages of telecommunication equipment.

Guidance is given for determining the need for personnel protection to be fitted in particular telecommunication installations based on the assessed risk.

The basic protection principles that need to be adhered to are discussed and a typical protective installation is explained.

Of particular concern is the occurrence of potential differences which may exist between conductive elements, such as metallic water services, power systems, telecommunication systems entering the building and local earth features. Methods of reducing these potential differences by a system of bonding of all affected conductors are outlined and the principles of bonding and typical installation techniques covered.

STANDARDS AUSTRALIA

Australian Standard

Telecommunication overvoltages

Part 1: Protection of persons

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE This Standard specifies the requirements for the protection of users of telecommunication equipment from overvoltages which may exist between a user environment and the telecommunication facilities in that environment.

This Standard does not apply to the carriers' networks.

NOTE: See the AUSTEL Technical Standards for the mandatory requirements for the connection of equipment to carriers' networks.

1.2 APPLICATION This Standard is intended for use by the owner, installers and users of telecommunication facilities.

The protection provided by compliance with this Standard is through the reduction of risk of injury from overvoltages. Although the probability and severity of injury may be reduced, the risk of such injuries occurring cannot be eliminated.

For information on lightning hazards and self-help protection, see Appendix B.

1.3 REFERENCED DOCUMENTS The following documents are referred to in this Standard:

AS

- 1768 Lightning protection
- 2420 Fire test methods for solid insulating materials and non-metallic enclosures used in electrical equipment
- 3000 Electrical installations—Buildings, structures and premises (known as the SAA Wiring Rules)
- 4117* Surge suppression devices for telecommunication applications

AS/NZS

- 3260 Approval and test specification—Safety of information technology equipment including electrical business equipment

AUSTEL

- TS 001 Safety Requirements for Customer Equipment
- TS 002 Installation Requirements for Customer Cabling (Wiring Rules)

OTHER

- Telecommunications Act 1991 No. 98 of 1991

1.4 DEFINITIONS For the purpose of this Standard, the following definitions apply.

1.4.1 Bonding conductor—the conductor that connects the MDF/IDF or, in a non-MDF/IDF situation, the surge suppression device to the power earthing system.

* First published as an Interim Standard.