

Australian Standard™

**DN 80 piston type vacuum interface
valves for municipal sewer systems**

This Australian Standard was prepared by Committee WS-022, Valves for Waterworks Purposes. It was approved on behalf of the Council of Standards Australia on 9 September 2004.

This Standard was published on 1 November 2004.

The following are represented on Committee WS-022:

Association of Consulting Engineers Australia
Australian Chamber of Commerce and Industry
Australian Industry Group
Australian Valve Manufacturers Association
Business New Zealand
Casting Technology New Zealand
Certification Bodies (Australia)
Department of Contract and Management Services W.A.
Institution of Engineers Australia
Local Government New Zealand
Master Plumbers Australia
New Zealand Water and Waste Association
Plastics Industry Pipe Association of Australia
Society of Mechanical Engineers of Australasia
Victorian Employers Chamber of Commerce
Water Services Association of Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

Australian Standard™

**DN 80 piston type vacuum interface
valves for municipal sewer systems**

First published as AS 4310—2004.

COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 6331 6

PREFACE

This Standard was prepared by the Standards Australia Committee WS-022, Valves for Waterworks Purposes and was based upon Water Industry Standard WSA 116 published by the Water Services Association of Australia, which it now replaces.

The objective of this Standard is to provide performance requirements for manufacturers of DN 80 piston type vacuum interface valves for municipal vacuum sewer systems. It has been specifically developed for the urban water industry for use by water agencies. The Standard is not intended for valves used in vacuum sewage applications for general industry e.g., ships, commercial premises, industry, aircraft, etc.

The Standard draws upon the considerable experience gained by Australian water agencies in the design, construction, operation and maintenance of vacuum sewerage systems since the mid-1970s.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the appendix to which they apply. A 'normative' appendix is an integral part of a Standard, whereas an 'informative' appendix is only for information and guidance.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	4
1.2 REFERENCED DOCUMENTS	4
1.3 DEFINITIONS	4
1.4 FREEDOM FROM DEFECTS	5
SECTION 2 MATERIALS AND COMPONENTS	
2.1 MATERIALS	7
2.2 O-RINGS (ELASTOMERIC TOROIDAL SEALING RINGS)	7
2.3 VALVE AND CONTROLLER TUBING	7
SECTION 3 DESIGN	
3.1 GENERAL	9
3.2 VALVE	9
3.3 CONTROLLER	10
3.4 SENSOR TUBE	11
3.5 BREATHER	11
3.6 INTERCHANGEABILITY	11
3.7 MAINTENANCE FEATURES	12
3.8 FASTENERS	12
3.9 SUBMERGENCE	12
3.10 CYCLE COUNTERS	12
3.11 AIR ADMITTANCE VALVES (BREATHING BELLS)	12
SECTION 4 PERFORMANCE TESTS	
4.1 GENERAL	13
4.2 TYPE TESTS	13
4.3 PRODUCTION TESTS	14
4.4 TEST CERTIFICATION	15
SECTION 5 MARKING AND PACKAGING	
5.1 BODY MARKING	17
5.2 PACKAGING, STORAGE AND TRANSPORTATION	17
SECTION 6 MANUALS	
6.1 FORMAT AND LANGUAGE	18
6.2 CONTENT	18
APPENDICES	
A MEANS FOR DEMONSTRATING COMPLIANCE WITH THIS STANDARD	19
B PURCHASING GUIDELINES	23
C REFERENCED DOCUMENTS	24
D ALTERNATIVE MATERIAL REQUIREMENTS	26
E RESISTANCE TO BLOCKAGE TEST	27
F SUBMERGENCE TEST	29
G ENDURANCE TEST	30

STANDARDS AUSTRALIA

Australian Standard**DN 80 piston type vacuum interface valves for municipal sewer systems**

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard specifies requirements for DN 80 piston-type vacuum interface valves for municipal sewer systems operating up to a maximum temperature of 45°C and 100% relative humidity.

This Standard is applicable to valves installed in vacuum sewage collection chambers as part of a reticulation system. The valves provide an interface between the vacuum in the sewerage reticulation system and atmospheric pressure in the collection chamber. The valve is designed to activate (fire) at a preset sewage level in the collection chamber in order to facilitate transfer of the sewage into the vacuum sewer.

Means for demonstrating compliance shall be in accordance with Appendix A.

NOTE: Purchasing guidelines are given in Appendix B.

1.2 REFERENCED DOCUMENTS

The documents referred to in this Standard are listed in Appendix C.

1.3 DEFINITIONS

For the purpose of this Standard, the definitions below apply.

1.3.1 Allowable operating pressure

The allowable internal pressure, including surge, which a component can safely withstand in service.

1.3.2 Allowable test pressure

The maximum internal hydrostatic pressure that may be applied on site to a component in a newly installed pipeline.

1.3.3 Batch volume

The volume of sewage in the sump corresponding to a level at which the controller level sensor setting activates the vacuum interface valve.

1.3.4 Breather

A device employed by the controller to facilitate transfer of atmospheric air into the valve housing to allow closure of the vacuum interface valve.

1.3.5 Collection chamber

A collection sump and vacuum interface valve pit connected to the vacuum sewer and into which sewage gravitates from the property(s) through the sanitary drain(s).

1.3.6 Collection sump

A pit formed in the floor of the collection chamber to store flows of sewage until sufficient has been accumulated to activate the interface valve.