

Australian Standard[®]

Tunnel fire safety

STANDARDS
Australia



This Australian Standard® was prepared by Committee FP-023, Tunnel Fire Safety. It was approved on behalf of the Council of Standards Australia on 27 October 2010. This Standard was published on 1 February 2011.

The following are represented on Committee FP-023:

- AUSTRROADS
 - Australasian Fire and Emergency Service Authorities Council
 - Australian Automobile Association
 - Australian Tunnel Operators Group
 - CSIRO Manufacturing and Materials Technology
 - Engineers Australia
 - Fire Protection Association Australia
 - Main Roads Department, Queensland
 - Main Roads Western Australia
 - Society of Fire Safety
 - RailCorp
 - Risk Management Institution of Australasia
 - Roads and Traffic Authority of NSW
-

This Standard was issued in draft form for comment as DR AS 4825.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

Tunnel fire safety

First published as AS 4825—2011.

COPYRIGHT

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

Published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 978 0 7337 9757 6

PREFACE

This Standard was prepared by Standards Australia Committee FP-023, Tunnel Fire Safety.

Whilst a number of existing overseas Standards and guidance documents were considered by the committee during the preparation of this first edition of the Standard, the document is not based upon any other Standard.

The committee decided that the most appropriate format for the Standard is to facilitate the current Australian practice of adopting a performance-based approach to fire safety in tunnels. Such an approach is reliant on fire safety engineering methodologies similar to those described in the *International Fire safety engineering Guidelines* which is extensively used in Australia for performance-based design for fire safety in buildings.

The Standard is intended to provide a generic framework for establishing the fire safety systems that are required in road, rail or bus tunnels to provide an acceptable level of safety in case of fire. This Standard is intended to guide professional fire safety engineers in the development of a fire safety strategy, the design and documentation of fire safety systems for tunnels.

Specifically, this Standard—

- (a) recommends appropriate performances of the fire safety system;
- (b) provides guidance on appropriate fire safety strategies;
- (c) provides information on what may constitute appropriate trial concept design for various tunnels;
- (d) does not restrict innovative approaches or new technology provided that the required performance can be demonstrated;
- (e) outlines what may be appropriate analysis methodology;
- (f) allows for both deterministic and probabilistic (risk-based) analysis and approach;
- (g) specifies what may constitute appropriate acceptance criteria;
- (h) provides general guidelines on system installation and maintenance, which is intended to facilitate making appropriate assumptions in the engineering analysis; and
- (i) refers to other Standards providing greater detail where appropriate.

It is not the purpose of this Standard to prescribe an acceptable level of fire safety for tunnels rather to provide a framework for establishing the required fire safety systems.

As it not possible to prescribe either the fire safety measures or the analysis required, the Standard has been written as an 'informative' document providing guidance to competent designers to undertake a performance-based design for fire safety. Further, the information presented permits a systematic consideration of a fire safety strategy with fire safety measures that can form the input into the fire safety engineering analysis to demonstrate to stakeholders that an acceptable level of safety can be achieved by the design.

This Standard incorporates a Commentary on some Clauses. The Commentary directly follows the relevant Clause, is designated by 'C' preceding the Clause number and is printed in italics in a panel.

CONTENTS

	<i>Page</i>
FOREWORD.....	5
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	6
1.2 OBJECTIVE.....	6
1.3 LIMITATIONS OF STANDARD	7
1.4 TUNNEL CLASSIFICATION.....	7
1.5 REFERENCED DOCUMENTS	7
1.6 DEFINITIONS	9
1.7 ABBREVIATIONS	12
SECTION 2 KEY INFORMATION AND DESIGN CONSIDERATION	
2.1 SCOPE OF SECTION	13
2.2 PHYSICAL CHARACTERISTICS	13
2.3 DESIGN CONSIDERATIONS.....	13
SECTION 3 FIRE ENGINEERING PROCESS	
3.1 SCOPE OF SECTION	18
3.2 ROLES OF STAKEHOLDERS	18
3.3 FIRE SAFETY DESIGN STAGES.....	20
3.4 FIRE SAFETY DOCUMENTATION	21
SECTION 4 TRIAL CONCEPT DESIGN	
SECTION 5 PERFORMANCE OF FIRE SAFETY MEASURES	
5.1 GENERAL	35
5.2 FIRE DETECTION SYSTEM	35
5.3 FIRE ALARM SYSTEM	35
5.4 VIDEO SURVEILLANCE	35
5.5 COMMUNICATION	36
5.6 TRAFFIC MONITORING.....	36
5.7 TRAFFIC MANAGEMENT.....	36
5.8 EMERGENCY/INCIDENT MANAGEMENT	36
5.9 EGRESS	37
5.10 EMERGENCY LIGHTING.....	37
5.11 WAYFINDING	37
5.12 FIRST ATTACK FIREFIGHTING	38
5.13 SMOKE HAZARD MANAGEMENT FOR EVACUATION	38
5.14 FACILITIES FOR EMERGENCY SERVICES INTERVENTION	38
5.15 FIRE-SUPPRESSION	39
5.16 STRUCTURAL FIRE RESISTANCE	39
5.17 FIRE COMPARTMENTATION	39
5.18 DRAINAGE SYSTEM PROTECTION	39
5.19 FIRE LOAD	40
5.20 EMERGENCY POWER SUPPLY	40

SECTION 6 FIRE ENGINEERING ASSESSMENT	
6.1	GENERAL 41
6.2	DETERMINISTIC AND PROBABILISTIC ANALYSIS 41
6.3	FIRE ENGINEERING ANALYSIS 41
6.4	ACCEPTANCE CRITERIA 47
SECTION 7 DESIGN GUIDANCE OF FIRE SAFETY MEASURES	
7.1	SCOPE OF SECTION 50
7.2	PERFORMANCE 50
7.3	DESIGN GUIDANCE 50
SECTION 8 FIRE PROTECTION SYSTEM INTEGRATION	
8.1	GENERAL 60
8.2	HUMAN MACHINE/COMPONENT INTERFACE 60
8.3	CONTROL ROOM DESIGN 61
SECTION 9 INSTALLATION AND CONSTRUCTION	
9.1	GENERAL 62
9.2	GENERAL INSTALLATION AND CONSTRUCTION 62
9.3	QUALITY MANAGEMENT 62
9.4	INCOMING INSPECTIONS 62
9.5	HANDLING AND STORAGE 62
9.6	VERIFICATION OF INSTALLATION AND CONSTRUCTION 63
9.7	PROTECTION OF INSTALLED FIRE SAFETY MEASURES 63
9.8	AS-BUILT DRAWINGS AND SPECIFICATIONS 63
9.9	ADDITION AND ALTERATION OF EXISTING FIRE SAFETY MEASURE 63
SECTION 10 TESTING AND COMMISSIONING	
10.1	GENERAL 64
10.2	DEVELOPMENT OF THE TESTING AND COMMISSIONING PLAN 64
10.3	TESTING AND COMMISSIONING OF SYSTEM COMPONENTS 65
10.4	TESTING AND COMMISSIONING OF FIRE SAFETY MEASURES 66
10.5	TESTING AND COMMISSIONING OF THE FIRE SAFETY SYSTEM 67
10.6	COMMISSIONING REPORT(S) 67
10.7	OPERATIONAL READINESS 67
SECTION 11 MAINTENANCE	
11.1	GENERAL 69
11.2	DESIGN FOR MAINTENANCE 69
11.3	MAINTENANCE 70
SECTION 12 EMERGENCY MANAGEMENT AND FIRE BRIGADE INTERVENTION	
12.1	GENERAL 73
12.2	EMERGENCY MANAGEMENT 73
12.3	FIRE BRIGADE INTERVENTION 74
APPENDICES	
A	DESIGN FIRE GUIDANCE 78
B	TYPICAL TIME-TEMPERATURE CURVES 80

FOREWORD

The design and implementation of fire safety measures and a management system for a tunnel will be influenced by the varying needs and operational requirements pertinent to the tunnel's use. Factors such as traffic volume, nature of vehicles, length of tunnel, and traffic conditions, all influence the risk and hence the level of safety within tunnels. Thus, fire safety measures that may be adequate to provide an acceptable level of risk under one set of operating conditions, may not be adequate under a different set of circumstances. Therefore, it is not possible to provide a prescriptive list of fire safety measures suitable for tunnels that, at first glance, are similar in specific characteristics (e.g. length).

The acceptability of a specific tunnel design is a matter for all the stakeholders, which include authorities having a regulatory function, in addition to the tunnel's owner and operator.

Fire safety engineering is an iterative process consisting of the evaluation of an initial concept design and a series of design assumptions that are tested through an analysis process. If the analysis reveals that the acceptance criteria are not met, then the concept design is modified until an acceptable outcome is obtained. The design assumptions used in the analysis then needs to be implemented in both the design and the built works to arrive at a tunnel with an acceptable level of safety.

STANDARDS AUSTRALIA

Australian Standard
Tunnel fire safety

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE

This Standard provides guidelines for fire safety in new road, rail and bus tunnels. It covers uni-directional and bi-directional tunnels of various lengths meeting the limitations outlined in Clause 1.3.

This Standard can be applied to tunnels involving vehicles with no drivers such as driverless trains, although special additional considerations may apply. For rail and bus tunnels, this Standard addresses the tunnel/station interface. This Standard addresses tunnels used to carry both passengers and freight, and the combustible materials and goods carried by those vehicles.

This Standard is not specifically intended for existing tunnels; however, the general principles may be applied to the upgrade of existing tunnels to improve fire safety. In the case of modification works to a tunnel, the modification should be treated as building a new tunnel for interpretation of this Standard. The existing constraints however, may limit the choice of fire safety measures that can be implemented. Such constraints may result in the fire safety measures not being able to fully satisfy the objective contained in this Standard.

1.2 OBJECTIVE

The objective of this Standard is to provide guidance on design, system selection, construction, operation and emergency management of road, rail and bus tunnels in order to satisfy fire safety objectives and other objectives identified by the stakeholders.

1.3 LIMITATIONS OF STANDARD

This Standard does not apply to the following types of tunnels:

- (a) Tunnels that do not meet the definition of a tunnel in Clause 1.6.
- (b) Funicular tunnels.
- (c) Service tunnels.
- (d) Pedestrian or bicycle tunnels.
- (e) Railway and bus stations.
- (f) Tunnels for vehicles with no persons onboard.

This Standard does not cover transportation of dangerous goods through tunnels.

NOTE: Transportation of dangerous goods usually involves a comprehensive risk assessment as to the optimum transportation route and other safety considerations. If dangerous goods or bulk fuels are to be transported through a tunnel, consideration should be given to any additional fire safety measures or precautions required to that are given in this Standard.

This Standard does not address fire safety during construction.