

AS 5804.1:2025



STANDARDS
Australia



High-voltage live work

Part 1: General

currently in preview, click buy full version



AS 5804.1:2025

This Australian Standard® was prepared by EL-052, Electrical Energy Networks, Construction and Operation. It was approved on behalf of Standards Australia's Standards Development and Accreditation Committee on 11 June 2025.

This Standard was published on 27 June 2025.

The following are represented on Committee EL-052:

Communications, Electrical and Plumbing Union - Electrical Division
Department of Primary Industries and Regional Development
Electric Energy Society of Australia
Electrical Regulatory Authorities Council, Australia
Energy Networks Australia
Engineers Australia
National Electrical and Communications Association

This Standard was issued for comment as DR AS 5804.1:2024

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals and new products by visiting:

www.standards.org.au

ISBN: 978 1 76175 254 4

Australian Standard[®]

High-voltage live work

Part 1: General

Originated as AS 5804.1—2010.
Second edition AS 5804.1:2025.

How to read this Standard

This page explains the meaning of the language and structure of this Standard.

Refer to Standards Australia's [Standardisation Guide 006](#) for more details about drafting rules.

Australian and Australian/New Zealand Standards are voluntary unless they are referenced in legislation or called up in contracts.

Requirements

To conform to a Standard, all requirements in the Standard need to be met.

A requirement is any statement in the Standard which uses the word "shall".

Recommendations, permissions and possibilities

The following words are commonly used in Standards, but statements using them do not have to be followed to conform to the Standard:

- (a) "should" means that something is recommended.
- (b) "may" means that something is permitted.
- (c) "can" means that something is possible.

Structure of Standards

A Standard always has the following parts:

- (i) The Preface states who developed the Standard, what the Standard is aiming to do, and how it relates to other documents.
- (ii) The Scope states what the Standard is about, what it covers and what it does not cover.
- (iii) The Normative references clause lists other documents that are referenced in the Standard as part of requirements.
- (iv) The Terms and definitions clause defines important terms to help with understanding the Standard.

A Standard may also include other parts, such as the following:

- (1) A normative appendix sets additional requirements that need to be conformed to.
- (2) An informative appendix provides additional information or guidance. An informative appendix provides additional information or guidance. They usually do not contain requirements. If an informative appendix does contain requirements, the Standard will specify when those requirements apply.
- (3) A Bibliography lists documents referenced in the Standard but not as part of requirements.

Many Standards include notes. Notes provide recommendations and/or guidance only. They never contain requirements.

Preface

This Standard was prepared by the Australian members of the joint Standards Australia/Standards New Zealand Committee EL-052, Electrical Energy Networks, Construction and Operation, to supersede AS 5804.1:2010, *High-voltage live working, Part 1: General*.

After consultation with stakeholders in both countries, Standards Australia and Standards New Zealand decided to continue to develop this document as an Australian Standard rather than an Australian/New Zealand Standard.

The objective of this document is to establish the minimum requirements for high-voltage live stick work to safeguard live workers and the public and to align live work requirements with current industry practices and advancements in technology.

This document forms part of the AS 5804 series on high voltage live work. A list of all parts in this series can be found in the Standards Australia online catalogue.

It is intended that this document be read in conjunction with AS 5804.2, AS 5804.3 and AS 5804.4.

The major changes in this edition are as follows:

- (a) Significant update of the live work equipment management requirements including the electrical and mechanical testing requirements for in-service live work equipment.
- (b) Alignment with ENA DOC 049 and ENA DOC 050 which reflect current industry best practice for the testing and maintenance of live work equipment.
- (c) Consolidation of the periodic electrical testing intervals and reference Standards previously specified in the AS 5804 series into [Table 12.14.3](#) of this document.

The inclusion of roles and responsibilities in AS 5804.1 was approved by Standards Australia's Production Management Group on 18/04/2024.

The terms “normative” and “informative” are used in Standards to define the application of the appendices to which they apply. A “normative” appendix is an integral part of a Standard, whereas an “informative” appendix is only for information and guidance.

Contents

Page

Preface	v
Introduction	x
1 Scope and general	1
1.1 Scope	1
1.2 Application	1
1.3 Normative references	2
1.4 Terms and definitions	2
1.5 Responsibilities	3
1.5.1 General	3
1.5.2 Network operator and service provider	9
1.5.3 On-site controller	10
1.5.4 Safety observer	10
1.5.5 Team members	11
2 Live work methods	11
2.1 General	11
2.2 Glove and barrier method	11
2.3 Stick work method	11
2.4 Barehand method	11
3 Risk assessment	11
3.1 General	11
3.2 Pre-job hazard and risk assessment	12
3.3 Known hazards	13
4 Live work personnel	13
4.1 Selection criteria	13
4.2 Medical assessment	13
4.2.1 General	13
4.2.2 Initial medical assessment	13
4.2.3 Ongoing regular medical assessment	13
4.3 Workplace health issues	14
4.4 Initial training and competency assessment	14
4.4.1 Training and assessment	14
4.4.2 Competency assessment	14
4.4.3 Refresher training	15
4.5 People working with a live work team	15
5 Work documentation	15
5.1 General	15
5.2 Procedure and techniques	15
5.3 Documentation	15
5.3.1 General	15
5.3.2 Live work manual	16
5.3.3 Live work permit	16
5.3.4 Approved work documentation	17
5.3.5 Minor changes to work procedure on-site	17
5.4 Records	17
6 Safe working principles	17
6.1 General	17
6.2 Work on adjacent structures and spans	17
6.3 Combination live work and access authority work	17
6.4 Integrity of insulation	18
6.5 Inspection of insulators	18
6.6 Restraint of free ends of harness straps, pole straps and ropes	18
6.7 Worksite electrical apparatus assessment	18
6.8 Safety observers	18

6.8.1	Safety observer	18
6.8.2	Team members	19
6.9	Work team communications	19
6.9.1	Communication with the system controller	19
6.9.2	Communication between work team members	19
6.10	Weather conditions	19
6.11	Traffic management	20
6.12	Step and touch potential	20
6.13	Protective devices	20
6.13.1	Operation of protective devices	20
6.13.2	Disabling of auto-reclose function	20
6.13.3	A manual reclose or other planned switching of a circuit	20
6.14	Plant earthing	21
6.15	Public safety	21
6.16	Personal protection	21
6.16.1	Wearing metallic objects	21
6.16.2	Hair length	21
6.16.3	Personal protective equipment	21
6.17	Procedures in the event of an incident/accident	21
6.17.1	Events constituting an incident or accident	21
6.17.2	Procedures for responding to live work incidents or accidents	22
6.18	Post-job assessment	22
6.19	Safe working principles for substations	22
7	Insulation and voltage	22
7.1	General	22
7.2	Insulating materials	23
7.3	High-voltage insulators	23
7.3.1	General	23
7.3.2	Handling of insulators exhibiting physical damage or electrical distress	23
7.3.3	Minimum number of electrically sound disc insulators	23
7.3.4	Testing of insulator strings	24
7.3.5	Minimum number of electrically sound discs not available	25
7.3.6	Capacitive charge on disc insulators	25
7.4	Porcelain disc insulators	25
7.5	Glass disc insulators	26
7.6	Non-ceramic insulators	26
7.6.1	General	26
7.6.2	Installation of new insulators	26
7.6.3	Handling of non-ceramic insulators	26
7.6.4	Assessment of non-ceramic insulators	26
7.7	Potential abnormal voltage conditions	26
7.7.1	General	26
7.7.2	Ferro-resonance	26
7.7.3	Ferranti effect	27
7.7.4	Lightning and backflash	27
7.7.5	Resonant earth system	28
7.7.6	Neutral earth resistor and neutral earth reactor	28
8	Current and conductors	28
8.1	General	28
8.2	Elevated conductor temperature	28
8.3	Current and switching	29
8.4	Conductors and controlled movement	29
9	Electromagnetic fields	30
9.1	General	30
9.2	Electric fields	30
9.3	Magnetic fields	30
9.4	Electromagnetic field management	30

10	Minimum approach distance	30
10.1	General	30
10.2	Insulation based on air	31
10.3	Minimum approach distance based on air	31
	10.3.1 Calculation	31
	10.3.2 Electrical factor	32
	10.3.3 Ergonomic distance	32
10.4	Recommended minimum approach distance	32
10.5	Conditions applicable to Tables 10.4(A) and 10.4(B)	34
10.6	Decreasing the minimum approach distance	35
10.7	Increasing the minimum approach distance	36
	10.7.1 Ergonomic distance	36
	10.7.2 Individual factors related to the live worker	36
	10.7.3 Environmental factors	36
10.8	Minimum approach distances for mobile plant	36
	10.8.1 General	36
	10.8.2 Variations to minimum approach distances	38
11	Equipment	39
11.1	General	39
11.2	Electrical rating of insulating equipment	40
11.3	Contamination	40
11.4	Insulation maintenance	40
11.5	Electrical properties of tools and equipment	40
	11.5.1 Categories of insulating materials	40
	11.5.2 Current associated with personal protective or cover-up tools and equipment ..	41
	11.5.3 Current associated with support, lift, or reach extending tools and equipment ..	41
	11.5.4 Maximum permissible current	41
11.6	Live work sticks	41
11.7	Gloves and sleeves	41
11.8	Insulating barriers	42
	11.8.1 General	42
	11.8.2 Types of insulating barriers	42
11.9	Conductor support equipment	42
11.10	Rope	42
	11.10.1 Properties of rope for live work	42
	11.10.2 Types of rope for use	42
11.11	Elevating work platforms	43
	11.11.1 Use of elevating work platforms	43
	11.11.2 Supporting energized components	43
	11.11.3 Uninsulated parts of the elevating work platforms	44
	11.11.4 Earthing and bonding of the chassis of the elevating work platforms	44
	11.11.5 Elevating work platforms for live high-voltage work	44
11.12	Crane operations	45
	11.12.1 General	45
	11.12.2 Instruction of crane operators	45
	11.12.3 Supervision of crane operators	45
	11.12.4 Supporting energized components	45
	11.12.5 Uninsulated parts of the crane	45
	11.12.6 Earthing and bonding of the chassis of the crane	45
	11.12.7 Operation of multiple plant items on the same site	45
11.13	Insulating positioning towers	45
11.14	Personal protective equipment	45
	11.14.1 General principles	45
	11.14.2 Safety footwear	46
	11.14.3 Eye and face protection	46
	11.14.4 Head protection	46
	11.14.5 Protective clothing	46
	11.14.6 Additional outer clothing	47

	11.14.7 Specific live work equipment	47
12	Care and maintenance of equipment	47
	12.1 General	47
	12.2 Equipment management system	48
	12.2.1 General	48
	12.2.2 Leaving of live insulating equipment on energized electrical apparatus	48
	12.3 Inspection	48
	12.3.1 General	48
	12.3.2 Frequency of inspection	49
	12.4 Cleaning	49
	12.5 Storage and transport	49
	12.6 Care and maintenance of live work sticks	50
	12.7 Care and maintenance of gloves and sleeves	50
	12.8 Care and maintenance of barriers	50
	12.9 Care and maintenance of conductor support equipment	50
	12.10 Rope for live work	50
	12.10.1 Insulating rope	50
	12.10.2 Storage and handling	51
	12.10.3 Live work rope	51
	12.10.4 Rescue rope	52
	12.11 Care and maintenance of elevating work platforms	52
	12.11.1 General	52
	12.11.2 Electrical	52
	12.11.3 Mechanical	52
	12.12 Care and maintenance of cranes and crane insulation	53
	12.13 Care and maintenance of PPE	53
	12.14 Testing	53
	12.14.1 Electrical testing	53
	12.14.2 Testing in the field	53
	12.14.3 Periodic electrical testing intervals and standards	54
	12.14.4 Mechanical testing	55
	12.14.5 Identification and marking of safe working load	55
13	Auditing	56
	13.1 General	56
	13.2 Basic principles	56
	13.3 Audit frequencies and scope	56
	13.4 Live work auditor	57
	13.4.1 General	57
	13.4.2 Selection	57
	13.5 Audit process	57
	13.6 Management of non-conformance	57
	13.7 Reporting of audit results	58
14	Use of helicopters	58
	14.1 General	58
	14.2 High-voltage live work principles	58
	Appendix A (normative) Minimum approach distance — Altitude correction factor	59
	Appendix B (informative) Site audit recommendations	60
	Appendix C (informative) Audit check sheets — minimum content	61
	Appendix D (informative) Minimum approach distance example calculations	64
	Appendix E (informative) Electrical approach distances for helicopter live work	67
	Bibliography	70

Introduction

This document has its origins in the former Electricity Supply Association of Australia (ESAA) documents:

- (a) HB ESAA LLM 01—2000, Guidelines for live line barehand work.
- (b) HB ESAA LLM 02—2000, Guidelines for live line stick work.
- (c) HB ESAA LLM 03—2000, Guidelines for live line glove and barrier work.
- (d) ESAA ND/NL 04—1995, Guidelines for use of helicopters for live line work.

All but ESAA ND/NL 04—1995 were later published as Energy Networks Association (ENA) documents but have now been withdrawn.

This document does not constitute a high-voltage live work manual or set down high-voltage live work procedures and techniques. All procedures and techniques are developed by the network operator and service provider in accordance with this document.