

Australian Standard™

Standard voltages

[Modified and including the full text of IEC 60038:1983]



Standards Australia

This Australian Standard was prepared by Committee EL/40, Standard Voltages, Current Ratings and Frequencies. It was approved on behalf of the Council of Standards Australia on 17 December 1999 and published on 23 February 2000.

The following interests are represented on Committee EL/40:

Australian Electrical and Electronic Manufacturers Association
Consumer Electronics Suppliers Association
Electricity Supply Association of Australia
Institution of Engineers, Australia
Ministry of Commerce, New Zealand

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Australia web site at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Australian Standard*, has a full listing of revisions and amendments published each month.

We also welcome suggestions for the improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.com.au, or write to the Chief Executive, Standards Australia International Ltd, PO Box 1055, Strathfield, NSW 2135.

Australian Standard™

Standard voltages

Originated as S.C. 10—1926.
Final edition AS 1926—1987.
Revised and redesignated AS 60038—2000.

COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd
PO Box 1055, Strathfield, NSW 2135, Australia

ISBN 0 7337 3275 5

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL/40, Standard Voltages, Current Ratings and Frequencies, to supersede AS 2926—1987, *Standard voltages—Alternating (50 Hz) and direct*.

This Standard is the result of a consensus among representatives on the Joint Committee to produce it as an Australian Standard.

This Standard is based on and contains the full text of, but is not equivalent to, IEC 60038:1983, *IEC standard voltages*, incorporating its Amendment 1:1994 and Amendment 2:1997.

Variations to IEC 60038:1983, as amended, are indicated at the appropriate places throughout this Standard. Strikethrough (*example*) identifies IEC tables and passages of text which, for the purposes of this Australian Standard, are deleted. Where Australian tables or passages of text are added, each is set in its proper place and identified by shading (*example*). A summary of these variations is given in Appendix ZZ.

In January 1997, the IEC commenced numbering its Standards from 60000 by adding 60000 to the number of each existing Standard. This coordinates IEC numbering with ISO numbering. During the transition period an IEC Standard might be identified by its new number or its old number (for example, IEC 60050 or IEC 50).

The term ‘normative’ has been used in this Standard to define the application of the appendix to which it applies. A ‘normative’ appendix is an integral part of a Standard.

As this Standard is reproduced from an International Standard, the following applies:

- (a) The AS number is shown only on the cover and title page.
- (b) In the source text, ‘this publication’ should read ‘this Australian Standard’.

References to International Standards should be replaced by equivalent Australian or Australian/New Zealand Standards, as follows:

<i>Reference to International Standard</i>		<i>Australian or Australian/New Zealand Standard</i>	
IEC		AS	
60071	Insulation co-ordination	1824	Insulation co-ordination
60071-1	Part 1: Definitions, principles and rules	1824.1	Part 1: Definitions, principles, and rules
		AS/NZS	
60335	Safety of household and similar electrical appliances	3350	Safety of household and similar electrical appliances
60335-1	Part 1: General requirements	3350.1	Part 1: General requirements

The following Australian/New Zealand Standard is referenced in this document.

AS/NZS

3000 Electrical installations (known as the Australian/New Zealand Wiring Rules)

CONTENTS

	<i>Page</i>
Scope	1
SECTION ONE - DEFINITIONS	
1 Nominal system voltage.....	1
2 Highest and lowest voltages of a system (excluding transient or abnormal conditions) ..	1
3 Supply terminals Point of supply.....	2
4 Supply voltage.....	2
5 Supply voltage range	2
6 Utilization voltage	2
7 Utilization voltage range	2
8 Rated voltage (of equipment)	2
9 Highest voltage for equipment.....	2
SECTION TWO - TABLES OF STANDARD VOLTAGES	
Table I.....	3
Table II.....	4
Table III.....	5
Table IIIA.....	5
Table IV.....	6
Table V.....	6
Table VI.....	7
Appendix ZZ Variation to IEC 60038:1983, Amendment 1:1994 and Amendment 2:1997 for application in Australia	8

Currently in preview, click buy full version.

STANDARDS AUSTRALIA

Australian Standard
Standard Voltages

Any IEC table, figure or passage of text that is struck-through is not part of this Standard. Any Australian table, figure or passage of text that is added (and identified by shading) is part of this Standard.

Scope

This publication applies to:

- a.c. transmission, distribution and utilization systems and equipment for use in such systems with standard frequencies 50 Hz and ~~60 Hz~~ having a nominal voltage above 100 V;
- a.c. and d.c. traction systems;
- a.c. and d.c. equipment having rated voltages below 120 V a.c. or below 750 V d.c., the a.c. voltages being intended (but not exclusively) for ~~50 Hz and 60 Hz~~ applications; such equipment covers batteries (from primary or secondary cells), other power supply devices (a.c. or d.c.), electrical equipment (including industrial and communication), and appliances.

This publication shall not apply to voltages representing or transmitting signals or measured values.

This publication shall not apply to standard voltages of components and parts used within electrical devices or items of equipment.

SECTION ONE—DEFINITIONS

For alternating voltages, the voltages stated below are r.m.s. values.

1 Nominal system voltage

Voltage by which a system is designated.

2 Highest and lowest voltages of a system (excluding transient or abnormal conditions)**2.1 Highest voltage of a system**

The highest value of voltage which occurs under normal operating conditions at any time and at any point on the system.

It excludes voltage transients, such as those due to system switching, and temporary voltage variations.