

Australian Standard[®]

Instrument transformers

**Part 1: Current transformers
(IEC 60044-1 Ed.1.2 (2003) MOD)**



This Australian Standard® was prepared by Committee EL-013, Measurement and protection transformers. It was approved on behalf of the Council of Standards Australia on 17 January 2007.

This Standard was published on 20 February 2007.

The following are represented on Committee EL-013:

- Australian Electrical and Electronic Manufacturers Association
 - Cigre APA2
 - Energy Networks Association
 - National Measurement Institute
 - University of South Australia
-

This Standard was issued in draft form for comment as D. 06516.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

Instrument transformers

**Part 1: Current transformers
(IEC 60044-1 Ed. 1.2 (2003) MOD)**

Originally was part of AS C45—1928.
Previous edition AS 60044.1—2003.
Second edition 2007.
Reissued incorporating Amendment No. 1 (January 2012).

COPYRIGHT

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

Published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 0 7337 8025 3

PREFACE

This Standard was prepared by the Standards Australia Committee EL-013, Measurement and protection transformers to supersede AS 60044.1—2003.

This Standard incorporates Amendment No. 1 (January 2012). The changes required by the Amendment are indicated in the text by a marginal bar and amendment number against the clause, note, table, figure or part thereof affected.

The objective of this Standard is to provide users and manufacturers of current transformers with definitions of terms, safety requirements, methods of specifying performance and methods of test.

This Standard is Part One of a series covering instrument transformers. The series consists of the following Standards:

AS

60044 Instrument transformers

60044.1 Part 1: Current transformers (this Standard)

60044.2 Part 2: Single-phase inductive voltage transformers

This Standard is an adoption with national modifications and has been reproduced from IEC 60044-1, Ed.1.2 (2003), *Instrument transformers – Part 1: Current transformers*, (including Amendment 1: 2000 and Amendment 2:2002), and has been varied as indicated to take account of Australian conditions.

Variations to IEC 60044-1, Ed.1.2 (2003) are indicated at the appropriate places throughout this standard. Strikethrough (*example*) identifies IEC text, tables and figures which, for the purposes of this Australian Standard, are deleted. Where text, tables or figures are added, each is set in its proper place and identified by shading (*example*). Added figures are not themselves shaded, but are identified by a shaded border.

As this Standard is reproduced from an international Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text ‘this part of IEC 60044’ should read ‘this part of AS 60044’.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

The terms ‘normative’ and ‘informative’ are used to define the application of the annex to which they apply. A normative annex is an integral part of a standard, whereas an informative annex is only for information and guidance.

Attention is drawn to the following differences between this Standard and AS 1675—1986 which is now obsolescent.

- (a) This Standard has a new thermal class for windings in oil and hermetically sealed that allows 65 K temperature rise. See Table 2, Limits of temperature rise of the windings.
- (b) This Standard has highest voltages for equipment of 170 kV and 245 kV in place of 245 kV in AS 1675—1986. See Table 3, Rated insulation levels for transformer primary windings.
- (c) This Standard introduces reduced levels of permissible partial discharges across the complete range of system earthing types and voltages, with increases in prestress voltage level (from the current 1.3 times the nominal voltage of the system U_m level to the induced voltage withstand test level) and in testing voltage level (from 1.1 U_m to 1.3 U_m). See Clause 5.1.2.2, Partial discharges and Clause 8.2.2.2, Partial discharge test procedure.

- (d) This Standard allows a maximum permissible voltage across secondary winding of up to 4.5 kV or for current transformers having a rated knee point e.m.f. greater than 450 V, 10 times the rated knee point voltage up to a limit of 10 kV. See Clause 5.1.5, Inter-turn insulation requirements.
- (e) This Standard introduces requirements for minimum insulator creepage distance and arcing/creepage ratio for various pollution levels. See Clause 5.1.6, Requirements for the external insulation.
- (f) This Standard requires repeated dielectric testing to be performed at 80% of the initial power frequency voltage (and not 75% as in AS 1675—1986). See Clause 6.2, Routine tests.
- (g) This Standard covers measurement of dielectric dissipation factor as a special test and not as a routine test as does AS 1675—1986. See Clause 6.3, Special tests.
- (h) This Standard tests radio interference voltage with a prestress voltage of $1.5 U_m/\sqrt{3}$ and a limit of 300 pC or 2500 μ V at $1.1 U_m/\sqrt{3}$. This test is also required for voltage 110 kV and upwards (and not from 245 kV as in AS 1675—1986). See Clause 7.5, Radio interference voltage measurement.
- (i) This Standard includes requirements for measurement of partial discharges different to those in AS 1675—1986 (which calls up AS 2532 which has been withdrawn). See Clause 8.2.2, Partial discharge measurement.
- (j) This Standard introduces new special tests of chopped impulse on primary winding and mechanical testing of primary terminals. See Clause 6.5, Special tests.
- (k) Special Metering Classes are introduced in this Standard as classes 0.2S and 0.5S, with a current range from 1-120% (that can be extended to 150% and 200%). AS 1675—1986 has classes 0.1ME, 0.2ME and 0.5ME for secondary currents 1 A and 5 A, but the current range is 2.5-125/150/200%. See Clause 11.2, Limits of current error and phase displacement for measuring current transformers.
- (l) This Standard allows a higher error margin for errors measured at 5% and 20% of rated current than does AS 1675—1986. The better accuracy can be achieved by selecting a different class for such needs. See Clause 11.2, Limits of current error and phase displacement for measuring current transformers.
- (m) This Standard requires a maximum current of 120% for accuracy testing of metering CTs instead of the 125% required in AS 1675—1986. See Clause 11.2, Limits of current error and phase displacement for measuring current transformers.
- (n) This Standard allows protection classes 5P and 10P to have current errors at rated current of 1% and 3% respectively. See Clause 12.3, Limits of errors for protective current transformers.
- (o) Tests for accuracy are done at 1.0 power factor in AS 1675—1986. This Standard requires tests for accuracy to be done at 0.8 power factor or at 1.0 power factor with the results converted to equivalent results at 0.8 power factor. See Clause 12.3, Limits of errors for protective current transformers.
- (p) AS 1675—1986 covered class PS which is not covered in this Standard. However, class PR (air gaps) of this Standard deals with requirements of this type. See Clause 13, Additional requirements for class PR protective current transformers.
- (q) This Standard includes a class PX which covers all requirements of class PL in AS 1675—1986. See Clause 14, Additional requirements for class PX protective current transformers.
- (r) This Standard does not have requirements for thermal stability testing.
- (s) This Standard has no requirements for variation of error margins during accuracy testing of metering cores.

- (t) This Standard introduces a test of transmitted overvoltage as a special test. See Clause 6.3, Special tests.

Currently in preview, click buy full version

CONTENTS

	<i>Page</i>
1 General.....	1
1.1 Scope.....	1
1.2 Normative references	2
2 Definitions.....	3
2.1 General definitions	3
2.2 Additional definitions for measuring current transformers.....	7
2.3 Additional definitions for protective current transformers.....	7
3 Normal and special service conditions.....	9
3.1 Normal service conditions.....	9
3.2 Special service conditions.....	10
3.3 System earthing	11
4 Ratings	11
4.1 Standard values of rated primary currents	11
4.2 Standard values of rated secondary currents.....	11
4.3 Rated continuous thermal current.....	11
4.4 Standard values of rated output	12
4.5 Short-time current ratings	12
4.6 Limits of temperature rise	12
5 Design requirements.....	13
5.1 Insulation requirements	13
5.2 Mechanical requirements	18
6 Classification of tests.....	19
6.1 Type tests	19
6.2 Routine tests	19
6.3 Special tests.....	20
7 Type tests	20
7.1 Short-time current tests.....	20
7.2 Temperature-rise test	21
7.3 Impulse tests on primary winding	21
7.4 Wet test for outdoor type transformers	22
7.5 Radio interference voltage measurement	22
8 Routine tests.....	23
8.1 Verification of terminal markings	23
8.2 Power-frequency withstand tests on primary windings and partial discharge measurement	24
8.3 Power-frequency withstand tests between sections of primary and secondary windings and on secondary windings.....	25
8.4 Inter-turn overvoltage test.....	25
9 Special tests	25
9.1 Chopped impulse test on primary winding	25
9.2 Measurement of capacitance and dielectric dissipation factor	26
9.3 Mechanical tests.....	26
9.4 Transmitted overvoltages measurement	27
10 Markings	28
10.1 Terminal markings – General rules.....	28
10.2 Rating plate markings	29

11	Additional requirements for measuring current transformers	30
11.1	Accuracy class designation for measuring current transformers	30
11.2	Limits of current error and phase displacement for measuring current transformers	30
11.3	Extended current ratings	32
11.4	Type tests for accuracy of measuring current transformers	32
11.5	Routine tests for accuracy of measuring current transformers	32
11.6	Instrument security factor	32
11.7	Marking of the rating plate of a measuring current transformer	33
12	Additional requirements for protective current transformers	33
12.1	Standard accuracy limit factors	33
12.2	Accuracy classes for protective current transformer	33
12.3	Limits of errors for protective current transformers	33
12.4	Type and routine tests for current error and phase displacement of protective current transformers	34
12.5	Type tests for composite error	34
12.6	Routine tests for composite error	34
12.7	Marking of the rating plate of a protective current transformer	35
13	Additional requirements for class PR protective current transformers	35
13.1	Standard accuracy limit factors	35
13.2	Accuracy classes for class PR protective current transformers	35
13.3	Limits of error for class PR protective current transformers	35
13.4	Type and routine tests for current error and phase displacement of class PR protective current transformers	36
13.5	Marking of rating plate of class PR current transformers	36
13.5.1	Principal marking	36
13.5.2	Special marking (when required):	36
14	Additional requirements for class PX protective current transformers	37
14.1	Specification of performance for class PX protective current transformers	37
14.2	Insulation requirements for class PX protective current transformers	37
14.3	Type tests for class PX protective current transformers	37
14.4	Routine tests for class PX protective current transformers	38
14.5	Marking of rating plate of class PX current transformers	38
	Annex A (normative) Protective current transformers	45
	Annex B (informative) Multiple chopped impulse test	49
	Annex ZA (normative) Calibration of a CT at a 0.8 power-factor lagging burden	50
	Figure 1 – Amplitude correction factors	39
	Figure 2 – Test circuit for partial discharge measurement	40
	Figure 3 – Alternative test circuit for partial discharge measurement	40
	Figure 4 – Example of balanced test circuit for partial discharge measurement	41
	Figure 5 – Example of calibration circuit for partial discharge measurement	41
	Figure 6 – Measuring circuit	42
	Figure 7 – Transmitted Overvoltages measurement: Test Circuit and GIS Test set-up	42
	Figure 8 – Transmitted Overvoltages measurement: General Test set-up	43
	Figure 9 – Transmitted Overvoltages measurement: Test Waveforms	44
	Figures A.1 to A.6	48
	Table 1 – Temperature categories	9

Table 2 – Limits of temperature rise of the windings	13
Table 3 – Rated insulation levels for transformer primary windings having highest voltage for equipment $U_m < 300$ kV.....	14
Table 4 – Rated insulation levels for transformer primary windings having highest voltage for equipment $U_m \geq 300$ kV.....	15
Table 5 – Power frequency withstand voltages for transformer primary windings having highest voltage for equipment $U_m \geq 300$ kV.....	15
Table 6 – Partial discharge test voltages and permissible levels	16
Table 7 – Creepage distances.....	17
Table 8 – Static withstand test loads	18
Table 9 – Modalities of application of test loads to be applied to the primary terminals	27
Table 10 – Markings of terminals.....	29
Table 11 – Limits of current error and phase displacement for measuring current transformers (classes from 0.1 to 1).....	31
Table 12 – Limits of current error and phase displacement for measuring current transformers for special application.....	31
Table 13 – Limits of current error for measuring current transformers (classes 3 and 5).....	32
Table 14 – Limits of error for protective current transformers	34
Table 15 – Limits of error for class PR protective current transformers.....	36
Table 16 – Transmitted overvoltage limits.....	18

Currently in preview, click buy full version

STANDARDS AUSTRALIA

Australian Standard**Instrument transformers
Part 1: Current transformers
(IEC 60044-1 Ed.1.2 (2003)MOD)**

Any table, figure or text of the international standard that is struck through is not part of this standard. Any Australian table, figure or text that is added is part of this standard and is identified by shading.

1 General**1.1 Scope**

This part of IEC 60044 applies to newly manufactured current transformers for use with electrical measuring instruments and electrical protective devices at frequencies from 15 Hz to 100 Hz.

Although the requirements relate basically to transformers with separate windings, they are also applicable, where appropriate, to autotransformers.

Clause 11 covers the requirements and tests, in addition to those in clauses 3 to 10, that are necessary for current transformers for use with electrical measuring instruments.

Clause 12 covers the requirements and tests, in addition to those in clauses 3 to 10, that are necessary for current transformers for use with electrical protective relays, and in particular for forms of protection in which the prime requirement is the maintenance of accuracy up to several times the rated current.

For certain protective systems, where the current transformer characteristics are dependant on the overall design of the protective equipment (for example high-speed balanced systems and earth-fault protection in resonant earthed networks), additional requirements are given in clause 13 for class PR transformers and in clause 14 for class PX transformers.

Clause 13 covers the requirements and tests in addition to those in clauses 3 to 10 that are necessary for current transformers for use with electrical protective relays, and in particular for forms of protection in which the prime requirement is the absence of remanent flux.

Clause 14 covers the requirements and tests in addition to those in clauses 3 to 10 that are necessary for current transformers for use with electrical protective relays, and in particular for forms of protection for which knowledge of the transformer's secondary excitation characteristic, secondary winding resistance, secondary burden resistance and turns ratio is sufficient to assess its performance in relation to the protective relay system with which it is to be used.

Current transformers intended for both measurement and protection shall comply with all the clauses of this standard.