

Australian Standard™

Instrument transformers

Part 3: Combined transformers

This Australian Standard was prepared by Committee EL-013, Measurement and Protection Transformers. It was approved on behalf of the Council of Standards Australia on 25 November 2003 and published on 30 January 2004.

The following are represented on Committee EL-013:

Australian Electrical and Electronic Manufacturers Association
Cigre AP12
CSIRO Telecommunications and Industrial Physics
Electricity Supply Association of Australia
University of South Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

Australian Standard™

Instrument transformers

Part 3: Combined transformers

First published as AS 60044.3—2004.

COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 5658 1

PREFACE

This Standard was prepared by the Standards Australia Committee EL-013, Measurement and Protection Transformers.

The objective of this Standard is to provide users and manufacturers of combined transformers with definitions of terms, safety requirements, methods of specifying performance and methods of test.

This Standard is Part Three of a series covering instrument transformers. The series consists of the following Standards:

AS

- 60044 Instrument transformers
- 60044.1 Part 1: Current transformers
- 60044.2 Part 2: Single-phase conductive voltage transformers
- 60044.3 Part 3: Combined transformers (this Standard)
- 60044.5 Part 5: Capacitor voltage transformers

This Standard is identical with, and has been reproduced from IEC 60044-3:2002, *Instrument transformers – Part 3: Combined transformers*.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text ‘this international standard’ should read ‘this Australian Standard’.
- (c) A full point should be substituted for a comma when referring to a decimal marker.
- (d) Any French text on figures should be ignored.

The terms ‘normative’ and ‘informative’ are used to define the application of the annex to which they apply. A normative annex is an integral part of a standard, whereas an informative annex is only for information and guidance.

CONTENTS

	<i>Page</i>
1 Scope and object.....	1
2 Definitions.....	1
2.1 Combined instrument transformer.....	1
3 Normal and special service conditions.....	1
4 Ratings.....	1
4.1 General.....	1
4.2 Limits of temperature rise.....	1
5 Design requirements.....	2
5.1 General.....	2
5.2 Transmitted overvoltages.....	2
6 Tests.....	2
6.1 Classification of tests.....	2
6.2 Type tests.....	3
6.3 Routine tests.....	3
6.4 Special tests.....	4
7 Type tests.....	4
7.1 General.....	4
7.2 Temperature-rise test.....	4
7.3 Impulse tests on primary windings.....	5
8 Routine tests.....	5
8.1 General.....	5
8.2 Power-frequency withstand test on the primary winding.....	5
9 Special tests.....	5
9.1 General.....	5
9.2 Measurement of capacitance and dielectric dissipation factor.....	5
9.3 Transmitted overvoltage measurement.....	5
10 Marking.....	6
10.1 Rating plate marking.....	6
10.2 Terminal marking.....	6
11 Additional requirements for measuring and protective combined transformer.....	6
11.1 General.....	6
11.2 Mutual influence.....	7
11.2 Type test for accuracy of measuring and protective combined transformer.....	7
11.3.1 General.....	7
11.3.2 Influence of the current transformer on the voltage transformer.....	7
11.3.3 Influence of the voltage transformer on the current transformer.....	8
11.4 Routine accuracy tests for measuring and protective combined transformers.....	9
Annex A (informative) The mutual influence of current and voltage transformers.....	13

Figures

Figure 1 – Geometrical construction of the circuit	10
Figure 2 – Measurement 2	10
Figure 3 – Measurement 3	10
Figure 4 – Error diagram of a voltage transformer class	11
Figure 5 – Error diagram of a current transformer class 0,2 at 5 % of rated current.....	11
Figure 6 – Transmitted overvoltage measurements	12
Figure 7 – Waveshape of the input voltage	12
Figure A.1 – Current conductor and magnetic field influencing a voltage transformer.....	14

STANDARDS AUSTRALIA

Australian Standard**Instrument transformers
Part 3: Combined transformers****1 Scope and object**

This part of IEC 60044 AS 60044 applies to newly manufactured combined transformers for use with electrical measuring instruments and electrical protective devices at frequencies from 15 Hz to 100 Hz.

The requirements and tests of this standard, in addition to the requirements and tests of IEC 60044-1 AS 60044.1, IEC 60044-2 AS 60044.2 and IEC 60044-5 AS 60044.5, cover current, voltage and capacitor voltage transformers, that are necessary for combined instrument transformers.

2 Definitions

For the purposes of this part of IEC 60044 AS 60044, the definitions given in IEC 60044-1 AS 60044.1 and IEC 60044-2 AS 60044.2 and the following definition apply.

2.1 Combined instrument transformer

Instrument transformer consisting of a current and a voltage transformer in the same case

3 Normal and special service conditions

For the purposes of this part of IEC 60044 AS 60044, Clause 3 of IEC 60044-1 AS 60044.1 and Clause 4 of IEC 60044-2 AS 60044.2 apply to current and voltage transformers respectively.

4 Ratings**4.1 General**

For the purposes of this part of IEC 60044 AS 60044, in addition to Clause 4 of IEC 60044-1 AS 60044.1 and Clause 5 of IEC 60044-2 AS 60044.2, the following subclause applies.

4.2 Limits of temperature rise

The temperature rise of a combined instrument transformer shall not exceed the appropriate values of 6.6 of IEC 60044-1 AS 60044.1 and of 5.4 of IEC 60044-2 AS 60044.2 respectively, if a voltage as indicated in IEC 60044-2 AS 60044.2, 5.4, is applied to it and the current transformer is carrying a primary current equal to the rated continuous thermal current. The current transformer is connected to a unity power factor burden corresponding to the rated output and with the voltage transformer being loaded at rated burden, or at the highest rated burden if there are several rated burdens, and at a power factor between 0,8 lagging and unity. The additional tolerance of 10 K proposed in some cases for the voltage transformers is also applicable for the current transformers of the combined instrument transformers.