

Australian Standard™

**Power transformers**

**Part 11: Dry-type transformers**

**STANDARDS**  
Australia



This Australian Standard was prepared by Committee EL-008, Power Transformers. It was approved on behalf of the Council of Standards Australia on 15 December 2005.  
This Standard was published on 25 January 2006.

---

The following are represented on Committee EL-008:

Australasian Railway Association  
Australian Chamber of Commerce and Industry  
Australian Electrical and Electronic Manufacturers Association  
Australian Greenhouse Office, Department of Environment and Heritage  
Australian Institute of Petroleum  
Energy Networks Association  
Engineers Australia  
Testing Interests (Australia)

---

#### **Keeping Standards up-to-date**

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at [www.standards.com.au](http://www.standards.com.au) and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at [mail@standards.org.au](mailto:mail@standards.org.au), or write to the Chief Executive, Standards Australia, GPO Box 476, Sydney, NSW 2001.

---

*This Standard was issued in draft form for comment as DR 05400.*

Australian Standard™

**Power transformers**

**Part 11: Dry-type transformers**

Original as AS 2735—1984.  
Revised and redesignated AS 60076.11—2006.

**COPYRIGHT**

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia

ISBN 0 7337 7099 1

## PREFACE

This Standard was prepared by the Standards Australia Committee EL-008, Power Transformers to supersede AS 2735—1984 on publication.

The objective of this Standard is to provide designers, manufacturers, test laboratories, purchasers and users with requirements for general purpose dry-type transformers. These requirements cover dry-type transformers with at least one winding operating at a voltage of at least 1.1 kV and no winding operating at a voltage greater than 36 kV.

This Standard is identical with, and has been reproduced from IEC 60076-11, Ed.1.0 (2004), *Power transformers Part 11: Dry-type transformers*.

The AS 60076 series, *Power transformers* consists of the following parts:

AS

60076.1 Part 1: General

60076.4 Part 4: Guide to the lightning impulse and switching impulse testing—Power transformers and reactors

60076.11 Part 11: Dry-type transformers (this Standard)

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text 'IEC 60076-11' should read 'AS 60076.11'.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

The terms 'normative' and 'informative' are used to define the application of the annex to which they apply. A normative annex is an integral part of a standard, whereas an informative annex is only for information and guidance.

## CONTENTS

	<i>Page</i>
1 Scope .....	1
2 Normative references .....	1
3 Terms and definitions .....	2
4 Service conditions .....	3
4.1 General .....	3
4.2 Normal service conditions .....	3
4.3 Electromagnetic compatibility (EMC) .....	3
4.4 Provision for unusual service conditions .....	4
4.5 Transport and storage conditions .....	4
5 Tappings .....	4
6 Connections .....	5
7 Ability to withstand short circuit .....	5
8 Rating .....	5
8.1 General .....	5
8.2 Rated power .....	5
8.3 Preferred values of rated power .....	5
8.4 Operation at higher than rated voltage .....	5
8.5 Operation with fan cooling .....	5
8.6 Operation in an enclosure .....	6
9 Rating plate .....	6
9.1 Rating plate fitted to the transformer .....	6
9.2 Rating plate fitted to the transformer enclosure .....	6
10 Identification according to cooling method .....	7
10.1 Identification symbols .....	7
10.2 Arrangement of symbols .....	7
11 Temperature-rise limits .....	7
11.1 Normal temperature-rise limits .....	7
11.2 Reduced temperature rises for transformers designed for high cooling air temperatures or special air cooling conditions .....	8
11.3 High altitude temperature rise correction .....	8
12 Insulation levels .....	8
12.1 General .....	8
12.2 Transformers for use at high altitudes .....	9
13 Climatic, environmental and fire behaviour classes .....	10
13.1 Climatic classes .....	10
13.2 Environmental classes .....	10
13.3 Fire behaviour classes .....	10
13.4 Test criteria for climatic, environmental and fire behaviour classes .....	10
14 General requirements for tests .....	11
15 Measurement of winding resistance (routine test) .....	11
16 Measurement of voltage ratio and check of phase displacement (routine test) .....	11
17 Measurement of short-circuit impedance and load loss (routine test) .....	11
18 Measurement of no-load loss and current (routine test) .....	12

19	Separate-source AC withstand voltage test (routine test) .....	12
20	Induced AC withstand voltage test (routine test).....	12
21	Lightning impulse test (type test).....	12
22	Partial discharge measurement (routine and special test) .....	13
	22.1 General.....	13
	22.2 Basic measuring circuit (typical only) .....	13
	22.3 Calibration of the measuring circuit.....	13
	22.4 Voltage application .....	14
	22.5 Partial discharge acceptance levels .....	15
23	Temperature-rise test (type test).....	15
	23.1 General.....	15
	23.2 Methods of loading.....	15
	23.3 Winding temperature-rise correction for reduced current.....	18
	23.4 Determination of steady state conditions.....	19
24	Measurement of sound level (special test) .....	19
25	Short-circuit test (special test).....	19
26	Environmental test (special test) .....	19
	26.1 General.....	19
	26.2 Validity of the test .....	19
	26.3 Testing procedure .....	20
27	Climatic test (special test).....	21
	27.1 Thermal shock test (special test).....	21
	27.2 Validity of the test .....	21
	27.3 Thermal shock test for C1 class transformers .....	21
	27.4 Thermal shock test for C2 class transformers .....	23
28	Fire behaviour test (special test) .....	23
	28.1 General.....	23
	28.2 Checking of corrosive and harmful gases emission .....	23
	28.3 Fire behaviour test for F1 class transformer .....	23
	28.4 Quantities to be measured and measuring devices .....	25
	28.5 Calibration of the test chamber without test object .....	25
	28.6 Test method.....	25
	28.7 Test report.....	26
	28.8 Criteria for evaluating the test results.....	26
29	Tolerances .....	27
30	Protection against direct contact .....	27
31	Degrees of protection provided by enclosures.....	27
32	Earthing terminal.....	27
33	Information required with enquiry and order .....	27
	Annex A (informative) Installation and safety of dry-type transformers.....	30

## STANDARDS AUSTRALIA

---

**Australian Standard**
**Power transformers**  
**Part 11: Dry-type transformers**


---

**1 Scope**

This part of IEC 60076 applies to dry-type power transformers (including auto-transformers) having values of highest voltage for equipment up to and including 36 kV and at least one winding operating at greater than 1,1 kV. The standard applies to all construction technologies.

This standard does not apply to:

- gas-filled dry type transformers where the gas is not air;
- single-phase transformers rated at less than 5 kVA;
- polyphase transformers rated at less than 15 kVA;
- instrument transformers (see IEC 60044 and IEC 60187);
- starting transformers;
- testing transformers;
- traction transformers mounted on rolling stock;
- flameproof and mining transformers;
- welding transformers;
- voltage regulating transformers;
- small power transformers in which safety is a special consideration.

Where IEC standards do not exist for the transformers mentioned above or for other special transformers, this standard may be applicable as a whole or in parts.

**2 Normative references**

The following reference documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the reference document (including any amendments) applies.

References to international standards that are struck through in this clause are replaced by references to Australian or Australian/New Zealand Standards that are listed immediately thereafter and identified by shading. Any Australian or Australian/New Zealand Standard that is identical to the International Standard it replaces is identified as such.

IEC 60050 (all parts), *International electrotechnical vocabulary (IEV)*

IEC 60071 (all parts), *Insulation co-ordination*

~~IEC 60076-1:1993, *Power transformers – Part 1: General*~~  
~~Amendment 1 (1999)~~

**AS 60076.1, *Power transformers – Part 1: General***