

Australian Standard™

**High-voltage test techniques—Partial  
discharge measurements**



Standards Australia

This Australian Standard was prepared by Committee EL-007, Power Switchgear. It was approved on behalf of the Council of Standards Australia on 20 August 2001 and published on 28 September 2001.

---

The following interests are represented on Committee EL-007:

Australasian Railway Association  
Australian British Chamber of Commerce  
Australian Electrical and Electronic Manufacturers Association  
Electricity Supply Association of Australia  
Institution of Engineers Australia  
Testing Interests (Australia)  
Transpower New Zealand  
WorkCover New South Wales

---

#### **Keeping Standards up-to-date**

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Australia web site at [www.standards.com.au](http://www.standards.com.au) and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Australian Standard*, has a full listing of revisions and amendments published each month.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at [mail@standards.com.au](mailto:mail@standards.com.au), or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

---

Australian Standard™

**High-voltage test techniques—Partial  
discharge measurements**

Originally issued as AS 1018—1970.  
Previous edition AS 1018—1985.  
Revised and redesignated AS 60270—2001.

**COPYRIGHT**

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd  
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 4109 6

## PREFACE

This Standard was prepared by the Standards Australia Committee EL-007, Power Switchgear to supersede AS 1018—1985.

The objective of this Standard is to define the terms used, relevant quantities to be measured, and to describe test and measuring circuits and procedures for the measurement of partial discharges in electrical equipment.

This Standard is identical with and has been reproduced from IEC 60270:2000, *High-voltage test techniques—Partial discharge measurements*.

This Standard differs from AS 1018—1985 in the following areas:

- (a) Definitions for partial discharge pulses and quantities related to partial discharge pulses, measuring systems and their characteristics and digital partial discharge instrumentation.
- (b) Test circuits and measuring systems.
- (c) Calibration of a measuring system in the complete test circuit and calibration.
- (d) Tests and test procedures.
- (e) Measurement of uncertainty and sensitivity.

A reference to an International Standard identified in the Normative References Clause by strikethrough (~~example~~) is replaced by a reference to the Australian or Australian/New Zealand Standard(s) listed immediately thereafter and identified by shading (**example**). Where the struck-through referenced document and the referenced Australian or Australian/New Zealand Standard are identical, this is indicated in parenthesis after the title of the latter.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text 'this standard' should read 'this Australian Standard'.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the annex to which they apply. A normative annex is an integral part of a Standard, whereas an informative annex is only for information and guidance.

## CONTENTS

	<i>Page</i>
1 Scope .....	1
2 Normative references .....	2
3 Definitions .....	2
4 Test circuits and measuring systems .....	6
4.1 General requirements .....	6
4.2 Test circuits for alternating voltages .....	7
4.3 Measuring systems for apparent charge .....	7
4.3.1 General .....	7
4.3.2 Coupling device .....	7
4.3.3 Pulse train response of instruments for the measurement of apparent charge .....	8
4.3.4 Wide-band PD instruments .....	8
4.3.5 Wide-band PD instruments with active integrator .....	9
4.3.6 Narrow-band PD instruments .....	9
4.4 Requirements for measurements with digital PD-instruments .....	9
4.4.1 Requirements for measurement of apparent charge $q$ .....	10
4.4.2 Requirements for measurement of test voltage magnitude and phase .....	10
4.5 Measuring systems for derived quantities .....	10
4.5.1 Coupling device .....	10
4.5.2 Instruments for the measurement of pulse repetition rate $n$ .....	10
4.5.3 Instruments for the measurement of average discharge current $I$ .....	10
4.5.4 Instruments for the measurement of discharge power $P$ .....	11
4.5.5 Instruments for the measurement of quadratic rate $D$ .....	11
4.5.6 Instruments for the measurement of the radio disturbance voltage .....	11
4.6 Ultra-wide-band instruments for PD detection .....	11
5 Calibration of a measuring system in the complete test circuit .....	11
5.1 General .....	11
5.2 Calibration procedure .....	12
6 Calibrators .....	12
6.1 General .....	12
6.2 Calibrators for the calibration of a measuring system in the complete test circuit .....	13
6.3 Calibrators for performance tests on measuring systems .....	13
7 Maintaining the characteristics of calibrators and measuring systems .....	13
7.1 Schedule of tests .....	14
7.2 Maintaining the characteristics of calibrators .....	14
7.2.1 Type tests on calibrators .....	14
7.2.2 Routine tests on calibrators .....	14
7.2.3 Performance tests on calibrators .....	14
7.2.4 Performance checks on calibrators .....	15
7.2.5 Record of performance .....	15
7.3 Maintaining the characteristics of measuring systems .....	15
7.3.1 Type tests on PD measuring systems .....	16
7.3.2 Routine tests on measuring systems .....	16

	<i>Page</i>
7.3.3 Performance tests on measuring systems.....	16
7.3.4 Performance checks for measuring systems.....	16
7.3.5 Checks for additional capabilities of digital measuring systems.....	17
7.3.6 Record of performance.....	17
8 Tests.....	18
8.1 General requirements.....	18
8.2 Conditioning of the test object.....	18
8.3 Choice of test procedure.....	18
8.3.1 Determination of the partial discharge inception and extinction voltages.....	19
8.3.2 Determination of the partial discharge magnitude at a specified test voltage.....	19
9 Measuring uncertainty and sensitivity.....	19
10 Disturbances.....	20
11 Partial discharge measurements during tests with direct voltage.....	20
11.1 General.....	20
11.2 Quantities related to partial discharges.....	21
11.3 Voltages related to partial discharges.....	21
11.3.1 Partial discharge inception and extinction voltages.....	21
11.3.2 Partial discharge test voltage.....	21
11.4 Test circuits and measuring systems.....	21
11.5 Tests.....	22
11.5.1 Choice of test procedures.....	22
11.5.2 Disturbances.....	22
Annex A (normative) Performance test on a calibrated test object.....	27
Annex B (informative) Test circuits.....	30
Annex C (informative) Measurements on cables, gas insulated switchgear, power capacitors and on test objects with winding.....	32
Annex D (informative) The use of radio disturbance (interference) meters for the detection of partial discharges.....	33
Annex E (informative) Guidelines for digital acquisition of partial discharge quantities.....	35
Annex F (informative) Non-electrical methods of PD detection.....	38
Annex G (informative) Disturbances.....	39
Figure 1 – Basic partial discharge test circuits.....	23
Figure 2 – Test circuit for measurement at a tapping of a bushing.....	24
Figure 3 – Test circuit for measuring self-excited test objects.....	24
Figure 4 – Connections for the calibration of the complete test arrangement.....	26
Figure 5 – Correct relationship between amplitude and frequency to minimize integration error for a wide-band system.....	26
Figure A.1 – Calibration of pulse calibrators.....	29
Figure D.1 – Variation of CISPR radio disturbance meter reading $f(N)$ with repetition frequency $N$ , for constant pulses.....	34
Figure E.1 – Output voltage signals $U_{out}$ of two different PD measuring systems for apparent charge (double pulse).....	37
Table 1 – Pulse train response of PD instruments.....	8
Table 2 – Tests required for calibrators.....	15
Table 3 – Tests required for measuring systems.....	17

## STANDARDS AUSTRALIA

## Australian Standard

## High-voltage test techniques—Partial discharge measurements

Any IEC table, figure or passage of text that is struck-through is not part of this Standard. Any Australian table, figure or passage of text that is added (and identified by shading) is part of this Standard.

## 1 Scope

This International Standard is applicable to the measurement of **partial discharges** which occur in electrical apparatus, components or systems when tested with alternating voltages up to 400 Hz or with direct voltage.

This standard

- defines the terms used;
- defines the quantities to be measured;
- describes test and measuring circuits which may be used;
- defines analogue and digital measuring methods required for common applications;
- specifies methods for calibration and requirements of instruments used for calibration;
- gives guidance on test procedures;
- gives some assistance concerning the discrimination of **partial discharges** from external interference.

The provisions of this standard should be used in the drafting of specifications relating to **partial discharge** measurements on specific power apparatus. It deals with electrical measurements of impulsive (short-duration) **partial discharges**, but reference is also made to non-electrical methods primarily used for **partial discharge** location (see annex F).

Diagnosis of the behaviour of specific power apparatus can be aided by digital processing of **partial discharge** data (see annex E) and also by non-electrical methods that are primarily used for **partial discharge** location (see annex F).

This standard is primarily concerned with electrical measurements of **partial discharges** made during tests with alternating voltage, but specific problems which arise when tests are made with direct voltage are considered in clause 11.

The terminology, definitions, basic test circuits and procedures often also apply to tests with other frequencies, but special test procedures and measuring system characteristics, which are not considered in this standard, may be required.

Annex A provides normative requirements for performance tests on calibrators.