

Australian Standard™

Fire hazard testing

**Part 1.40: Guidance for assessing the
fire hazard of electrotechnical
products—Insulating liquids**

STANDARDS
Australia

The logo for Standards Australia, featuring a stylized graphic of overlapping circles and a swoosh above the text 'STANDARDS Australia'.

This Australian Standard was prepared by Committee EL-053, Fire hazard testing—
Electrotechnical equipment. It was approved on behalf of the Council of Standards
Australia on 23 May 2006.
This Standard was published on 22 June 2006.

The following are represented on Committee EL-053:

Australian Electrical and Electronic Manufacturers Association
Australian Information Industry Association
Electrical Compliance Testing Association
Electrical Regulatory Authorities Council
Energy Networks Association

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia, GPO Box 476, Sydney, NSW 2001.

This Standard was issued in draft form for comment as DR 06176.

Australian Standard™

Fire hazard testing

**Part 1.40: Guidance for assessing the
fire hazard of electro-technical
products—Insulating liquids**

First published as AS 60695.1.40—2006.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia

ISBN 0 7337 7542 X

PREFACE

This Standard was prepared by the Standards Australia Committee EL-053, Fire hazard testing—Electrotechnical equipment.

The objective of this series of standards is to provide the electrotechnology industry and standards writing committees with a series of standards which give guidance on assessing the fire hazard of electrotechnical products.

This Standard is identical with, and has been reproduced from IEC 60695-1-40, Ed 1.0 (2002), *Fire hazard testing - Part 1-40: Guidance for assessing the fire hazard of electrotechnical products - Insulating liquids*.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text 'IEC 60695-1-40' should read 'AS 60695.1.40'.
- (c) A full point should be substituted for a comma when referring to a decimal marker.
- (d) Any French text on figures should be ignored.

The terms 'normative' and 'informative' are used to define the application of the annex to which they apply. A normative annex is an integral part of a standard, whereas an informative annex is only for information and guidance.

Any International Standard referenced should be replaced by an equivalent Australian Standard where one is available. The availability of equivalent Australian Standards can be determined either from the Standards Web Shop at www.standards.com.au or from the annual printed catalogue of Australian Standards.

CONTENTS

	<i>Page</i>
INTRODUCTION	iv
1 Scope	1
2 Normative references	1
3 Definitions	1
4 Classification of insulating liquids	2
5 Types of electrotechnical equipment containing insulating liquids	2
6 Fire parameters	2
7 Fire scenarios	3
8 Protective measures against fire	5
9 Considerations for the selection of test methods	6
Annex A (informative) History of insulating liquids	8
Annex B (informative) Preventive and protective measures against fire	9
Annex C (informative) Transformers	10
Annex D (informative) Power capacitors	12
Annex E (informative) Cables	13
Annex F (informative) Bushings	15
Annex G (informative) Switchgear	16
Bibliography	17
Table 1 – Classification of insulating liquids	2

INTRODUCTION

The risk of fire must be considered for all forms of electrotechnical products. For more than 100 years, insulating liquids based on mineral oil have been used for the insulating and cooling of electrical transformers and some other types of electrotechnical equipment.

During the last 60 years, synthetic insulating liquids have been developed and used in specific electrotechnical applications for which their properties are particularly suitable. However, for technical and economic reasons, highly refined mineral oil continues to be the most widely used insulating liquid for use in transformers, the major end use application. Their safe installation is covered by local, national and international regulations.

The fire safety record of electrotechnical equipment containing insulating liquids is good for both mineral oil and synthetic liquids. In recent years improvements in design and protective measures against fire have reduced the fire hazard for electrotechnical equipment containing mineral oil. However, as for all forms of electrotechnical equipment, the objective should be to reduce the likelihood of fire even in the event of foreseeable abnormal use.

The practical aim shall be to prevent ignition, but if ignition occurs, to control the fire, preferably within the enclosure of the electrotechnical equipment.

STANDARDS AUSTRALIA

Australian Standard**Fire hazard testing****Part 1.40: Guidance for assessing the fire hazard of electrotechnical products—Insulating liquids**

1 Scope

This technical specification provides guidance on the minimization of fire hazard arising from the use of electrical insulating liquids to

- a) electrotechnical equipment and systems,
- b) people, building structures and their contents.

As insulating liquids are always part of an insulating system, the fire hazard of the complete system must also be assessed.

This basic safety publication is primarily intended for use by technical committees in the preparation of standards in accordance with the principles set down in IEC Guide 104 and ISO/IEC Guide 51. It is not intended for use by manufacturers or certification bodies.

One of the responsibilities of a technical committee is, wherever applicable, to make use of basic safety publications in the preparation of its publications.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60695-1-1:1999, *Fire hazard testing – Part 1-1: Guidance for assessing the fire hazard of electrotechnical products – General guidelines*

IEC 60695-8-1:2001, *Fire hazard testing – Part 8-1: Heat release – General guidance*

IEC 61100:1999, *Classification of insulating liquids according to fire-point and net calorific value*

IEC Guide 104:1997, *The preparation of safety publications and the use of basic safety publications and group safety publications*

ISO/IEC Guide 51:1999, *Safety aspects – Guidelines for their inclusion in standards*

ISO/IEC 13943:2000, *Fire safety – Vocabulary*

ISO 2592:2000, *Determination of flash and fire points – Cleveland open cup method*

3 Definitions

For the purposes of this document, the terms and definitions given in ISO/IEC 13943 apply.