

Australian Standard™

**Fire hazard testing**

**Part 5.2: Corrosion damage effects of  
fire effluent—Summary and relevance of  
test methods**

**STANDARDS**  
Australia



This Australian Standard was prepared by Committee EL-053, Fire hazard testing—  
Electrotechnical equipment. It was approved on behalf of the Council of Standards  
Australia on 23 May 2006.  
This Standard was published on 22 June 2006.

---

The following are represented on Committee EL-053:

Australian Electrical and Electronic Manufacturers Association  
Australian Information Industry Association  
Electrical Compliance Testing Association  
Electrical Regulatory Authorities Council  
Energy Networks Association

---

#### **Keeping Standards up-to-date**

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at [www.standards.com.au](http://www.standards.com.au) and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at [mail@standards.org.au](mailto:mail@standards.org.au), or write to the Chief Executive, Standards Australia, GPO Box 476, Sydney, NSW 2001.

---

*This Standard was issued in draft form for comment as DR 06179.*

Australian Standard™

**Fire hazard testing**

**Part 5.2: Corrosion damage effects of  
fire effluent—Summary and relevance of  
test methods**

First published as AS 60695.5.2—2006.

**COPYRIGHT**

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia

ISBN 0 7337 7544 6

## PREFACE

This Standard was prepared by the Standards Australia Committee EL-053, Fire hazard testing—Electrotechnical equipment.

The objective of this series of standards is to provide the electrotechnology industry and standards writing committees with a series of standards which give guidance on assessing the fire hazard of electrotechnical products.

This Standard is identical with, and has been reproduced from IEC/TS 60695-5-2, Ed 2.0 (2002), *Fire hazard testing - Part 5.2: Corrosion damage effects of fire effluent - Summary and relevance of test methods*.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text 'IEC/TS 60695-5-2' should read 'AS 60695.5.2'.
- (c) A full point should be substituted for a comma when referring to a decimal marker.
- (d) Any French text on figures should be ignored.

The terms 'normative' and 'informative' are used to define the application of the annex to which they apply. A normative annex is an integral part of a standard, whereas an informative annex is only for information and guidance.

Any International Standard referenced should be replaced by an equivalent Australian Standard where one is available. The availability of equivalent Australian Standards can be determined either from the Standards Web Shop at [www.standards.com.au](http://www.standards.com.au) or from the annual printed catalogue of Australian Standards.

## CONTENTS

	<i>Page</i>
INTRODUCTION .....	iv
1 Scope .....	1
2 Normative references .....	1
3 Terms and definitions .....	1
4 Classification of test methods .....	2
4.1 Introduction .....	2
4.2 Test specimen .....	3
4.3 Fire model .....	3
4.4 The nature of the corrosivity measurement .....	3
5 Published test methods .....	4
5.1 Introduction .....	4
5.2 Tests for the determination of halogen acid in combustion gases .....	4
5.3 Tests for the determination of the acidity and conductivity of combustion gases dissolved in an aqueous solution .....	5
5.4 Test for the determination of corrosive gases by using the copper mirror test in ASTM D 2671-00 [9] .....	6
5.5 Static method (ISO 11907-2 [10]) .....	7
5.6 Travelling furnace method (ISO 11907-3 [11]) .....	9
5.7 Cone corrosimeter method .....	12
6 Leakage current and metal loss (IEC 60695-5-1) .....	13
6.1 Purpose and principle .....	13
6.2 Test specimen .....	13
6.3 Corrosion targets .....	13
6.4 Test method .....	14
7 Overview of methods and relevance of data .....	14
 Annex A (informative) Acidity and conductivity of aqueous solutions – Test methods .....	 18
Annex B (informative) Determination of repeatability and reproducibility – Comparative tests of solutions of combustion gases .....	19
Bibliography .....	23
 Figure 1 – Schematic drawing of a serpentine-track resistance target .....	 8
Figure 2 – Schematic drawing of a typical corrosion target of defined metal thickness .....	11
Figure 3 – Interdigitated leakage current target .....	14
 Table 1 – General classification of fire stages in accordance with ISO/TR 9122-1 .....	 4
Table 2 – Overview of corrosivity test methods .....	16
Table A.1 – Test methods for the measurement of acidity and conductivity of aqueous solutions obtained after bubbling combustion effluent through water .....	18
Table B.1 – Determination of repeatability and reproducibility – Comparative pH tests on solutions of combustion gases .....	20
Table B.2 – Determination of repeatability and reproducibility – Comparative resistivity tests on solutions of combustion gases .....	21
Table B.3 – Results obtained on brominated polycarbonate .....	22

## INTRODUCTION

The risk of fire should be considered in any electrical circuit. With regard to this risk, the circuit and equipment design, the selection of components and the choice of materials should contribute towards reducing the likelihood of fire even in the event of foreseeable abnormal use, malfunction or failure. The practical aim should be to prevent ignition caused by electrical malfunction but, if ignition and fire occur, to control the fire preferably within the bounds of the enclosure of the electrotechnical product.

All fire effluent is corrosive to some degree and the level of potential to corrode depends on the nature of the fire, the combination of combustible materials involved in the fire, the nature of the substrate under attack, and the temperature and relative humidity of the environment in which the corrosion is taking place. There is no evidence that fire effluent from electrotechnical products offers greater risk of corrosion damage than the fire effluent from other products such as furnishings, building materials, etc.

The performance of electrical and electronic components can be adversely affected by corrosion damage when subjected to fire effluent. A wide variety of combinations of small quantities of effluent gases, smoke particles, moisture and temperature may provide conditions for electrical component or system failures from breakage, overheating or shorting.

Evaluation of potential corrosion damage is particularly important for high value and safety-related electrotechnical products and installations.

Technical committees responsible for the products will choose the test(s) and specify the level of severity.

The study of corrosion damage requires an interdisciplinary approach involving chemistry, electricity, physics, mechanical engineering, metallurgy and electrochemistry. In the preparation of this part of IEC 60695, all of the above have been considered.

IEC 60695-5-2 provides a summary of test methods including relevance and usefulness.

IEC 60695-5-1 defines the scope of the guidance and indicates the field of application.

IEC 60695-5-3 gives details of a small-scale test method for the measurement of leakage current and metal loss caused by fire effluent.

## STANDARDS AUSTRALIA

---

**Australian Standard****Fire hazard testing**  
**Part 5.2: Corrosion damage effects of fire effluent—Summary and  
relevance of test methods**

---

**1 Scope**

This part of IEC 60695 gives a summary of the test methods that are used in the assessment of the corrosivity of fire effluent. It presents a brief summary of test methods in common use, either as international standards or national or industry standards. It includes special observations on their relevance, for electrotechnical products and their materials, to real fire scenarios and gives recommendations on their use.

One of the responsibilities of a technical committee is, wherever applicable, to make use of basic safety publications in the preparation of its publications

**2 Normative references**

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60695-4:1993, *Fire hazard testing – Part 4: Terminology concerning fire tests*

IEC 60695-5-1:2002, *Fire hazard testing – Part 5-1: Corrosion damage effects of fire effluent – General guidance*

IEC/TS 60695-5-3, *Fire hazard testing – Part 5-3: Corrosion damage effects of fire effluent – Leakage current and metal loss test method<sup>1</sup>*

IEC Guide 104:1997, *The preparation of safety publications and the use of basic safety publications and group safety publications*

ISO/IEC 13943:2000, *Fire safety – Vocabulary*

ISO/TR 9122-1:1999, *Toxicity testing of fire effluents – Part 1: General*

**3 Terms and definitions**

For the purposes of this part of IEC 60695, the definitions given in ISO/IEC 13943 and IEC 60695-4, as well as the following definitions, apply.

**3.1****corrosion damage**

physical and/or chemical damage or impaired function caused by chemical action

[ISO/IEC 13943, definition 25]

---

<sup>1</sup> To be published.