

AS 60947.3:2023



STANDARDS
Australia



Low-voltage switchgear and controlgear

Part 3: Switches, disconnectors, switch-disconnectors and fuse combination units (IEC 60947-3:2020 (ED. 4.0) MOD)

currently in preview, click buy full version

AS 60947.3:2023

This Australian Standard ® was prepared by EL-006, Industrial Switchgear And Controlgear. It was approved on behalf of the Council of Standards Australia on 16 October 2023.

This Standard was published on 3 November 2023.

The following are represented on Committee EL-006:

- Association of Accredited Certification Bodies
- Australian Industry Group
- Bureau of Steel Manufacturers of Australia
- Electrical Regulatory Authorities Council, Australia
- Energy Networks Australia
- Engineers Australia
- National Electrical and Communications Association
- National Electrical Switchboard Manufacturers Association

This Standard was issued in draft form for comment as DR AS 60947.3:2022.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

ISBN 978 1 76139 403 4

Low-voltage switchgear and controlgear

Part 3: Switches, disconnectors, switch- disconnectors and fuse combination units (IEC 60947-3:2020 (ED. 4.0) MOD)

Originated as AS 1775—1975.
Revised and designated as AS/NZS IEC 60947.3:2015.
Previous edition AS 60947.3:2012.
Second edition 2023.



© IEC Geneva Switzerland 2023 — All rights reserved
© Standards Australia Limited 2023

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of either the IEC or the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth). If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please see the contact details on the back cover or the contact us page of the website for further information.

Preface

This Standard was prepared by the Australian members of the Joint Standards Australia/Standards New Zealand Committee EL-006 Industrial Switchgear and Controlgear, to supersede AS 60947.3:2018.

After consultation with stakeholders in both countries, Standards Australia and Standards New Zealand decided to develop this document as an Australian Standard rather than an Australian/New Zealand Standard.

AS 60947.3:2018 will also remain current for 24 months after the date of publication of this document and after this time it will be superseded by AS 60947.3:2023. Regulatory authorities that reference this document in regulation may apply these requirements at a different time. Users of this document should consult with these authorities to confirm their requirements.

The objective of this Standard is to incorporate new requirements for determination of suitability of rated uninterruptible duty current, to specify requirements for switches, disconnectors, switch-disconnectors and fuse-combination units and their dedicated accessories to be used in distribution circuits and motor circuits of which the rated voltage does not exceed 1 000 V AC or 1 500 V DC, and to state —

- (a) the characteristics of the equipment;
- (b) the conditions that apply to the equipment with reference to:
 - (i) operation and behaviour in normal service;
 - (ii) operation and behaviour in case of specified abnormal conditions, e.g. short-circuit; and
 - (iii) dielectric properties;
- (c) the tests for confirming that these conditions have been met and the methods that are adopted for these tests; and
- (d) the information relevant to the marking of the equipment or made available by the manufacturer, e.g. in the catalogue.

The major changes in this edition are as follows:

- (i) Update AS 60947.3:2018 which is an adoption of IEC 60947-3:2015, to adopt the most recent IEC 60947-3:2020.
- (ii) Clarify and update the derating criteria of material at different ambients and provide a table of limiting temperature related to ambient.
- (iii) Clarify and resolve the conflict between AS 60947.3:2018, Table 12 and AS/NZS 6143.1:2016, Table 6.
- (iv) Clarify the different limits for I_e , and I_{the} (40°C and 60°C).
- (v) Clarify and update the criteria to be reported in a test report.
- (vi) New uninterrupted duty test (Clause D.5.3.4.2).

Lists of all parts in the AS 60947 series can be found in the [Standards Australia online catalogue](#).

This Standard is an adoption with national modifications, and has been reproduced from, IEC 60947-3:2020 *Low-voltage switchgear and controlgear - Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units*. The modifications are additional requirements and are set out in [Appendix ZZ](#), which has been added at the end of the source text.

The modifications made to IEC 60947.3:2021 (Ed.4.0) form the Australian modifications for purpose of the IECEE CB Scheme for recognition of testing to standards for safety of electrical equipment.

[Appendix ZZ](#) lists the modifications to IEC 60947-3:2020 for the application of this Standard in Australia.

As this document has been reproduced from an International Standard the following applies:

- (A) In the source text “this International Standard” should read “this document”.
- (B) A full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

CONTENTS

FOREWORD	7
INTRODUCTION	9
1 Scope	10
2 Normative references	11
3 Terms, definitions and index of terms	12
3.1 General	12
3.2 Alphabetical index of terms	12
3.3 General terms	13
4 Classification	15
4.1 According to the utilization category	15
4.2 According to the method of operation	15
4.2.1 Manually operated equipment	15
4.2.2 Remotely operated equipment	15
4.3 According to suitability for isolation	16
4.4 According to the degree of protection provided	16
4.5 Summary of symbols for equipment types	16
5 Characteristics	16
5.1 Summary of characteristics	16
5.2 Type of equipment	17
5.3 Rated and limiting values for the main circuit	17
5.3.1 General	17
5.3.2 Rated voltages	17
5.3.3 Currents	17
5.3.4 Rated frequency	17
5.3.5 Rated duty	18
5.3.6 Normal load and overload characteristics	18
5.3.7 Short-circuit characteristics	18
5.4 Utilization category	19
5.5 Control circuit	20
5.6 Auxiliary circuit	20
5.7 Relays and releases	20
5.8 Co-ordination with short-circuit protective devices (SCPD)	20
6 Product information	20
6.1 Nature of information	20
6.2 Marking	20
6.3 Instructions for installation, operation and maintenance, decommissioning and dismantling	22
6.4 Normal service, mounting and transport conditions	22
7 Constructional and performance requirements	22
8.1 Constructional requirements	22
8.1.1 General	22
8.2 Performance requirements	23
8.2.1 Operating conditions	23
8.2.2 Temperature-rise	24
8.2.3 Dielectric properties	24

8.2.4	Ability to make and break under no-load, normal load and overload conditions.....	24
8.2.5	Ability to make, break or withstand short-circuit currents	27
8.2.6	Void.....	27
8.2.7	Additional performance requirements for equipment suitable for isolation.....	27
8.2.8	Critical load current performance: DC equipment.....	27
8.2.9	Overload requirements for equipment incorporating fuses.....	27
8.3	Electromagnetic compatibility (EMC).....	27
8.3.1	General	27
8.3.2	Immunity.....	27
8.3.3	Emission.....	27
9	Tests.....	29
9.1	Kinds of test.....	29
9.1.1	General	29
9.1.2	Type tests.....	29
9.1.3	Routine tests	29
9.1.4	Sampling tests.....	30
9.1.5	Special tests.....	30
9.2	Compliance with constructional requirements.....	30
9.2.1	General	30
9.3	Performance	31
9.3.1	General	31
9.3.2	Test sequences	31
9.3.3	General test conditions	32
9.3.4	Test sequence I: general performance characteristics	35
9.3.5	Test sequence II: operational performance capability	39
9.3.6	Test sequence III: short-circuit performance capability.....	41
9.3.7	Test sequence IV: conditional short-circuit current.....	45
9.3.8	Test sequence V: overload performance capability	48
9.3.9	Test sequence VI: critical load current performance of equipment with a DC rating.....	49
9.4	Electromagnetic compatibility tests	51
9.4.1	General	51
9.4.2	Immunity	52
9.4.3	Emission.....	52
9.5	Special tests	52
9.5.1	Mechanical and electrical durability	52
9.5.2	Mechanical durability	52
9.5.3	Electrical durability	52
9.5.4	Damp heat, salt mist, vibration and shock.....	53
Annex A (normative)	Equipment for direct switching of a single motor.....	54
A.1	General.....	54
A.2	Rated.....	54
A.2.1	Intermittent periodic duty or intermittent duty	54
A.2.2	Temporary duty	54
A.3	Making and breaking capacities	54
A.4	Utilization category	54
A.5	Operational performance	57

A.6	Mechanical durability	58
A.7	Electrical durability	58
A.8	Verification of making and breaking capacities	58
A.9	Operational performance test	58
A.10	Special tests	58
A.10.1	General	58
A.10.2	Mechanical durability test	59
A.10.3	Electrical durability test	59
A.11	Critical load current performance for DC equipment	60
Annex B (informative)	Items subject to agreement between manufacturer and user	61
Annex C (normative)	Single pole operated three-pole switches	62
C.1	General	62
C.2	Tests	63
C.3	Test set-up and sequence	63
C.3.1	Making and breaking capacities (9.3.4.4) and operational performance (9.3.5.2)	63
C.3.2	Fuse protected short-circuit test (9.3.7.3)	63
C.4	Condition of equipment after tests	63
C.5	Instructions for use	63
Annex D (normative)	Switches, disconnectors, switch-disconnectors and fuse-combination units for use in photovoltaic (PV) DC applications	64
D.1	General	64
D.1.1	Background	64
D.1.2	Object	64
D.2	Normative references	64
D.3	Terms and definitions	64
D.4	Classification	65
D.4.1	According to the utilization category	65
D.5	Characteristics	65
D.6	Product information	66
D.7	Normal service, mounting and transport conditions	66
D.8	Constructional and performance requirements	66
D.9	Tests	70
Annex E (normative)	Additional requirements for LV switchgear intended for connection of aluminium conductors	76
E.1	Object	76
E.2	Normative references	76
E.3	Terms, definitions and index of terms	76
E.4	Classification	77
E.5	Characteristics	77
E.6	Product information	77
E.6.1	Nature of information	77
E.6.2	Marking	77
E.6.3	Instructions for installation, operation and maintenance, decommissioning and dismantling	77
E.7	Normal service, mounting and transport conditions	78
E.8	Constructional and performance requirements	78
E.9	Tests	78
E.9.1	General	78

E.9.2	Current cycling test.....	79
E.9.3	Mechanical properties of terminals	84
E.9.4	Test for insertability of unprepared round aluminium conductors having the maximum cross-section	85
Annex F (informative)	Power loss.....	88
F.1	General.....	88
F.2	Test methods	88
F.2.1	General	88
F.2.2	General case for AC switches and/or disconnectors	88
F.2.3	General case for AC fused combination units and fuse disconnectors.....	88
F.2.4	Switches and/or disconnectors of rated current not exceeding 400 A.....	89
F.2.5	Fused combination units and fuse disconnectors of rated current not exceeding 400 A.....	89
F.3	Test procedure.....	90
Bibliography	93
Figure C.1	– Typical arrangements	62
Figure E.1	– General test arrangement	80
Figure E.2	– Mounting of terminals for the current cycling test	80
Figure F.1	– Example of power loss measurement according to F.2.2	90
Figure F.2	– Example of power loss measurement according to F.2.3	91
Figure F.3	– Example of power loss measurement according to F.2.4	91
Figure F.4	– Example of power loss measurement according to F.2.5	92
Table 1	– Summary of equipment definitions	16
Table 2	– Utilization categories	19
Table 3	– Product information	21
Table 4	– Verification of rated making and breaking capacities (see 9.3.4.4) – Conditions for making and breaking corresponding to the various utilization categories	25
Table 5	– Verification of operational performance – Number of operating cycles corresponding to the rated operational current.....	26
Table 6	– Test circuit parameters for Table 5	26
Table 7	– Immunity tests	28
Table 8	– Emission limits	28
Table 9	– List of type tests applicable to a given equipment.....	31
Table 10	– Overall scheme of test sequences	32
Table 11	– Test sequence I: general performance characteristics	36
Table 12	– Temperature-rise limits for terminals and accessible parts.....	39
Table 13	– Test sequence II: operational performance capability	40
Table 14	– Test sequence III: short-circuit performance capability	42
Table 15	– Test sequence IV: conditional short-circuit current – circuit-breaker protected	46
Table 16	– Test sequence IV: conditional short-circuit current – fuse protected	47
Table 17	– Test sequence V: overload performance capability	49
Table 18	– Number of operating cycles corresponding to the critical load current.....	51
Table 19	– Test circuit parameters for Table 18	51

Table 20 – Test sequence VI: critical load current performance of equipment with a DC rating	51
Table A.1 – Utilization categories	55
Table A.2 – Rated making and breaking capacity conditions corresponding to several utilization categories	56
Table A.3 – Relationship between current broken I_C and off-time for the verification of the rated making and breaking capacities	57
Table A.4 – Operational performance – Conditions for making and breaking corresponding to several utilization categories	57
Table A.5 – Verification of the number of on-load operating cycles – Conditions for making and breaking corresponding to several utilization categories	60
Table D.1 – Utilization categories	65
Table D.2 – Service arrangements	66
Table D.3 – Environmental conditions	66
Table D.4 – Rated impulse withstand levels for PV switches, PV disconnectors, PV switch-disconnectors or PV fuse-combination units	67
Table D.5 – Verification of rated making and breaking capacities (see 9.3.4.2) – Conditions for making and breaking corresponding to the DC-PV category	68
Table D.6 – Number of operating cycles	69
Table D.7 – Test circuit parameters for Table D.6	69
Table D.8 – Overall scheme of test sequences	71
Table D.9 – Number of operating cycles corresponding to the critical load current	73
Table D.10 – Test circuit parameters for Table D.9	73
Table E.1 – List of tests for terminal connections with aluminium cables	78
Table E.2 – Conductor length for current cycling test as per conductor cross-section	81
Table E.3 – Equalizer dimensions	81
Table E.4 – Starting test current for the current cycling test	83
Table E.5 – Example of stability factor calculation	84
Table E.6 – Test values for flexion and pull-out test for cables	85
Table E.7 – Test aluminium cable for test currents up to 800 A	86
Table E.8 – Test aluminium bars for test currents above 150 A and up to 3 150 A	87

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60947-3 has been prepared by subcommittee 121A: Low-voltage switchgear and controlgear, of IEC technical committee 121: Switchgear and controlgear and their assemblies for low voltage.

This fourth edition cancels and replaces the third edition published in 2008, Amendment 1:2012 and Amendment 2:2015. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- addition of critical load current tests for DC switches (see 9.3.9);
- addition of requirements for a conditional short-circuit rating for disconnectors, switches, and switch-disconnectors protected by circuit-breakers (see 9.3.7.2);
- addition of new categories for high-efficiency motors switching (see Annex A);

- addition of new Annex E for connection to aluminium conductors;
- addition of new Annex F for power losses measurement.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
121A/340/FDIS	121A/354/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60947 series, published under the general title *Low-voltage switchgear and controlgear*, can be found on the IEC website.

This part is to be used in conjunction with the sixth edition of IEC 60947-1:2020. The numbering of the subclauses is sometimes not continuous because it is based on IEC 60947-1:2020.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

The contents of the corrigendum of October 2021 have been included in this copy.

INTRODUCTION

The provisions of the general rules dealt with in IEC 60947-1 are applicable to this document, where specifically called for. Clauses and subclauses, tables, figures and annexes of the general rules thus applicable are identified by reference to the sixth edition of IEC 60947-1:2020, for example, 5.3.4.1 of IEC 60947-1:2020, Table 4 of IEC 60947-1:2020, or Annex A of IEC 60947-1:2020.

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units

1 Scope

This part of IEC 60947 applies to switches, disconnectors, switch-disconnectors and fuse-combination units and their dedicated accessories to be used in distribution circuits and motor circuits of which the rated voltage does not exceed 1 000 V AC or 1 500 V DC.

NOTE 1 Accessories are interconnecting units, extended terminals, internal coils, auxiliary contacts, motor operator, etc. offered as options with the basic unit.

This document does not apply to equipment coming within the scope of IEC 60947-2, IEC 60947-4-1 and IEC 60947-5-1.

Particular requirements for switches, disconnectors, switch-disconnectors and fuse-combination units for use in photovoltaic (PV) DC applications are given in Annex D.

Specific requirements for LV switchgear intended for the connections of aluminium conductors are given in Annex E.

Guidance on measurement of power loss is provided in Annex F.

This document does not include the additional requirements necessary for electrical apparatus for explosive gas atmospheres.

NOTE 2 Depending on its design, a switch (or disconnector) can be referred to as "a rotary switch (disconnector)", "cam-operated switch (disconnector)", "knife-switch (disconnector)", etc.

NOTE 3 In this document, the word "switch" also applies to the apparatus referred to in French as "commutateurs", intended to modify the connections between several circuits and *inter alia* to substitute a part of a circuit for another.

NOTE 4 In general, throughout this document, switches, disconnectors, switch-disconnectors and fuse-combination units will be referred to as "equipment".

The object of this document is to state:

- a) the characteristics of the equipment;
- b) the conditions that apply to the equipment with reference to:
 - 1) operation and behaviour in normal service;
 - 2) operation and behaviour in case of specified abnormal conditions, e.g. short-circuit;
 - 3) dielectric properties;
- c) the tests for confirming that these conditions have been met and the methods that are adopted for these tests;
- d) the information relevant to the marking of the equipment or made available by the manufacturer, e.g. in the catalogue.

Specific items requiring agreement between the user and the manufacturer are identified in Annex B.