

Australian Standard™

Low-voltage switchgear and controlgear

Part 8: Control units for built-in thermal protection (PTC) for rotating electrical machines

This Australian Standard was prepared by Committee EL-006, Industrial Switchgear and Controlgear. It was approved on behalf of the Council of Standards Australia on 3 March 2005.
This Standard was published on 31 March 2005.

The following are represented on Committee EL-006:

Australasian Railway Association
Australian Chamber of Commerce and Industry
Australian Electrical and Electronic Manufacturers Association
Bureau of Steel Manufacturers of Australia
Electricity Supply Association of Australia
Engineers Australia
National Electrical and Communications Association
National Electrical Switchboard Manufacturers Association
Testing Interests (Australia)

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia, GPO Box 5420, Sydney, NSW 2001.

This Standard was issued in draft form for comment as DR 04233.

Australian Standard™

Low-voltage switchgear and controlgear

Part 8: Control units for built-in thermal protection (PTC) for rotating electrical machines

Originally as AS 1023.1—1985 and AS 1023.3—1973.
Amalgamated, revised and redesignated AS 60947.8—2005.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 6572 6

PREFACE

This Standard was prepared by the Standards Australia Committee EL-006, Industrial Switchgear and Controlgear to supersede AS 1023.1—1985 and AS 1023.3—1973.

The objective of this Standard is to specify rules for control units, which perform the switching functions in response to thermal detectors incorporated in rotating electrical machines.

This Standard is Part 8 of a series which, when complete, will consist of the following:

AS 60947	Low-voltage switchgear and controlgear
AS 60947.1*	Part 1: General rules
AS 60947.2*	Part 2: Circuit-breakers
AS 60947.3	Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units
AS 60947.3 Suppl	Part 3: Switches, disconnectors, switch-disconnector and fuse-combination units, Supplement 1: Fuse-switch-disconnectors and switch-disconnectors for use with low-voltage aerial bundled cables
AS 60947.4.1*	Part 4.1: Contactors and motor-starters—Electromechanical contactors and motor-starters
AS 60947.4.2*	Part 4.2: Contactors and motor-starters—A.C. semiconductor motor controllers and starters
AS 60947.4.3	Part 4.3: Contactors and motor-starters—A.C. semiconductor controllers and contactors for non-motor loads
AS 60947.5.1*	Part 5.1: Control circuit devices and switching elements—Electromechanical control circuit devices
AS 60947.5.2*	Part 5.2: Control circuit devices and switching elements—Proximity switches
AS 60947.5.3	Part 5.3: Control circuit devices and switching elements—Requirements for proximity devices with defined behaviour under fault conditions
AS 60947.5.4*	Part 5.4: Control circuit devices and switching elements—Methods of assessing the performance of low-energy contacts—Special tests
AS 60947.5.5	Part 5.5: Control circuit devices and switching elements—Electrical emergency stop devices with mechanical latching function
AS 60947.5.6	Part 5.6: Control circuit devices and switching elements—D.C. interface for proximity sensors and switching amplifiers (NAMUR)
AS 60947.5.7*	Part 5.7: Control circuit devices and switching elements—Requirements for proximity devices with analogue output
AS 60947.6.1	Part 6.1: Multiple function equipment—Automatic transfer switching equipment
AS 60947.6.2*	Part 6.2: Multiple function equipment—Control and protective switching devices (or equipment) (CPS)
AS 60947.7.1*	Part 7.1: Ancillary equipment—Terminal blocks for copper conductors
AS 60947.7.2*	Part 7.2: Ancillary equipment—Protective conductor terminal blocks for copper conductors
AS 60947.7.3*	Part 7.3: Ancillary equipment—Safety requirements for terminal blocks for the reception of cartridge fuse-links

AS 60947.8* Part 8: Control units for built-in thermal protection for rotating machines (this Standard)

It is the intention of the Standards Australia Committee to align the numbering of this series of Standards with that of the corresponding IEC 60947 series of Standards.

Standards from the list above that are marked with an asterisk (*) are, at the time of publication of this document, available as a part of the AS 60947 series of Standards.

Standards that are not so marked remain as AS/(NZS) 3947 series Standards. Following the next amendment or revision of the corresponding IEC Standard, each of these Standards remaining in the AS/(NZS) 3947 series will be revised and renumbered as a part of the AS 60947 series.

This Standard is identical in technical content with and has been reproduced from, IEC 60947-8, Ed.1.0(2003), *Low-Voltage Switchgear and Controlgear, Part 8: Control units for built-in thermal protection (PTC) for rotating electrical machines*.

The provisions of the general rules dealt with in AS 60947.1 (hereinafter referred to as Part 1) are applicable to this Standard, where specifically called for. Clauses and subclauses, tables, figures and appendices of the general rules thus applicable are identified by reference to Part 1, for example, 1.2.3 of Part 1, table 4 of Part 1, or annex A of Part 1. Where reference is made to other parts of the AS 60947 (AS/NZS 3947) series, they too are referred to as their relevant parts. AS 60947.5.1 is referred to as Part 5.1.

Thermal protection systems that are based on the principle of monitoring the temperature of the protected parts constitute a simple and effective means of protecting rotating electrical machines against excessive temperature rises, including those caused by faults in the cooling system, or excessively high ambient temperature, whereas systems of protection based only on monitoring the current absorbed may not ensure this type of protection.

Since the operating temperature and response times of thermal protection systems are fixed in advance, they may not be adjusted in relation to the conditions of use of the machine and they may not be completely effective for all fault conditions or improper use of the machine.

A thermal protection system in accordance with this Standard may consist of a characteristic change thermal detector which has an associated control unit to convert a point on the characteristic of the detector to a switching function. A very large number of thermal protection systems are in use and, in all cases, the machine manufacturer will fit the detectors in the machine. The machine manufacturer will either supply the control unit with the machine or specify particulars of the control unit to be used.

It is also customary for the control units to be considered as part of the control system and not necessarily supplied with the machine. For this reason it is considered necessary to have an interchangeable system where the characteristics of association between the detector and the control unit are specified. This particular system is not considered superior in any way to other systems complying with the requirements of this standard, but in some fields the practice is likely to be that this interchangeable system will be used, as indicated by the designation 'Mark A'.

As this standard is reproduced from an International Standard, the following applies:

- (i) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (ii) In the source text 'this standard' should read 'this Australian Standard'.
- (iii) A full point should be substituted for a comma when referring to a decimal marker.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the annex to which they apply. A 'normative' annex is an integral part of a Standard, whereas an 'informative' annex is only for information and guidance.

CONTENTS

	<i>Page</i>
1 Scope	1
2 Normative references	1
3 Terms and definitions	3
4 Classification	6
5 Characteristics	6
5.1 General	6
5.2 Type of equipment	6
5.3 Rated electrical values of protection systems	7
5.4 Rated electrical values of characteristic variation thermal detectors	8
5.5 Rated voltage of the detector circuit of the control unit	9
6 Product information	9
6.1 Nature of information	9
6.2 Marking	10
6.3 Instructions for installation, operation and maintenance	10
7 Normal service, mounting and transport conditions	10
8 Constructional and performance requirements	10
8.1 Constructional requirements	10
8.2 Performance requirements	11
8.3 Electromagnetic compatibility (EMC)	12
9 Tests	13
9.1 Kinds of tests	13
9.2 Compliance with constructional requirements	14
9.3 Compliance with performance requirements	14
9.4 EMC tests	18
9.5 Routine and sampling tests	19
Annex A (normative) Thermal detectors used in thermal protection systems	21
Annex B (normative) Special tests	23
Annex C (informative) Verification requirements in circumstances requiring short-circuit detection in the sensor circuit	24

STANDARDS AUSTRALIA

Australian Standard

Low-voltage switchgear and controlgear
Part 8: Control units for built-in thermal protection (PTC)
for rotating electrical machines

1 Scope

This part of IEC 60947 AS 60947 specifies rules for control units, which perform the switching functions in response to the thermal detectors incorporated in rotating electrical machines according to IEC 60034-11, and the industrial application.

It specifies rules for that type of system comprising a positive temperature coefficient (PTC) thermistor detector having particular characteristics, and its associated control unit.

The PT100 detectors are covered by IEC 60751, where the resistor values are given according to the temperatures of the detector.

The present rules lay down the characteristics of association of this particular positive temperature coefficient thermistor detector and its associated control unit (designated "Mark A detector" and "Mark A control unit"), when they are used in thermal protection systems.

NOTE It is not possible to specify all the requirements for the operating characteristics of a control unit, as they are dependent on some aspects of the thermal detectors. Some aspects of the requirements of the thermal protector system can only be specified when account is taken of the characteristics of the rotating machine to be protected and the method of installation of the detector within the machine.

For these reasons, for each characteristic it is necessary to specify who is responsible for stating the required values and who is responsible for compliance with the requirement and for carrying out any confirmatory test.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

References to international standards that are struck through in this clause are replaced by references to Australian or Australian/New Zealand Standards that are listed immediately thereafter and identified by shading. Any Australian or Australian/New Zealand Standard that is identical to the international standard it replaces is identified as such.

~~IEC 60034-11:1978, *Rotating electrical machines – Part 11: Built-in thermal protection – Chapter 11: Rules for protection of rotating electrical machines*~~

~~IEC 60410:1973, *Sampling plans and procedures for inspection by attributes*~~

~~IEC 60417-DB:2000¹, *Graphical symbols for use on equipment*~~

AS 60417, *Graphical symbols for use on equipment*

IEC 60738-1:1998, *Thermistors – Directly heated positive step-function temperature coefficient – Part 1: Generic specification*

¹DB refers to the IEC on-line database.