

Australian Standard<sup>®</sup>

**Adjustable speed electrical power drive  
systems**

**Part 4: General requirements—Rating  
specifications for a.c. power drive  
systems above 1000 V a.c. and not  
exceeding 35 kV**

**STANDARDS**  
Australia



This Australian Standard® was prepared by Committee EL-027, Power Electronics. It was approved on behalf of the Council of Standards Australia on 28 June 2007. This Standard was published on 31 August 2007.

---

The following are represented on Committee EL-027:

- Australian Communications Authority
  - Australian Electrical and Electronic Manufacturers Association
  - Bureau of Steel Manufacturers of Australia
  - Energy Networks Association
  - Monash University
  - University of Wollongong
- 

This Standard was issued in draft form for comment as DR 7149.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

---

#### **Keeping Standards up-to-date**

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using the current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting [www.standards.org.au](http://www.standards.org.au)

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at [mail@standards.org.au](mailto:mail@standards.org.au), or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

---

Australian Standard<sup>®</sup>

**Adjustable speed electrical power drive systems**

**Part 4: General requirements—Rating specifications for a.c. power drive systems above 1000 V a.c. and not exceeding 35 kV**

First published as AS 61800.4—2007.

**COPYRIGHT**

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia

ISBN 0 7337 8336 8

## PREFACE

This Standard was prepared by the Standards Australia Committee EL-027, Power Electronics.

The objective of this Standard is to provide designers, manufacturers, specifiers, purchasers and users of variable speed drive systems with a set of common characteristics to define variable speed drives with supply voltage above 1 kV and up to 35 kV.

This Standard is identical with, and has been reproduced from IEC 61800-4, Ed.1.0 (2002), *Adjustable speed electrical power drive systems – Part 4: General requirements—Rating specifications for a.c. power drive systems above 1 000 V a.c. and not exceeding 35 kV*.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text 'IEC 61800-4' should read 'AS 61800.4'.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

The terms 'normative' and 'informative' are used to define the application of the annex to which they apply. A normative annex is an integral part of a standard, whereas an informative annex is only for information and guidance.

## CONTENTS

	<i>Page</i>	
1	Scope .....	1
2	Normative references .....	1
3	Definitions .....	4
3.1	System .....	4
3.2	PDS input parameters .....	10
3.3	Converter .....	11
3.4	PDS output parameters .....	12
3.5	Control .....	12
3.6	Tests .....	13
3.7	Symbols .....	14
4	Overview of drive system topologies .....	16
4.1	Topologies classification .....	16
4.2	Converter configuration .....	16
4.3	Motor type .....	17
4.4	By-pass and redundant configurations .....	18
4.5	Regenerative and dynamic braking .....	19
5	Service conditions .....	19
5.1	Installation and operation .....	19
5.2	Transportation .....	23
5.3	Storage of equipment .....	24
6	Ratings .....	25
6.1	Power drive system (PDS) .....	25
6.2	Converter .....	28
6.3	Transformer .....	29
6.4	Motor .....	29
7	Control performance requirements .....	30
7.1	Steady state performance .....	30
7.2	Dynamic performance .....	31
7.3	Process control interface performance .....	37
8	PDS main components .....	39
8.1	Responsibilities .....	39
8.2	Transformer .....	40
8.3	Converter and associated controls .....	43
8.4	Motor .....	44
9	PDS integration requirements .....	50
9.1	General conditions .....	50
9.2	Integration of components with voltages above 1 000 V .....	53
9.3	Protection interface .....	57
9.4	Driven equipment interface .....	59
10	Tests .....	60
10.1	Performance of tests .....	60
10.2	Items of individual PDS component tests .....	60
10.3	Drive system tests .....	63
11	Efficiency determination .....	69
11.1	General .....	69
11.2	Segregated loss method .....	71
11.3	Full load system test .....	75
	Annex A (informative) Most commonly used drive system topologies .....	78
	Annex B (informative) Speed control performance and the mechanical system .....	90
	Annex C (informative) Power semiconductor losses .....	96

Currently in preview, click buy full vers.

## STANDARDS AUSTRALIA

**Australian Standard****Adjustable speed electrical power drive systems  
Part 4: General requirements—Rating specifications for a.c. power drive  
systems above 1000 V a.c. and not exceeding 35 kV****1 Scope**

This part of IEC 61800 applies to adjustable speed a.c. drive systems that include power conversion, control equipment and a motor. Excluded are traction for railway applications and electrical vehicle drives.

It applies to power drive systems (see figure 1) with converter voltages (line-to-line voltage), between 1 kV a.c. and 35 kV a.c., input side 50 Hz or 60 Hz, and load side frequencies up to 600 Hz. Requirements for voltages above 15 kV are not included and are defined by agreement between the manufacturer and the system supplier.

For power drive systems, with voltages above 1 kV, using a step-down input transformer and/or a step-up output transformer in connection with a low voltage converter (below 1 000 V), IEC 61800-2 applies.

EMC aspects are covered in IEC 61800-3.

Specific safety requirements for drive systems with voltage above 1 kV will be covered in IEC 61800-5.

This standard gives the characteristics of the converters, their topologies and their relationship with the complete a.c. drive system. It also states their performance requirements with respect to ratings, normal operating conditions, overload conditions, surge withstand capabilities, stability, protection and line earthing, topologies and testing. Furthermore, it deals with application guidelines, such as control strategies, torsion analysis, recommendations for earthing and drive system component integration.

**2 Normative references**

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

References to international standards that are struck through in this clause are replaced by references to identical Australian Standards that are listed immediately thereafter and identified by shading.

IEC 60034-1, *Rotating electrical machines – Part 1: Rating and performance*

IEC 60034-2:1972, *Rotating electrical machines – Part 2: Methods for determining losses and efficiency of rotating electrical machinery from tests (excluding machines for traction vehicles)*  
Amendment 1 (1995)  
Amendment 2 (1996)