

Australian Standard[®]

Fire protection equipment—Carbon dioxide extinguishing systems for use on premises—Design and installation (ISO 6183:2009, MOD)

STANDARDS
Australia



This Australian Standard® was prepared by Committee FP-011, Special Hazard Fire Protection Systems. It was approved on behalf of the Council of Standards Australia on 10 March 2011.

This Standard was published on 1 April 2011.

The following are represented on Committee FP-011:

- Australian Industry Group
 - Australian Museum
 - Chamber of Commerce & Industry Queensland
 - CSIRO Manufacturing and Materials Technology
 - Engineers Australia
 - Fire Protection Association Australia
 - National Fire Industry Association
 - Society of Fire Protection Engineers Australasian Chapter
 - Security Providers Association of Australia
-

This Standard was issued in draft form for comment as DP AS 6183.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To remain in their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

Fire protection equipment—Carbon dioxide extinguishing systems for use on premises—Design and installation (ISO 6183:2009, MOD)

Originally in part as AS 4214.1—1995 and AS 4214.3—1995.
Previous edition part of AS 4214—2002.
Part of AS 4214—2002 revised and redesignated as AS 6183—2011.

COPYRIGHT

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

Published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 978 0 7337 9806 1

PREFACE

This Standard was prepared by the Standards Australia Committee FP-011, Special Hazard Fire Protection Systems, to supersede the requirements for carbon dioxide extinguishing systems from AS 4214—2002, *Gaseous fire extinguishing systems*.

This Standard is an adoption with national modifications and has been reproduced from ISO 6183:2009, *Fire protection equipment—Carbon dioxide extinguishing systems for use on premises—Design and installation*, and has been varied as indicated to take account of Australian conditions. The modifications are specified in Appendix ZZ.

As this Standard is reproduced from an international standard, the following applies:

- (a) Its number appears on the cover and title page while the international standard number appears only on the cover.
- (b) In the source text ‘this International Standard’ should read ‘this Australian Standard’.
- (c) A full point substitutes for a comma when referring to a decimal marker.

Detailed requirements for the design and installation of marine CO₂ systems are provided in Annex ZB (Marine) of AS ISO 14520.1 *Gaseous fire-extinguishing systems—Physical properties and system design, Part 1: General requirements (ISO 14520-1:2006, MOD)*.

The terms ‘normative’ and ‘informative’ are used to define the application of the annex or appendix to which they apply. A normative annex or appendix is an integral part of a Standard, whereas an informative annex is only for information and guidance.

CONTENTS

	<i>Page</i>
1	Scope 1
2	Normative references 1
3	Terms and definitions..... 1
4	Use and limitations 4
4.1	General..... 4
4.2	Uses for carbon dioxide systems 4
4.3	Limitations for carbon dioxide systems..... 5
4.4	Temperature limitations 5
5	Safety 5
5.1	Hazard to personnel 5
5.2	Safety precautions..... 5
5.2.1	Normally occupied and normally unoccupied areas 5
5.2.2	Warning notices for occupiable areas..... 6
5.2.3	Warning notices for unoccupiable areas 9
5.3	Electrical hazards 9
5.4	Electrical earthing..... 10
5.5	Electrostatic discharge 10
6	System design..... 10
6.1	General..... 10
6.1.1	Specifications..... 11
6.1.2	Working documents 11
6.2	Carbon dioxide supply 11
6.2.1	Quality..... 11
6.2.2	Quantity 11
6.2.3	Container arrangement 12
6.2.4	Storage containers 12
6.3	Distribution..... 14
6.3.1	General..... 14
6.3.2	Piping 14
6.3.3	Fittings 15
6.3.4	Pipe and valve supports 15
6.3.5	Valves..... 16
6.3.6	Nozzles..... 16
6.4	Enclosures (total flooding) 17
6.4.1	Structural strength..... 17
6.4.2	Loss through openings..... 17
6.4.3	Ventilation systems..... 18
6.5	Detection, actuation and control systems 18
6.5.1	General..... 18
6.5.2	Shut down of plant and equipment..... 18
6.5.3	Automatic detection 18
6.5.4	Operating devices..... 18
6.5.5	Control equipment..... 19
6.5.6	Operating alarms and indicators..... 20
7	Carbon dioxide flow and concentration calculations 20
7.1	General..... 20

7.2	System flow calculations	20
7.2.1	General	20
7.2.2	Friction losses	20
7.2.3	Pressure drop	20
7.2.4	Valves and fittings	21
7.2.5	As-installed calculations	21
7.2.6	Specific requirements	21
7.3	Carbon dioxide concentration requirements	22
7.3.1	Flame extinguishment	22
7.3.2	Determination of the design concentration	22
7.3.3	Inerting	22
7.4	Total flooding quantity	23
7.4.1	General	23
7.4.2	Design quantity	23
7.4.3	K_B factor	23
7.5	Design of local application systems	25
7.5.1	General	25
7.5.2	Carbon dioxide requirements	25
7.5.3	Rate by area method	26
7.5.4	Rate by volume method	27
7.6	Duration of protection	29
7.7	System performance	29
7.7.1	Discharge time	29
7.7.2	Extended discharge	29
8	Commissioning and acceptance	30
8.1	General	30
8.2	Tests	30
8.2.1	General	30
8.2.2	Enclosure check	30
8.2.3	Review of mechanical components	30
8.2.4	Review of enclosure integrity	31
8.2.5	Review of electrical components	31
8.2.6	Preliminary functional tests	32
8.2.7	System functional operational test	32
8.2.8	Remote monitoring operations (if applicable)	33
8.2.9	Control panel primary power source	33
8.2.10	Completion of functional tests	33
8.3	Completion certificate and documentation	33
9	Inspection, maintenance, testing and training	33
9.1	General	33
9.2	Inspection	33
9.2.1	General	33
9.2.2	Container	34
9.2.3	Hose	34
9.2.4	Enclosure	34
9.3	Maintenance	34
9.3.1	General	34
9.3.2	User programme of inspection	34
9.3.3	Service schedule	35
9.4	Training	35
Annex A (normative)	Working documents	36
Annex B (normative)	Carbon dioxide system pipe and orifice size determination	38
Annex C (informative)	System performance verification	46
Annex D (informative)	General information on carbon dioxide	47
Annex E (informative)	Examples of calculations	52
Appendix ZZ (Normative)	VARIATIONS TO ISO 6183:2009 FOR AUSTRALIA	55

INTRODUCTION

This International Standard is intended for use by those concerned with purchasing, designing, installing, testing, inspecting, approving, operating and maintaining carbon dioxide (CO₂) extinguishing systems.

This International Standard applies only to carbon dioxide fixed fire-extinguishing systems in buildings and other premises on land. Although the general principles could well apply to other uses (e.g. maritime use), for these other uses additional considerations will almost certainly have to be taken into account and the application of the requirements given in this International Standard is therefore unlikely to be fully satisfactory. General information about carbon dioxide as an extinguishing medium is given in Annex D. This can be useful background information for those unfamiliar with the characteristics of this medium.

It has been assumed in the preparation of ISO 6183 that the execution of its provisions will be entrusted to those persons appropriately qualified and experienced in the specification, design, installation, testing, approval, inspection, operation and maintenance of systems and equipment, for whose guidance it has been prepared, and who can be expected to exercise a duty of care to avoid unnecessary release of carbon dioxide. New requirements to minimize the need to release carbon dioxide during testing and commissioning procedures are included in this edition. These are linked to the inclusion of enclosure integrity testing.

Carbon dioxide has for many years been a recognized effective medium for the extinction of flammable liquid fires as well as fires in the presence of electrical and ordinary Class A hazards. Nevertheless, it ought not be forgotten, in the planning of comprehensive schemes, that there could be hazards for which this media is not suitable, or that in certain circumstances or situations there can be dangers in its use requiring special precautions.

The use of carbon dioxide is no longer recommended for total flooding of occupied areas. ISO 14520 provides requirements for other extinguishing agents that can be more appropriately used in these areas.

It is important that the fire protection of a building or plant be considered as a whole. Carbon dioxide systems form only a part, though an important part, of the available facilities. It cannot be assumed that their adoption necessarily removes the need to consider supplementary measures, such as the provision of portable fire extinguishers or other mobile appliances for first aid or emergency use, or to deal with special hazards.

Advice on these matters can be obtained from the appropriate manufacturer of the carbon dioxide or the extinguishing system. Information can also be sought from the appropriate fire authority, the health and safety authorities and insurers. In addition, reference will need to be made, as necessary, to other national standards and statutory regulations of the particular country.

It is essential that firefighting equipment be carefully maintained to ensure instant readiness when required. Routine maintenance is liable to be overlooked or given insufficient attention by the owner of the system. It is, however, neglected at peril to the lives of occupants of the premises and at the risk of crippling financial loss. The importance of maintenance cannot be too highly emphasized. Inspection — preferably by a third party — should include an evaluation concluding that the extinguishing system continues to provide adequate protection for the risk (protected zones as well as state of the art can change over time).

AUSTRALIAN STANDARD

Fire protection equipment—Carbon dioxide extinguishing systems for use on premises—Design and installation (ISO 6183:2009, MOD)**1 Scope**

This International Standard specifies requirements and gives recommendations for the design, installation, testing, maintenance and safety of fixed carbon dioxide firefighting systems in buildings, plants or other structures. It is not applicable to extinguishing systems on ships, in aircraft, on vehicles and mobile fire appliances, or to below-ground systems in the mining industry; nor does it apply to carbon dioxide pre-inerting systems.

Design of systems where unclosable opening(s) exceed a specified area and where the opening(s) can be subject to the effect of wind is not specified, although general guidance on the procedure to be followed in such cases is given (see 7.4.3.2).

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 1182:2002, *Reaction to fire tests for building products — Non-combustibility test*

ISO 3864-1:2002, *Graphical symbols — Safety colours and safety signs — Part 1: Design principles for safety signs in workplaces and public areas*

ISO 5923:1989, *Fire protection — Fire extinguishing media — Carbon dioxide*

ISO 14520-1:2006, *Gaseous fire extinguishing systems — Physical properties and system design — Part 1: General requirements*

ISO 16003:2008, *Components for fire extinguishing systems using gas — Requirements and test methods — Container valve assemblies and their actuators; selector valves and their actuators; nozzles; flexible and rigid connectors; and check valves and non-return valves*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

approved
acceptable to a relevant **authority** (3.2)

NOTE — In determining the acceptability of installations or procedures, equipment or materials, the authority could base acceptance on compliance with the appropriate standards.