

Australian Standard™

**Communication networks and systems
in substations
Part 2: Glossary**

STANDARDS
Australia



This Australian Standard was prepared by Committee EL-050, Power System Control and Communication. It was approved on behalf of the Council of Standards Australia on 15 August 2005.
This Standard was published on 20 September 2005.

The following are represented on Committee EL-050:

Australian Electrical and Electronic Manufacturers Association
Commerce Queensland
Energy Networks Association
Engineers Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia, GPO Box 476, Sydney, NSW 2001.

This Standard was issued in draft form for comment as DR 050202.

Australian Standard™

**Communication networks and systems
in substations
Part 2: Glossary**

First published as AS 61850.2—2005.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia

ISBN 0 7337 6850 4

PREFACE

This Standard was prepared by the Standards Australia Committee EL-050, Power System Control and Communication.

The objective of this Standard is to provide users and manufacturers of substation automation equipment with a glossary of terms in order to obtain consistency in their usage in Australia.

This Standard is identical with, and has been reproduced from IEC/TR 61850-2, Ed.1 (2003), *Communication networks and systems in substations – Part 2: Glossary*.

This Standard is Part of *Communication networks and systems in substations*. The series consists of the following:

- Part 1: Introduction and overview
- Part 2: Glossary (this Standard)
- Part 3: General requirements
- Part 4: System and project management
- Part 5: Communication requirements for functions and device models
- Part 6: Configuration description language for communication in electrical substations related to IEDs
- Part 7.1: Basic communication structure for substation and feeder equipment—Principles and models
- Part 7.2: Basic communication structure for substation and feeder equipment—Abstract communication service interface (ACMI)
- Part 7.3: Basic communication structure for substation and feeder equipment—Common data classes
- Part 7.4: Basic communication structure for substation and feeder equipment—Compatible logical node classes and data classes
- Part 8.1: Specific communication service mapping (SCSM)—Mappings to MMS (ISO/IEC 9505-1 and ISO/IEC 9506-2) and to ISO/IEC 8802-3
- Part 9.1: Specific communication service mapping (SCSM)—Sampled values over serial unidirectional multidrop point to point link
- Part 9.2: Specific communication service mapping (SCSM)—Sampled values over ISO/IEC 8802-3

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text 'IEC/TR 61850-2' should read 'AS 61850.2'.
- (c) A full point should be substituted for a comma when referring to a decimal marker.
- (d) Any French text on figures should be ignored.

CONTENTS

	<i>Page</i>
1 Scope	1
2 Terms and definitions	1
3 Abbreviations	21
Bibliography	34

Currently in preview, click buy full vers.

Currently in preview, click buy full vers.

STANDARDS AUSTRALIA

Australian Standard**Communication networks and systems in substations
Part 2: Glossary**

1 Scope

This part of the IEC 61850 series applies to Substation Automation Systems (SAS). It defines the communication between intelligent electronic devices (IEDs) in the substation and the related system requirements.

This part of the IEC 61850 series contains the glossary of specific terminology and definitions used in the context of Substation Automation Systems within the various parts of the standard.

2 Terms and definitions

The following terms and definitions apply to all parts of the IEC 61850 series¹.

2.1.1**abstract communication service interface**

virtual interface to an IED providing abstract information modelling methods for logical devices, logical nodes, data, and data attributes, and communication services for example connection, variable access, unsolicited data transfer, device control and file transfer services, independent of the actual communication stack and profiles used

[IEC 61850-1]

2.1.2**access point**

communication access point to an IED. This may be a serial port, an Ethernet connection, or a client or server address dependent on the stack being used. Each access point of an IED to a communication bus is uniquely identified. Each server has only one, logical, access point

[IEC 61850-6]

2.1.3**application layer**

layer 7 in the OSI reference model for Open Systems Interconnection comprising the interface between the OSI environment and the IED's or user's application

[ISO/IEC 7498-1]

2.1.4**association**

conveyance path established between a client and a server for the exchange of messages

[IEC 61850-7-1]

¹ References to other standards given below certain definitions indicate that the term is either described or used in the cited standard. All references are listed in the bibliography.