

AS 61869.3:2021



STANDARDS
Australia



Instrument transformers

**Part 3: Additional requirements for inductive voltage transformers
(IEC 61869-3:2011 (ED.1.0) MOD)**

currently in preview, click buy full version

AS 61869.3:2021

This Australian Standard® was prepared by EL-013, Measurement And Protection Transformers. It was approved on behalf of the Council of Standards Australia on 15 February 2021.

This Standard was published on 26 February 2021.

The following are represented on Committee EL-013:

Australian Industry Group
Energy Networks Australia
Engineers Australia
National Measurement Institute
University of South Australia

This Standard was issued in draft form for comment as DR AS 61869.3:2020.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

ISBN 978 1 76113 227 8

Instrument transformers

Part 3: Additional requirements for inductive voltage transformers (IEC 61869-3:2011 (ED.1.0) MOD)

Originated as part of AS C45—1928.
Previous edition AS 60044.2—2006.
Revised and redesignated as AS 61869.3:2021.



© IEC 2021 — All rights reserved
© Standards Australia Limited 2021

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of either the IEC or the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth). If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please see the contact details on the back cover or the contact us page of the website for further information.

Preface

This Standard was prepared by the Standards Australia Committee EL-013, Measurement and Protection Transformers, to supersede AS 60044.2—2007, *Instrument transformers, Part 2: Inductive voltage transformers (IEC 60044-2:Ed.1.2 (2003) MOD)*.

The objective of this document applies to new inductive voltage transformers for use with electrical measuring instruments and electrical protective devices at frequencies from 15 Hz to 100 Hz.

Requirements specific to three-phase voltage transformers are not included in this document but, so far as they are relevant, the requirements in Clauses 4 to 10 apply to these transformers.

This document is an adoption with national modifications, and has been reproduced from IEC 61869-3:2011, *Instrument transformers — Part 3: Additional requirements for inductive voltage transformers*. The modifications are additional requirements and are set out in [Appendix ZZ](#), which has been added at the end of the source text.

[Appendix ZZ](#) lists the variations to IEC 61869-3:2011 (ED. 1.0) for the application of this document in Australia.

As this document has been reproduced from an International Standard, the following applies:

- (a) In the source text “this part of 61869” should read “this document”.
- (b) A full point substitutes for a comma when referring to a decimal number.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

NOTES

Currently in preview, click buy full version

CONTENTS

FOREWORD.....	4
1 Scope.....	7
2 Normative references.....	7
3 Terms, definitions and abbreviations.....	7
3.1 General definitions.....	7
3.2 Definitions related to dielectric ratings.....	8
3.4 Definitions related to accuracy.....	9
3.5 Definitions related to other ratings.....	9
3.7 Index of abbreviation.....	9
5 Ratings.....	9
5.3 Rated insulation levels.....	10
5.5 Rated output.....	10
5.5.301 Rated output values.....	10
5.5.302 Rated thermal limiting output.....	10
5.5.303 Rated output values for residual voltage winding.....	10
5.5.304 Rated thermal limiting output for residual voltage windings.....	10
5.6 Rated accuracy class.....	11
5.6.301 Accuracy requirements for single-phase inductive measuring voltage transformers.....	11
5.6.302 Additional requirements for single-phase inductive protective voltage transformers.....	12
5.301 Standard values of rated voltages.....	13
5.301.1 Rated primary voltages.....	13
5.301.2 Rated secondary voltages.....	13
5.301.3 Rated voltages for residual voltage windings.....	13
5.302 Standard values of rated voltage factor.....	14
6 Design and construction.....	15
6.4 Requirements for temperature rise of parts and components.....	15
6.4.1 General.....	15
6.13 Markings.....	15
6.13.301 Terminal markings.....	15
6.13.302 Rating plate markings.....	19
6.301 Short-circuit withstand capability.....	20
7 Tests.....	20
7.1 General.....	20
7.1.2 List of tests.....	20
7.2 Type tests.....	21
7.2.2 Temperature-rise test.....	21
7.2.3 Impulse voltage withstand test on primary terminals.....	22
7.2.5 Electromagnetic Compatibility (EMC) tests.....	23
7.2.6 Test for accuracy.....	23
7.2.301 Short-circuit withstand capability test.....	23
7.3 Routine tests.....	24
7.3.1 Power-frequency voltage withstand tests on primary terminals.....	24
7.3.2 Partial discharge measurements.....	27
7.3.5 Test for accuracy.....	27

7.4	Special tests	27
7.4.3	Measurement of capacitance and dielectric dissipation factor	27
7.4.6	Internal arc fault test	28
Figure 301	– Single-phase transformer with fully insulated terminals and a single secondary	16
Figure 302	– Single-phase transformer with a neutral primary terminal with reduced insulation and a single secondary	16
Figure 303	– Three-phase assembly with a single secondary	16
Figure 304	– Single-phase transformer with two secondaries	17
Figure 305	– Three-phase assembly with two secondaries	17
Figure 306	– Single-phase transformer with one multi-tap secondary	17
Figure 307	– Three-phase assembly with one multi-tap secondary	17
Figure 308	– Single-phase transformer with two multi-tap secondaries	18
Figure 309	– Single-phase transformer with one residual voltage winding	18
Figure 310	– Three-phase transformer with one residual voltage winding	18
Figure 311	– Example of a typical rating plate	20
Figure 312	– Example of a rating plate with typical data	20
Figure 313	– Common mode (separate source) test voltage application	26
Figure 314	– Differential mode (induced) test voltage application – Primary excitation	26
Figure 315	– Differential mode (induced) test voltage application – Secondary excitation	27
Table 301	– Limits of voltage error and phase displacement for measuring voltage transformers	11
Table 302	– Limits of voltage error and phase displacement for protective voltage transformers	12
Table 303	– Rated voltages for secondary windings intended to produce a residual voltage	14
Table 10	– List of tests	21
Table 305	– Burden ranges for accuracy tests	23

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INSTRUMENT TRANSFORMERS –

Part 3: Additional requirements for inductive voltage transformers

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This International Standard IEC 61869-3 has been prepared by subcommittee 38: Instrument transformers

This standard replaces IEC 60044-2: Inductive Voltage Transformers.

The text of this standard is based on the following documents:

FDIS	Report on voting
38/410/FDIS	38/413/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This standard is Part 3 of IEC 61869, published under the general title *Instrument transformers*.

This part 3 is to be read in conjunction with, and is based on, IEC 61869-1, *General Requirements* - first edition (2007)- however the reader is encouraged to use its most recent edition.

This Part 3 follows the structure of IEC 61869-1 and supplements or modifies its corresponding clauses.

When a particular clause/subclause of Part 1 is not mentioned in this Part 3, that clause/subclause applies as far as is reasonable. When this standard states “addition”, “modification” or “replacement”, the relevant text in Part 1 is to be adapted accordingly.

For additional clauses, subclauses, figures, tables, annexes or notes, the following numbering system is used:

- clauses, subclauses, tables, figures and notes that are numbered starting from 301 are additional to those in Part 1;
- additional annexes are lettered 3A, 3B, etc.

An overview of the planned set of standards at the date of publication of this document is given below. The updated list of standards issued by IEC TC 8 is available at the website: www.iec.ch.

PRODUCT FAMILY STANDARDS		PRODUCT STANDARD	PRODUCTS	OLD STANDARD
61869-1 GENERAL REQUIREMENTS FOR INSTRUMENT TRANSFORMERS		61869-2	ADDITIONAL REQUIREMENTS FOR CURRENT TRANSFORMERS	60044-1 60044-6
		61869-3	ADDITIONAL REQUIREMENTS FOR INDUCTIVE VOLTAGE TRANSFORMERS	60044-2
		61869-4	ADDITIONAL REQUIREMENTS FOR COMBINED TRANSFORMERS	60044-3
		61869-5	ADDITIONAL REQUIREMENTS FOR CAPACITIVE VOLTAGE TRANSFORMERS	60044-5
	61869-6 ADDITIONAL GENERAL REQUIREMENT FOR ELECTRONIC INSTRUMENT TRANSFORMERS AND LOW POWER STAND ALONE SENSORS	61869-7	ADDITIONAL REQUIREMENTS FOR ELECTRONIC VOLTAGE TRANSFORMERS	60044-7
		61869-8	ADDITIONAL REQUIREMENTS FOR ELECTRONIC CURRENT TRANSFORMERS	60044-8
		61869-9	DIGITAL INTERFACE FOR INSTRUMENT TRANSFORMERS	
		61869-10	ADDITIONAL REQUIREMENTS FOR LOW-POWER STAND-ALONE CURRENT SENSORS	
		61869-11	ADDITIONAL REQUIREMENTS FOR LOW POWER STAND ALONE VOLTAGE SENSORS	60044-7
		61869-12	ADDITIONAL REQUIREMENTS FOR COMBINED ELECTRONIC INSTRUMENT TRANSFORMER OR COMBINED STAND ALONE SENSORS	
		61869-13	STAND ALONE MERGING UNIT	

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INSTRUMENT TRANSFORMERS –

Part 3: Additional requirements for inductive voltage transformers

1 Scope

This part of IEC 61869 applies to new inductive voltage transformers for use with electrical measuring instruments and electrical protective devices at frequencies from 15 Hz to 100 Hz.

NOTE 301 Requirements specific to three-phase voltage transformers are not included in this standard but, so far as they are relevant, the requirements in clauses 4 to 10 apply to these transformers and a few references to them are included in those clauses (e.g. see 3.1.303, 5.301.1, 5.301.2, 5.5.301, 6.13.301.1 and Table 304).

All the transformers shall be suitable for measuring purposes, but, in addition, certain types may be suitable for protection purposes. Transformers for the dual purpose of measurement and protection shall comply with all clauses of this standard.

2 Normative references

Clause 2 of IEC 61869-1:2007 is applicable with the following additions:

IEC 60028, *International Standard of resistance for copper*

IEC 60038, *IEC standard voltages*

IEC 61869-1:2007, *Instrument transformers – Part 1: General requirements*

3 Terms, definitions and abbreviations

For the purposes of this document, the terms and definitions in IEC 61869-1:2007 apply with the following additions:

3.1 General definitions

3.1.301

voltage transformer

instrument transformer in which the secondary voltage, in normal conditions of use, is substantially proportional to the primary voltage and differs in phase from it by an angle which is approximately zero for an appropriate direction of the connections

[IEC 60050-321:1986, 321-03-01]

3.1.302

unearthed voltage transformer

voltage transformer which has all parts of its primary winding, including terminals, insulated from earth to a level corresponding to its rated insulation level

3.1.303

earthed voltage transformer

single-phase voltage transformer which is intended to have one end of its primary winding directly earthed or a three-phase voltage transformer which is intended to have the star-point of its primary winding directly earthed