

AS 61869.6:2021



STANDARDS
Australia



Instrument transformers

Part 6: Additional general requirements for low-power instrument transformers (IEC 61869-6:2016 (ED 1.0) MOD)

currently in preview, click buy full version

AS 61869.6:2021

This Australian Standard® was prepared by EL-013, Measurement And Protection Transformers. It was approved on behalf of the Council of Standards Australia on 11 February 2021.

This Standard was published on 26 February 2021.

The following are represented on Committee EL-013:

Australian Industry Group
Energy Networks Australia
Engineers Australia
National Measurement Institute
University of South Australia

This Standard was issued in draft form for comment as DR AS 61869.6:2020.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

ISBN 978 1 76113 219 3

Instrument transformers

Part 6: Additional general requirements for low-power instrument transformers (IEC 61869-6:2016 (ED 1.0) MOD)

First published as AS 61869.6:2021.



© IEC 2021 — All rights reserved
© Standards Australia Limited 2021

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of either the IEC or the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth). If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please see the contact details on the back cover or the contact us page of the website for further information.

Preface

This Standard was prepared by the Standards Australia Committee EL-013, Measurement and Protection Transformers.

The objective of this document is to define the errors in case of analogue or digital output.

This document covers only additional general requirements for low-power instrument transformers (LPIT) used for a.c. applications having rated frequencies from 15 Hz to 100 Hz covering MV, HV and EHV or used for d.c. applications.

This document also considers additional requirements concerning bandwidth.

This document does not cover the specification for the digital output format of instrument transformers.

This document is an adoption with national modifications, and has been reproduced from, IEC 61869-6:2016, *Instrument transformers — Part 6: Additional requirements for low-power instrument transformers*.

The modifications are additional requirements and are set out in [Appendix ZZ](#), which has been added at the end of the source text.

[Appendix ZZ](#) lists the variation to IEC 61869-6:2016 for the application of this document in Australia.

As this document has been reproduced from an International Standard, the following applies:

- (a) In the source text “this part of 61869” should read “this document”
- (b) A full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

NOTES

Currently in preview, click buy full version

CONTENTS

FOREWORD.....	6
1 Scope.....	10
2 Normative reference	10
3 Terms and definitions	13
3.1 General terms and definitions	13
3.2 Terms and definitions related to dielectric ratings and voltages.....	17
3.3 Terms and definitions related to current ratings	17
3.4 Terms and definitions related to accuracy	21
3.5 Terms and definitions related to other ratings.....	26
3.7 Index of abbreviations and symbols	26
4 Normal and special service conditions.....	28
4.2 Normal service conditions	28
4.2.3 Vibrations or earth tremors	28
4.2.601 Partially outdoor LPIT	28
5 Ratings.....	28
5.3 Rated insulation levels and voltages	28
5.3.5 Insulation requirements for secondary terminals	28
5.3.601 Rated auxiliary power supply voltage (U_{ar}).....	28
5.4 Rated frequency.....	29
5.5 Rated output	29
5.5.601 Rated burden (R_{br})	29
5.5.602 Standard values for the rated delay time (t_{dr})	29
5.6 Rated accuracy class	30
6 Design and construction	30
6.7 Mechanical requirements.....	30
6.11 Electromagnetic compatibility (EMC).....	30
6.11.3 Requirements for immunity.....	30
6.11.4 Requirement for transmitted overvoltages.....	32
6.11.601 Emission requirements.....	32
6.13 Markings.....	33
6.601 Requirements for optical transmitting system and optical output link.....	33
6.601.1 General	33
6.601.2 Optical connectors	33
6.601.3 Fibre optic terminal box.....	33
6.601.4 Total cable length	33
6.602 Requirements for electrical transmitting system and electrical wires for output link	33
6.602.1 Connectors	33
6.602.2 Earthing of the output cable.....	34
6.603 Signal-to-noise ratio	34
6.604 Failure detection and maintenance announcement.....	35
6.605 Operability	35
6.606 Reliability and dependability	35
6.607 Vibrations	35
7 Tests.....	36
7.1 General.....	36

7.1.2	List of tests	36
7.2	Type tests	37
7.2.1	General	37
7.2.2	Temperature-rise test.....	37
7.2.3	Impulse voltage withstand test on primary terminals.....	37
7.2.5	Electromagnetic compatibility (EMC) tests	37
7.2.6	Test for accuracy	41
7.2.601	Low-voltage component voltage withstand test	43
7.3	Routine tests.....	44
7.3.1	Power-frequency voltage withstand tests on primary terminals	44
7.3.4	Power-frequency voltage withstand tests on secondary terminals.....	45
7.3.5	Test for accuracy	45
7.3.601	Power-frequency voltage withstand test for low-voltage components	45
7.4	Special tests	45
7.4.601	Vibration tests.....	45
601	Information to be given with enquiries, tenders and orders.....	46
601.1	Designation.....	46
601.2	Dependability.....	46
Annex 6A (normative) LPIT frequency response and accuracy requirements for harmonics.....		47
6A.1	General.....	47
6A.2	Requirements for noise and distortion.....	47
6A.3	Anti-aliasing filter requirements for LPIT using digital data processing.....	47
6A.4	LPIT accuracy requirements for harmonics and low frequencies	49
6A.4.1	General	49
6A.4.2	Measuring accuracy classes.....	49
6A.4.3	Accuracy class extension for quality metering and low bandwidth d.c. applications	50
6A.4.4	Protective accuracy classes	51
6A.4.5	Special high bandwidth protection accuracy class.....	51
6A.4.6	Special accuracy classes for d.c. coupled low-power voltage transformer	52
6A.5	Tests for accuracy versus harmonics and low frequencies.....	52
6A.6	Test arrangement and test circuit.....	53
6A.6.1	Test for accuracy for harmonics and low frequencies	53
6A.6.2	Type test for proper anti-aliasing	53
Annex 6B (informative) Transient performances of low-power current transformers		55
6B.1	General.....	55
6B.2	Short-circuit currents in power systems.....	55
6B.3	Conventional current transformer equivalent circuit.....	58
6B.4	Types of current transformers.....	60
6B.4.1	Types of conventional CTs	60
6B.4.2	Types of low-power current transformers	61
6B.5	Transient performance of current transformers.....	62
6B.5.1	Transient performance of conventional current transformers	62
6B.5.2	Transient performance of low-power current transformers	63
6B.6	Summary	64
Annex 6C (informative) Transient performances of low-power voltage transformers.....		65
6C.1	Overview	65

6C.2	General.....	65
6C.2.1	Defining primary and secondary voltages.....	65
6C.2.2	Normal service conditions of the network.....	65
6C.2.3	Abnormal service conditions of the network.....	66
6C.2.4	Rated secondary voltages.....	66
6C.2.5	Steady-state conditions.....	66
6C.3	Transient conditions.....	66
6C.3.1	Theoretical considerations.....	66
6C.3.2	Definition of transient error.....	73
6C.3.3	Test of transient performance.....	73
Annex 6D	(informative) Test circuits.....	78
6D.1	Test circuits for accuracy measurements in steady state for low-power current transformers.....	78
6D.2	Test circuits for accuracy measurements in steady state for low-power voltage transformers.....	81
Annex 6E	(informative) Graph explaining the accuracy requirements for multi-purpose low-power current transformer.....	84
Bibliography	85
Figure 601	– General block diagram of a single-phase LPIT.....	10
Figure 602	– Primary time constant T_p	19
Figure 603	– Duty cycles, single energization.....	20
Figure 604	– Duty cycles, double energization.....	21
Figure 605	– Examples of subassembly subjected to EMC tests – Usual structure used in HV AIS applications.....	38
Figure 606	– Examples of subassembly subjected to EMC tests – Usual structure used in MV applications.....	39
Figure 607	– Examples of subassembly subjected to EMC tests – Usual structure used in HV GIS applications.....	39
Figure 608	– Temperature cycle accuracy test.....	42
Figure 6A.1	– Digital data acquisition system example.....	48
Figure 6A.2	– Frequency response mask for metering accuracy class 1 ($f_r = 60$ Hz, $f_s = 4\ 800$ Hz).....	49
Figure 6B.1	– Illustration of a fault in a power system.....	56
Figure 6B.2	– Short-circuit current a.c. and d.c. components.....	56
Figure 6B.3	– Symmetric fault current.....	57
Figure 6B.4	– Asymmetric fault current.....	57
Figure 6B.5	– Equivalent electrical circuit of a conventional CT.....	58
Figure 6B.6	– Flux-current characteristic for a conventional CT without remanence representation.....	59
Figure 6B.7	– Representation of hysteresis and remanent flux for a conventional CT.....	60
Figure 6B.8	– Comparison of flux-current characteristics for gapped and gapless CTs.....	62
Figure 6B.9	– Secondary current distorted due to the CT saturation.....	63
Figure 6B.10	– AC component for non-saturated and saturated CT.....	63
Figure 6C.1	– Schematic diagram explaining the trapped charge phenomena.....	69
Figure 6C.2	– Voltages during trapped charges phenomena.....	70
Figure 6C.3	– Modelization example of a simplified low-power voltage transformer.....	72

Figure 6C.4 – Testing arrangement for short time constant	76
Figure 6C.5 – Testing arrangement for long time constant	77
Figure 6C.6 – Typical waveform of $e(t)$ during test	77
Figure 6D.1 – Test circuit for analogue accuracy measurements in steady state	78
Figure 6D.2 – Test circuit for analogue accuracy measurements in steady state (alternative solution)	79
Figure 6D.3 – Test circuit for digital accuracy measurements in steady state	80
Figure 6D.4 – Test circuit for analogue accuracy measurements in steady state	81
Figure 6D.5 – Test circuit for analogue accuracy measurements in steady state (alternative solution)	82
Figure 6D.6 – Test circuit for digital accuracy measurements in steady state	83
Figure 6E.1 – Accuracy limits of a multi-purpose low-power current transformer	84
Table 601 – Secondary terminal and low voltage component withstand capability	28
Table 602 – Immunity requirements and tests	30
Table 603 – Connectors	34
Table 10 – List of tests	36
Table 6A.1 – Anti-aliasing filter	48
Table 6A.2 – Measuring accuracy classes	50
Table 6A.3 – Accuracy classes extension for quality metering and low bandwidth d.c. applications	50
Table 6A.4 – Accuracy classes extension for high bandwidth d.c. applications	51
Table 6A.5 – Protective accuracy classes	51
Table 6A.6 – Accuracy classes for special high bandwidth protection	52
Table 6A.7 – Accuracy classes for special d.c. coupled low-power voltage transformers	52
Table 6A.8 – Accuracy classes for harmonics	53
Table 6B.1 – Protective CTs	61
Table 6C.1 – Primary short circuit	71
Table 6C.2 – Trapped charges	71
Table 6C.3 – Limits of instantaneous voltage error for protective electronic voltage transformers in case of trapped charges reclose	71

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INSTRUMENT TRANSFORMERS –

**Part 6: Additional general requirements
for low-power instrument transformers**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use, and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, also issue IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61869-6 has been prepared by IEC technical committee 38: Instrument transformers.

This first edition of IEC 61869-6 cancels and replaces the relevant parts of IEC 60044-7, published in 1999, and of IEC 60044-8, published in 2002¹.

¹ IEC 60044-7 and IEC 60044-8 will eventually be replaced by the IEC 61869 series, but until all the relevant parts will be published, these two standards are still in force.

The text of this standard is based on the following documents:

FDIS	Report on voting
38/501/FDIS	38/507/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61869 series, published under the general title *Instrument transformers*, can be found on the IEC website.

This Part 6 is to be read in conjunction with, and is based on, IEC 61869-1:2007, *General Requirements* – however, the reader is encouraged to use its most recent edition.

This Part 6 follows the structure of IEC 61869-1:2007 and supplements or modifies its corresponding clauses.

When a particular clause/subclause of Part 1 is not mentioned in this Part 6, that clause/subclause applies. When this standard states “addition”, “modification” or “replacement”, the relevant text in Part 1 is to be adapted accordingly.

For additional clauses, subclauses, figures, tables, annexes or notes, the following numbering system is used:

- clauses, subclauses, tables, figures and notes that are numbered starting from 601 are additional to those in Part 1;
- additional annexes are lettered 6A, 6B, etc.

An overview of the planned set of standards at the date of publication of this document is given below. The updated list of standards issued by IEC TC 38 is available at the website: www.iec.ch.

PRODUCT FAMILY STANDARDS		PRODUCT STANDARD IEC	PRODUCTS	OLD STANDARD IEC
IEC 61869-1 GENERAL REQUIREMENTS FOR INSTRUMENT TRANSFORMERS		61869-2	ADDITIONAL REQUIREMENTS FOR CURRENT TRANSFORMERS	60044-1 60044-6
		61869-3	ADDITIONAL REQUIREMENTS FOR INDUCTIVE VOLTAGE TRANSFORMERS	60044-2
		61869-4	ADDITIONAL REQUIREMENTS FOR COMBINED TRANSFORMERS	60044-3
		61869-5	ADDITIONAL REQUIREMENTS FOR CAPACITOR VOLTAGE TRANSFORMERS	60044-5
	IEC 61869-6 ADDITIONAL GENERAL REQUIREMENTS FOR LOW-POWER INSTRUMENT TRANSFORMERS	61869-7	ADDITIONAL REQUIREMENTS FOR ELECTRONIC VOLTAGE TRANSFORMERS	60044-7
		61869-8	ADDITIONAL REQUIREMENTS FOR ELECTRONIC CURRENT TRANSFORMERS	60044-8
		61869-9	DIGITAL INTERFACE FOR INSTRUMENT TRANSFORMERS	
		61869-10	ADDITIONAL REQUIREMENTS FOR LOW-POWER PASSIVE CURRENT TRANSFORMERS	
		61869-11	ADDITIONAL REQUIREMENTS FOR LOW-POWER PASSIVE VOLTAGE TRANSFORMERS	60044-7
		61869-12	ADDITIONAL REQUIREMENTS FOR COMBINED ELECTRONIC INSTRUMENT TRANSFORMER OR COMBINED PASSIVE TRANSFORMERS	
		61869-13	STAND ALONE MERGING UNIT	
		61869-14	ADDITIONAL REQUIREMENTS FOR CURRENT TRANSFORMERS FOR DC APPLICATIONS	
		61869-15	ADDITIONAL REQUIREMENTS FOR DC VOLTAGE TRANSFORMERS FOR DC APPLICATIONS	

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INSTRUMENT TRANSFORMERS –

Part 6: Additional general requirements for low-power instrument transformers

1 Scope

This part of IEC 61869 is a product family standard and covers only additional general requirements for low-power instrument transformers (LPIT) used for a.c. applications having rated frequencies from 15 Hz to 100 Hz covering MV, HV and EHV or used for d.c. applications. This product standard is based on IEC 61869-1:2007, in addition to the relevant product specific standard.

This part of IEC 61869 does not cover the specification for the digital output format of instrument transformers.


This part of IEC 61869 defines the errors in case of analogue or digital output. The other characteristics of the digital interface for instrument transformers are standardised in IEC 61869-9 as an application of the standards, the IEC 61850 series, which details layered substation communication architecture.

This part of IEC 61869 considers additional requirements concerning bandwidth. The accuracy requirements on harmonics and requirements for the anti-aliasing filter are given in the normative Annex 6A.4.

The general block diagram of single-phase LPITs is given in Figure 601.

According to the technology, it is not absolutely necessary that all parts described in Figure 601 are included in the instrument transformer.

As an example, for low-power passive transformers (LPITs without active electronic components) the blocks are composed only with passive components and there is no power supply.



IEC

Figure 601 – General block diagram of a single-phase LPIT

2 Normative reference

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.