

Australian Standard™

**Electricity metering equipment (ac)—
Particular requirements**

**Part 23: Static meters for reactive
energy (classes 2 and 3)**

STANDARDS
Australia



This Australian Standard was prepared by Committee EL-011, Electricity Metering Equipment. It was approved on behalf of the Council of Standards Australia on 19 January 2006.
This Standard was published on 10 February 2006.

The following are represented on Committee EL-011:

Australian Chamber of Commerce and Industry
Australian Electrical and Electronic Manufacturers Association
Electrical Regulatory Authorities Council
Electricity Engineers Association (New Zealand)
Energy Networks Association
Engineers Australia
Ministry of Economic Development (New Zealand)
NEMMCO
National Measurement Institute

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia, GPO Box 476, Sydney, NSW 2001.

This Standard was issued in draft form for comment as DR 05140.

Australian Standard™

**Electricity metering equipment (ac)—
Particular requirements**

**Part 23: Static meters for reactive
energy (classes 2 and 3)**

First published as AS 62053.23—2006.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia

ISBN 0 7337 7243 9

PREFACE

This Standard was prepared by the joint Standards Australia/Standards New Zealand Committee EL-011, Electricity Metering Equipment. After consultation with stakeholders in both countries, Standards Australia and Standards New Zealand decided to develop this Standard as an Australian, rather than an Australian/New Zealand Standard.

The objective of this Standard is to provide electricity utilities and manufacturers with requirements and tests for static electricity meters for reactive energy.

This Standard is identical with, and has been reproduced from IEC 62053-23, Ed.1.0 (2003), *Electricity metering equipment (ac)—Particular requirements—Part 23: Static meters for reactive energy (classes 2 and 3)*.

As this Standard is reproduced from an International Standard, the following apply:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text ‘this part of IEC 62053’ should read ‘AS 62053.23’.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

The terms ‘normative’ and ‘informative’ are used to define the application of the annex to which they apply. A normative annex is an integral part of a standard, whereas an informative annex is only for information and guidance.

CONTENTS

	<i>Page</i>
INTRODUCTION	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Standard electrical values	2
5 Mechanical requirements	2
6 Climatic conditions	2
7 Electrical requirements	2
7.1 Power consumption	2
7.2 Influence of short-time overcurrents	3
7.3 Influence of self-heating	4
7.4 AC voltage test	4
8 Accuracy requirements	4
8.1 Limits of error due to variation of the current	5
8.2 Limits of error due to influence quantities	5
8.3 Test of starting and no-load condition	7
8.4 Meter constant	8
8.5 Accuracy test conditions	8
8.6 Interpretation of test results	10
Annex A (normative) Test circuit diagram for d.c. component	11
Annex B (normative) Electromagnet for testing the influence of externally produced magnetic fields	13
Annex C (informative) Geometric representation of active and reactive power	14
Figure A.1 – Test circuit diagram for half-wave rectification	11
Figure A.2 – Half-wave rectified waveform	12
Figure B.1 – Electromagnet for testing the influence of externally produced magnetic fields	13
Figure C.1 – Recommended geometric representation	14
Figure C.2 – Alternative geometric representation	15
Table 1 – Power consumption in voltage circuits for single-phase and polyphase meters including the power supply	2
Table 2 – Power consumption in current circuits	3
Table 3 – Variations due to short-time overcurrents	3
Table 4 – Variations due to self-heating	4
Table 5 – AC voltage tests	4
Table 6 – Percentage error limits (single-phase meters and polyphase meters with balanced loads)	5
Table 7 – Percentage error limits (polyphase meters carrying a single-phase load, but with balanced polyphase voltages applied to voltage circuits)	5
Table 8 – Influence quantities	6
Table 9 – Starting current	8

Table 10 – Voltage and current balance	9
Table 11 – Reference conditions	10
Table 12 – Interpretation of test results	10

Currently in preview, click buy full version

INTRODUCTION

This part of IEC 62053 is to be used with relevant parts of the IEC 62052, IEC 62053 and IEC 62059 series, Electricity metering equipment:

- IEC 62052-11:2003, *Electricity metering equipment (a.c.) – General requirements, tests and test conditions – Part 11: Metering equipment*
- IEC 62053-11:2003, *Electricity metering equipment (a.c.) – Particular requirements – Part 11: Electromechanical meters for active energy (classes 0,5, 1 and 2)*
Replaces particular requirements of IEC 60521: 1988 (2nd edition)
- IEC 62053-21:2003, *Electricity metering equipment (a.c.) – Particular requirements – Part 21: Static meters for active energy (classes 1 and 2)*
Replaces particular requirements of IEC 61036: 2000 (2nd edition)
- IEC 62053-22:2003, *Electricity metering equipment (a.c.) – Particular requirements – Part 22: Static meters for active energy (classes 0,2 S and 0,5 S)*
Replaces particular requirements of IEC 60687: 1992 (2nd edition)
- IEC 62053-31:1998, *Electricity metering equipment (a.c.) – Particular requirements – Part 31: Pulse output devices for electromechanical and electronic meters (two wires only)*
- IEC 62053-61:1998, *Electricity metering equipment (a.c.) – Particular requirements – Part 61: Power consumption and voltage requirements*
- IEC 62059-11:2002, *Electricity metering equipment (a.c.) – Dependability – Part 11: General concepts*
- IEC 62059-21:2002, *Electricity metering equipment (a.c.) – Dependability – Part 21: Collection of meter dependability data from the field*

This part is a standard for type testing electricity meters. It covers the particular requirements for meters, being used indoors and outdoors. It does not deal with special implementations (such as metering-part and/or displays in separate housings).

This standard is intended to be used in conjunction with IEC 62052-11. When any requirement in this standard concerns an item already covered in IEC 62052-11, the requirements of this standard take precedence over the requirements of IEC 62052-11.

This standard distinguishes

- between accuracy class index 2 and accuracy class index 3 meters;
- between meters to use in networks equipped with or without earth fault neutralizers.

The test levels are regarded as minimum values that provide for the proper functioning of the meter under normal working conditions. For special application, other test levels might be necessary and should be agreed on between the user and the manufacturer.

Currently in preview, click buy full vers.

STANDARDS AUSTRALIA

Australian Standard

**Electricity metering equipment (ac)—Particular requirements
Part 23: Static meters for reactive energy (classes 2 and 3)**

Any table, figure or text of the international standard that is struck through is not part of this standard. Any Australian/New Zealand table, figure or text that is added is part of this standard and is identified by shading.

1 Scope

This part of IEC 62053 applies only to newly manufactured static var-hour meters of accuracy classes 2 and 3, for the measurement of alternating current electrical reactive energy in 50 Hz or 60 Hz networks and it applies to their type tests only. For practical reasons, this standard is based on a conventional definition of reactive energy for sinusoidal currents and voltages containing the fundamental frequency only.

It applies only to static var-hour meters for indoor and outdoor application consisting of a measuring element and register(s) enclosed together in a meter case. It also applies to operation indicator(s) and test output(s). If the meter has a measuring element for more than one type of energy (multi-energy meters), or when other functional elements, like maximum demand indicators, electronic tariff registers, time switches, ripple control receivers, data communication interfaces, etc. are enclosed in the meter case, then the relevant standards for these elements also apply.

It does not apply to:

- var-hour meters where the voltage across the connection terminals exceeds 600 V (line-to-line voltage for meters for polyphase systems);
- portable meters;
- data interfaces to the register of the meter;
- reference meters.

The dependability aspect is covered by the documents of the IEC 62059 series.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

References to international standards that are struck through in this clause are replaced by references to Australian or Australian/New Zealand Standards that are listed immediately thereafter and identified by shading. Any Australian or Australian/New Zealand Standard that is identical to the International Standard it replaces is identified as such.

IEC 60736:1982, *Testing equipment for electrical energy meters*

~~IEC 62052-11:2003, *Electricity metering equipment (a.c.)—General requirements, tests and test conditions—Part 11: Metering equipment*~~