



**Electricity metering equipment (ac)—
Particular requirements**

**Part 24: Static meters for reactive
energy at fundamental frequency
(classes 0.5 S, 1 S and 1)
(IEC 62053-24:2016 (ED.1.1) (MOD))**



This Australian Standard® was prepared by Committee EL-011, Electricity Metering Equipment. It was approved on behalf of the Council of Standards Australia on 29 November 2018.

This Standard was published on 21 December 2018.

The following are represented on Committee EL-011:

- Australian Chamber of Commerce and Industry
 - Australian Energy Council
 - Australian Energy Market Operator
 - Australian Industry Group
 - Consumers Federation of Australia
 - Electrical Regulatory Authorities Council
 - Energy Networks Australia
 - National Electrical and Communications Association
 - National Measurement Institute
-

This Standard was issued in draft form for comment as L2 AS 62053.24:2018.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To remain in their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard®

**Electricity metering equipment (ac)—
Particular requirements**

**Part 24: Static meters for reactive
energy at fundamental frequency
(classes 0.5 S, 1 S and 1)
(IEC 62053-24:2016 (ED.1.1) (MOD))**

First published as AS 62053.24:2018.

COPYRIGHT

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

Published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 978 1 76072 316 3

PREFACE

This Standard was prepared by the Standards Australia Committee EL-011, Electricity Metering Equipment.

The objective of this Standard is to communicate to users, and also provide manufacturers, with the particular requirements for class 1 and 0.5 reactive energy static meters intended for use in Australia.

This Standard is an adoption with national modifications and has been reproduced from IEC 62053-24:2016+AMD.1:2016 CSV (ED.1.1), *Electricity metering equipment (a.c.)—Particular requirements, Part 24: Static meters for reactive energy at fundamental frequency (classes 0, 1 S, 1 S and 1)*. ‘CSV’ stands for ‘consolidated version’ whereby IEC Amendment 1:2016 has been incorporated into the source text.

The Australian variations to the IEC source text are listed in Appendix ZZ.

This Standard is structured as follows:

- (a) Preface.
- (b) IEC 62053-24:2016, (ED.1.1) (unedited from the Contents page to the final clause of the source document).
- (c) Appendix ZZ, containing variations to IEC 62053-24:2016, (ED.1.1) for application in Australia.

As this Standard is reproduced from an International Standard, the following applies:

- (i) In the source text ‘this part of IEC 62053’ should read ‘this Australian Standard’.
- (ii) A full point should be substituted for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific standards.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the annex or appendix to which they apply. A ‘normative’ annex or appendix is an integral part of a Standard, whereas an ‘informative’ annex or appendix is for information and guidance only.

This Standard belongs to the programme of adoptions of IEC 62052 and IEC 62053 series Standards on electricity metering equipment. Existing adoptions have been updated and a new Part (AS 62053.24) in the series has been added. The current adoptions comprise the following:

AS 62052.11 (General meter requirements). Modified adoption of IEC 62052-11:2016 (ED.1.1).

AS 62052.21 (Tariff and load control). Modified adoption of IEC 62052-21:2016 (ED.1.1).

AS 62053.21 (Class 1/2 kWh). Modified adoption of IEC 62053-21:2016 (ED.1.1).

AS 62053.22 (Class 0.2/0.5 kWh). Modified adoption of IEC 62053-22:2016 (ED.1.1).

AS 62053.23 (Class 2/3 kvarh). Modified adoption of IEC 62053-23:2016 (ED.1.1).

AS 62053.24 (Class 1.0/0.5 kvarh). Modified adoption of IEC 62053-24:2016 (ED.1.1) (this Standard).

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
INTRODUCTION TO AMENDMENT 1.....	7
1 Scope.....	8
2 Normative references.....	9
3 Terms and definitions.....	9
4 Standard electrical values.....	9
5 Mechanical requirements.....	9
6 Climatic conditions.....	10
7 Electrical requirements.....	10
7.1 General.....	10
7.2 Power consumption.....	10
7.2.1 General.....	10
7.2.2 Voltage circuits.....	10
7.2.3 Current circuits.....	10
7.3 Influence of short-time overcurrents.....	11
7.4 Influence of self-heating.....	12
7.5 AC voltage test.....	12
8 Accuracy requirements.....	12
8.1 General.....	12
8.2 Limits of error due to variation of the current.....	12
8.3 Limits of error due to influence quantities.....	13
8.3.1 General.....	13
8.3.2 Tests of the influence of DC and even harmonics in the current circuit.....	15
8.3.3 Continuous magnetic induction of external origin.....	15
8.3.4 Harmonics.....	15
8.4 Test of starting and no-load condition.....	15
8.4.1 General.....	15
8.4.2 Initial start-up of the meter.....	16
8.4.3 Test of no-load condition.....	16
8.4.4 Starting.....	16
8.5 Meter constant.....	16
8.6 Accuracy test conditions.....	16
8.7 Interpretation of test results.....	18
Annex A (normative) Test circuit diagram for DC and even harmonics.....	19
Annex B (normative) Electromagnet for testing the influence of externally produced magnetic fields.....	21
Annex C (informative) Geometric representation of active and reactive power.....	22
Annex D (informative) Effect of phase displacement.....	24
D.1 Phase displacement and matching of current transformers and meters for reactive energy.....	24
Annex E (informative) Treatment of harmonics and tests for harmonics.....	25
E.1 Non-sinusoidal conditions and reactive power definition.....	25
E.2 Tests for accuracy under non-sinusoidal conditions.....	25
E.3 Fifth harmonic test.....	26

Bibliography.....	27
Figure A.1 – Test circuit diagram for half-wave rectification	19
Figure A.2 – Half-wave rectified waveform	20
Figure B.1 – Electromagnet for testing the influence of externally produced magnetic fields.....	21
Figure C.1 – Recommended geometric representation	22
Figure C.2 – Alternative geometric representation	23
Table 1 – Power consumption in voltage circuits for single-phase and polyphase meters including the power supply	10
Table 2 – Power consumption in current circuits	11
Table 3 – Variations due to short-time overcurrents	11
Table 4 – Variations due to self-heating	12
Table 6 – Percentage error limits (single-phase meters and polyphase meters with balanced loads)	13
Table 7 – Percentage error limits (polyphase meters carrying a single-phase load, but with balanced polyphase voltages applied to voltage circuits)	13
Table 8 – Influence quantities	13
Table 9 – Starting current	16
Table 10 – Voltage and current balance	17
Table 11 – Reference conditions	18
Table 12 – Interpretation of test results	18
Table D.1 – Limits of phase displacement for measuring current transformers and corresponding measurement error for reactive energy measurement	24

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

DISCLAIMER

This Consolidated version is not an official IEC Standard and has been prepared for user convenience. Only the current versions of the standard and its amendment(s) are to be considered the official documents.

This Consolidated version of IEC 62053-24 bears the edition number 1.1. It consists of the first edition (2014-06) [documents 13/1569/FDIS and 13/1578/RVD] and its amendment 1 (2016-11) [documents 13/1703/FDIS and 13/1717/RVD]. The technical content is identical to the base edition and its amendment.

This Final version does not show where the technical content is modified by amendment 1. A separate Redline version with all changes highlighted is available in this publication.

International Standard IEC 62053-24 has been prepared by IEC technical committee 13: Electrical energy measurement and control.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of IEC series 62053, under the general title *Electricity metering equipment (a.c.) – Particular requirements*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

NOTE The attention of National Committees is drawn to the fact that equipment manufacturers and testing organizations may need a transitional period following publication of a new, amended or revised IEC publication in which to make products in accordance with the new requirements and to equip themselves for conducting new or revised tests.

It is the recommendation of the committee that the content of this publication be adopted for implementation nationally not earlier than 2 years from the date of publication.

INTRODUCTION

This part of IEC 62053 is to be used with the following relevant parts of the IEC 62052, IEC 62053 and IEC 62059 series, *Electricity metering equipment*:

IEC 62052-11:2003, *Electricity metering equipment (AC) – General requirements, tests and test conditions – Part 11: Metering equipment*
Amendment 1 (2016)

IEC 62052-31:2015, *Electricity metering equipment (AC) – General requirements, tests and test conditions – Part 31: Product safety requirements and tests*

IEC 62053-21:2003, *Electricity metering equipment (a.c.) – Particular requirements – Part 21: Static meters for active energy (classes 1 and 2)*

IEC 62053-22:2003, *Electricity metering equipment (a.c.) – Particular requirements – Part 22: Static meters for active energy (classes 0,2 S and 0,5 S)*

IEC 62053-31:1998, *Electricity metering equipment (a.c.) – Particular requirements – Part 31: Pulse output devices for electromechanical and electronic meters (two wires only)*

IEC 62053-52:2005, *Electricity metering equipment (a.c.) – Particular requirements – Part 52: Symbols*

IEC 62053-61:1998, *Electricity metering equipment (a.c.) – Particular requirements – Part 61: Power consumption and voltage requirements*

IEC 62059-11:2002, *Electricity metering equipment (a.c.) – Dependability – Part 11: General concepts*

IEC 62059-21:2002, *Electricity metering equipment (a.c.) – Dependability – Part 21: Collection of meter dependability data from the field*

IEC 62059-31-1:2008, *Electricity metering equipment – Dependability – Part 31-1: Accelerated reliability testing – Elevated temperature and humidity*

IEC 62059-32-1:2011, *Electricity metering equipment – Dependability – Part 32-1: Durability – Testing of the stability of metrological characteristics by applying elevated temperature*

IEC 62059-41:2006, *Electricity metering equipment – Dependability – Part 41: Reliability prediction*

This part is a standard for type testing electricity meters. It covers the particular requirements for meters, used indoors and outdoors. It does not deal with special implementations (such as metering part and/or displays in separate housings).

This standard is intended to be used in conjunction with IEC 62052-11. When any requirement in this standard concerns an item already covered in IEC 62052-11, the requirements of this standard take precedence over the requirements of IEC 62052-11.

This standard distinguishes:

- between transformer operated meters of accuracy class index 0,5 S and 1 S and direct connected meters of accuracy class index 1;
- between protective class I and protective class II meters;
- between meters for use in networks equipped with or without earth fault neutralizers.

The test levels are regarded as minimum values that provide for the proper functioning of the meter under normal working conditions. For special application, other test levels might be necessary and should be agreed on between the user and the manufacturer.

INTRODUCTION TO AMENDMENT 1

The purpose of this amendment is to identify and remove all safety related requirements and tests of IEC 62053-24:2014 that are replaced and extended by the complete set of requirements and tests in IEC 62052-31:2015.

Currently in preview, click buy full version

AUSTRALIAN STANDARD

Electricity metering equipment (ac)—Particular requirements**Part 24:****Static meters for reactive energy at fundamental frequency (classes 0.5 S, 1 S and 1) (IEC 62053-24:2016 (ED.1.1) (MOD))****1 Scope**

This part of IEC 62053 applies only to newly manufactured transformer operated static var-hour meters of accuracy classes 0,5 S, and 1 S as well as direct connected static var-hour meters of accuracy class 1, for the measurement of alternating current electrical reactive energy in 50 Hz or 60 Hz networks and it applies to their type tests only.

This standard uses a conventional definition of reactive energy where the reactive power and energy is calculated from the fundamental frequency components of the currents and voltages only. See Clause 3.

NOTE 1 This differs from the approach of IEC 62053-23, where reactive power and energy is defined only for sinusoidal signals. In this standard reactive power and energy is defined for all periodic signals. Reactive power and energy is defined in this way to achieve proper reproducibility of measurements with meters of different designs. With this definition, reactive power and energy reflects the generally unnecessary current possible to compensate with capacitors rather than the total unnecessary current.

It applies only to static var-hour meters for indoor and outdoor application consisting of a measuring element and register(s) enclosed together in a meter case. It also applies to operation indicator(s) and test output(s). If the meter has a measuring element for more than one type of energy (multi-energy meters), or when other functional elements, like maximum demand indicators, electronic tariff registers, time switches, ripple control receivers, data communication interfaces, etc., are enclosed in the meter case, then the relevant standards for these elements also apply.

NOTE 2 IEC 61869-2:2012 describes transformers having a measuring range of $0,05 I_n$ to I_{max} for accuracy classes 0,2, 0,5, 1 and 2, and transformers having a measuring range of $0,01 I_n$ to I_{max} for accuracy classes 0,2 S and 0,5 S. As the measuring range of a meter and its associated transformers have to be matched and as only transformers of classes 0,2 S / 0,5 S have the current error and phase displacement characteristics suitable to operate a class 0,5 S / 1 S meter respectively as specified in this standard, the measuring range of the transformer operated meters will be $0,01 I_n$ to I_{max} . Reactive meters intended to be used together with non-S transformers are, therefore, not covered by this standard.

It does not apply to:

- var-hour meters where the voltage across the connection terminals exceeds 600 V (line-to-line voltage for meters for polyphase systems);
- portable meters;
- data interfaces to the register of the meter;
- reference meters.

The dependability aspect is covered by the standards of the IEC 62059 series.

The safety aspect is covered by IEC 62052-31:2015.