

Australian Standard™

Electricity metering (ac)—Tariff and load control

Part 11: Particular requirements for electronic ripple control receivers

STANDARDS
Australia



This Australian Standard was prepared by Committee EL-011, Electricity Metering Equipment. It was approved on behalf of the Council of Standards Australia on 19 January 2006.
This Standard was published on 10 February 2006.

The following are represented on Committee EL-011:

Australian Chamber of Commerce and Industry
Australian Electrical and Electronic Manufacturers Association
Electrical Regulatory Authorities Council
Electricity Engineers Association (New Zealand)
Energy Networks Association
Engineers Australia
Ministry of Economic Development (New Zealand)
NEMMCO
National Measurement Institute

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia, GPO Box 476, Sydney, NSW 2001.

This Standard was issued in draft form for comment as DR 05137.

Australian Standard™

Electricity metering (ac)—tariff and load control

Part 11: Particular requirements for electronic ripple control receivers

Originally as AS 1284.6—1992.
Revised and redesignated as AS 62054.11—2006.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia

ISBN 0 7337 7241 2

PREFACE

This Standard was prepared by the joint Standards Australia/Standards New Zealand Committee EL-011, Electricity Metering Equipment to supersede AS 1284.6, *Electricity metering—Ripple control receivers for tariff and load control*. After consultation with stakeholders in both countries, Standards Australia and Standards New Zealand decided to develop this Standard as an Australian, rather than an Australian/New Zealand Standard.

The objective of this Standard is to provide electricity utilities and manufacturers with requirements and tests for ripple control receivers.

This Standard is identical with, and has been reproduced from IEC 62054-11, Ed.1.0 (2005) *Electricity metering (ac)—Tariff and load control—Part 11: Particular requirements for electronic ripple control receivers*.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text ‘this part of IEC 62054’ should read ‘AS 62054-11’.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

The terms ‘normative’ and ‘informative’ are used to define the application of the annex to which they apply. A normative annex is an integral part of a standard, whereas an informative annex is only for information and guidance.

CONTENTS

	<i>Page</i>
INTRODUCTION	iv
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Standard electrical values	2
5 Mechanical requirements and tests	2
5.1 Operation status indicator	2
6 Climatic conditions, requirements and tests	2
7 Electrical requirements and tests	2
7.1 Supply voltage	2
7.2 Heating	3
7.3 Insulation	3
7.4 Output elements	3
7.5 Functional requirements and tests – Control performance	3
7.6 Electromagnetic compatibility (EMC)	5
7.7 Radio interference suppression	11
8 Test conditions and type test	11
Annex A (normative) Harmonic levels for testing ripple control receivers	12
Annex B (normative) Selection of frequency for tests with harmonics	13
Annex C (normative) Combination of parameters for operation and non-operation tests	14
Annex D (informative) Acceptance tests	15
Annex E (informative) Code terms	16
Annex F (informative) Example of a test configuration for operation and non-operation tests and for measurement of disturbance-limit curves	17
Annex G (informative) Values of the influence quantities for the different tests	18
Figure B.1 – Examples for selection of the frequency H_c	13
Figure B.2 – Frequency deviations for measurement of the disturbance-limit curves	13
Figure F.1 – Test configuration	17
Table A.1 – Recommended values for 50 Hz networks	12
Table C.1 – Combination of parameters	14

INTRODUCTION

The test levels are regarded as minimum values to guarantee the proper functioning of the equipment under normal working conditions. For special applications, other test levels might be necessary and should be agreed on between the user and the manufacturer.

Ripple control receivers are components of a system of remote control permitting the simultaneous operation of a large number of receivers from a central point. The signal generally used for this purpose is an audio-frequency voltage superimposed on the mains frequency and coded in the form of pulses, which can provide a multiplicity of control functions. Other types of signals, such as frequency modulation, deformation of the mains frequency, etc. may also be used. These signals are propagated through the electricity supply network, from the injection point to the receiver sites.

Some characteristics of such systems, for example, the value of the frequency or the method of coding, are not standardized here.

To facilitate the application of this standard the following principles should be applied.

- 1) The requirements of this standard are not limiting. If it is absolutely unavoidable, a user can add additional technical requirements in his specification.

The technical requirements and tests relate to the general functioning of the receiver. The method of operation of the functional elements is not specified. These requirements and tests may, however, be the subject of additional technical agreements.

- 2) Ripple control systems are auxiliary equipment for network operation. Their design is determined by the network characteristics and other factors. At the present time rapid development of power electronic equipment is leading to a parallel increase in the amount of harmonic distortion in the supply voltage. The harmonic levels indicated in this standard take account of this development. They are not to be considered as values that could be regarded as permissible on the network but as recommended values for designing and testing receivers. These recommended levels could be adapted to particular characteristics of networks under consideration.

Receivers designed for use with transmitters already in operation and having a control frequency equal, or very close, to a harmonic, need not conform to the whole of the requirements of this standard.

For information, the relevant parts of IEC 62052, IEC 62054 and IEC 62059 are listed below.

IEC 62052-21	Electricity metering equipment (a.c.) – General requirements, tests and test conditions – Part 21: Tariff and load control equipment (Replaces the general requirements of IEC 61037 and IEC 61038.)
IEC 62054-11	Electricity metering – Tariff and load control – Part 11: Particular requirements for electronic ripple control receivers (Replaces the particular requirements of IEC 61037.)
IEC 62054-21	Electricity metering – Tariff and load control – Part 21: Particular requirements for time switches (Replaces the particular requirements of IEC 61038.)
IEC 62059-11	Electricity metering equipment – Dependability – Part 11: General concepts
IEC 62059-21	Electricity metering equipment – Dependability – Part 21: Collection of meter dependability data from the field
IEC 62059-41	Electricity metering equipment – Dependability – Part 41: Reliability prediction ¹

¹ To be published.

STANDARDS AUSTRALIA

Australian Standard

Electricity metering (ac)—Tariff and load control
Part 11: Particular requirements for electronic ripple control receivers

Any table, figure or text of the international standard that is struck through is not part of this standard. Any Australian/New Zealand table, figure or text that is added is part of this standard and is identified by shading.

1 Scope

This part of IEC 62054 specifies particular requirements for the type test of newly manufactured indoor electronic ripple control receivers for the reception and interpretation of pulses of a single audio frequency superimposed on the voltage of the electricity distribution network and for the execution of the corresponding switching operations. In this system the mains frequency is generally used to synchronize the transmitter and receivers. Neither the control frequency nor the encoding are standardized in this standard.

This standard gives no requirements for constructional details internal to the receiver.

In the case where ripple control functionality is integrated in multifunction electricity metering equipment, the relevant parts of this standard apply.

This standard does not cover the acceptance test and the conformity tests. Nevertheless, an example of what could be an acceptance test is given in Annex D.

The dependability aspect is covered by the documents of the IEC 62059 series.

When using this standard in conjunction with IEC 62052-21, the requirements of this standard take precedence over those of IEC 62052-21 with regard to any item already covered in it.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

References to international standards that are struck through in this clause are replaced by references to Australian or Australian/New Zealand Standards that are listed immediately thereafter and identified by shading. Any Australian or Australian/New Zealand Standard that is identical to the International Standard it replaces is identified as such.

~~IEC 62052-21, *Electricity metering equipment (a.c.)—General requirements, tests and test conditions—Part 21: Tariff and load control equipment*~~

AS 62052.21, *Electricity metering equipment (a.c.)—General requirements, tests and test conditions, Part 21: Tariff and load control equipment*