



## **Fire detection and alarm systems**

### **Part 12: Line type smoke detectors using a transmitted optical beam (ISO 7240-12:2014, MOD)**

STANDARDS  
Australia



AS 7240.12:2018

This Australian Standard ® was prepared by FP-002, Fire Detection, Warning, Control and Intercom Systems. It was approved on behalf of the Council of Standards Australia on 30 November 2018.

This Standard was published on 20 December 2018.

The following are represented on Committee FP-002:

Association of Hydraulic Services Consultants Australia  
Australasian Fire and Emergency Service Authorities Council  
Australian Chamber of Commerce and Industry  
Australian Industry Group  
Australian Institute of Building Surveyors  
CSIRO  
Deafness Forum of Australia  
Department of Health and Human Services (VIC)  
Engineers Australia  
Fire Protection Association Australia  
National Electrical and Communications Association  
National Fire Industry Association  
Property Council of Australia  
Society of Fire Safety

This Standard was issued in draft form for comment as DR AS 7240.12:2018.

#### **Keeping Standards up-to-date**

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

[www.standards.org.au](http://www.standards.org.au)

[www.saiglobal.com](http://www.saiglobal.com) (sales and distribution)

ISBN 978 1 76072 307 1



## **Fire detection and alarm systems**

### **Part 12: Line type smoke detectors using a transmitted optical beam (ISO 7240-12:2014, MOD)**

First published as AS 7240.12—2007.  
This edition AS 7240.12:2018.

#### **COPYRIGHT**

© 2018 — All rights reserved  
© Standards Australia Limited 2018

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth).

Published by SAI Global Pty Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia.

## Preface

This Standard was prepared by the Standards Australia Committee FP-002, Fire Detection, Warning, Control and Intercom Systems, to supersede AS 7240.12—2007, *Fire detection and alarm systems, Part 12: Line type smoke detectors using a transmitted optical beam*.

The objective of this Standard is to specify requirements, test methods and performance criteria for line-type smoke detectors for use in fire detection systems installed in buildings. The detectors consist of at least a transmitter and a receiver and can include reflector(s), for the detection of smoke by the attenuation and/or changes in attenuation of an optical beam.

This Standard is an adoption with national modifications, and has been reproduced from, ISO 7240-12:2014, *Fire detection and alarm systems — Part 12: Line type smoke detectors using a transmitted optical beam*. The modifications are additional requirements and are set out in [Appendix ZZ](#), which has been added at the end of the source text.

[Appendix ZZ](#) lists the variations to ISO 7240-12:2014 for the application of this Standard in Australia.

As this document has been reproduced from an International Standard, the following applies:

- (a) In the source text “this part of ISO 7240” should read “this Australian Standard”.
- (b) A full point substitutes for a comma when referring to a decimal marker.

Australian Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

# Contents

Preface .....	ii
Foreword .....	vi
Introduction .....	viii
<b>1 Scope</b> .....	<b>1</b>
<b>2 Normative references</b> .....	<b>1</b>
<b>3 Terms and definitions</b> .....	<b>2</b>
<b>4 Requirements</b> .....	<b>3</b>
4.1 Compliance .....	3
4.2 Individual alarm indication .....	3
4.3 Connection of ancillary devices .....	3
4.4 Monitoring of detachable detectors and connections .....	3
4.5 Manufacturer's adjustments .....	4
4.6 On-site adjustment of response threshold value .....	4
4.7 Protection of optical components .....	4
4.8 Limit of compensation .....	4
4.9 Fault signalling .....	4
4.10 Software-controlled detectors .....	5
4.10.1 General .....	5
4.10.2 Software documentation .....	5
4.10.3 Software design .....	5
4.10.4 Storage of programs and data .....	6
<b>5 Test methods</b> .....	<b>6</b>
5.1 General .....	6
5.1.1 Atmospheric conditions for tests .....	6
5.1.2 Mounting arrangement .....	6
5.1.3 Operating conditions for tests .....	6
5.1.4 Tolerances .....	7
5.1.5 Measurement of response threshold value .....	7
5.1.6 Provision for tests .....	7
5.1.7 Test schedule .....	8
5.1.8 Test report .....	8
5.2 Reproducibility .....	8
5.2.1 Object of test .....	8
5.2.2 Test procedure .....	9
5.2.3 Requirements .....	9
5.3 Repeatability .....	9
5.3.1 Object of test .....	9
5.3.2 Test procedure .....	9
5.3.3 Requirements .....	9
5.4 Alignment dependence .....	10
5.4.1 Object of test .....	10
5.4.2 Test procedure .....	10
5.4.3 Requirements .....	10
5.5 Variation of supply parameters .....	10
5.5.1 Object .....	10
5.5.2 Test procedure .....	11
5.5.3 Requirements .....	11
5.6 Rapid changes in attenuation .....	11
5.6.1 Object of test .....	11
5.6.2 Test procedure .....	11
5.6.3 Requirements .....	11
5.7 Slow changes in attenuation .....	12

5.7.1	Object of test.....	12
5.7.2	Test procedure.....	12
5.7.3	Requirements.....	12
5.8	Optical path length dependence.....	12
5.8.1	Object of test.....	12
5.8.2	Test procedure.....	12
5.8.3	Requirements.....	13
5.9	Fire sensitivity.....	13
5.9.1	Object of test.....	13
5.9.2	Test procedure.....	13
5.9.3	Requirements.....	14
5.10	Stray light.....	15
5.10.1	Object of test.....	15
5.10.2	Test procedure.....	15
5.10.3	Requirements.....	15
5.11	Dry heat (operational).....	16
5.11.1	Object of test.....	16
5.11.2	Test procedure.....	16
5.11.3	Requirements.....	16
5.12	Cold (operational).....	17
5.12.1	Object of test.....	17
5.12.2	Test procedure.....	17
5.12.3	Requirements.....	18
5.13	Damp heat, steady-state (operational).....	18
5.13.1	Object of the test.....	18
5.13.2	Test procedure.....	18
5.13.3	Requirements.....	19
5.14	Damp heat, steady-state (endurance).....	19
5.14.1	Object of test.....	19
5.14.2	Test procedure.....	19
5.14.3	Requirements.....	19
5.15	Vibration, sinusoidal (endurance).....	20
5.15.1	Object of test.....	20
5.15.2	Test procedure.....	20
5.15.3	Requirements.....	20
5.16	Electromagnetic compatibility (EMC), immunity tests (operational).....	21
5.17	Sulfur dioxide, SO <sub>2</sub> , corrosion (endurance).....	21
5.17.1	Object of test.....	21
5.17.2	Test procedure.....	21
5.17.3	Requirements.....	22
5.18	Impact (operational).....	22
5.18.1	Object of test.....	22
5.18.2	Test procedure.....	22
5.18.3	Requirements.....	23
<b>6</b>	<b>Test report.....</b>	<b>23</b>
<b>7</b>	<b>Marking.....</b>	<b>24</b>
<b>8</b>	<b>Data.....</b>	<b>24</b>
<b>Annex A</b>	(informative) <b>Compensation for detector drift.....</b>	<b>26</b>
<b>Annex B</b>	(normative) <b>Bench for response threshold value measurements.....</b>	<b>31</b>
<b>Annex C</b>	(normative) <b>Fire test room.....</b>	<b>33</b>
<b>Annex D</b>	(normative) <b>Smouldering pyrolysis wood fire (TF2).....</b>	<b>35</b>
<b>Annex E</b>	(normative) <b>Glowing smouldering cotton fire (TF3).....</b>	<b>38</b>
<b>Annex F</b>	(normative) <b>Flaming plastics (polyurethane) fire (TF4).....</b>	<b>40</b>

<b>Annex G</b>	(normative) <b>Flaming liquid (<i>n</i>-heptane) fire (TF5)</b> .....	<b>42</b>
<b>Annex H</b>	(normative) <b>Smoke-measuring instruments</b> .....	<b>43</b>
<b>Annex I</b>	(normative) <b>Apparatus for stray light</b> .....	<b>46</b>
<b>Annex J</b>	(informative) <b>Information concerning the construction of the measuring ionization chamber</b> .....	<b>48</b>
<b>Appendix ZZ</b>	(normative) <b>Variations to ISO 7240-12:2014 for Australia</b> .....	<b>51</b>

Currently in preview, click buy full version

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2. [www.iso.org/directives](http://www.iso.org/directives)

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received. [www.iso.org/patents](http://www.iso.org/patents)

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT), see the following URL: [Foreword - Supplementary information](#)

The committee responsible for this document is ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 3, *Fire detection and fire alarm systems*.

This second edition cancels and replaces the first edition (ISO 7240-12:2006), which has been technically revised.

ISO 7240 consists of the following parts, under the general title *Fire detection and alarm systems*:

- Part 1: General and definitions
- Part 2: Control and indicating equipment
- Part 3: Audible alarm devices
- Part 4: Power supply equipment
- Part 5: Point-type heat detectors
- Part 6: Carbon monoxide fire detectors using electro-chemical cells
- Part 7: Point-type smoke detectors using scattered light, transmitted light or ionization
- Part 8: Carbon monoxide fire detectors using an electro-chemical cell in combination with a heat sensor
- Part 9: Test fires for fire detectors [Technical Specification]
- Part 10: Point-type flame detectors
- Part 11: Manual call points
- Part 12: Line type smoke detectors using a transmitted optical beam
- Part 13: Compatibility assessment of system components

- *Part 14: Design, installation, commissioning and service of fire detection and fire alarm systems in and around buildings*
- *Part 15: Point type fire detectors using scattered light, transmitted light or ionization sensors in combination with a heat sensor*
- *Part 16: Sound system control and indicating equipment*
- *Part 17: Short-circuit isolators*
- *Part 18: Input/output devices*
- *Part 19: Design, installation, commissioning and service of sound systems for emergency purposes*
- *Part 20: Aspirating smoke detectors*
- *Part 21: Routing equipment*
- *Part 22: Smoke detection equipment for ducts*
- *Part 23: Visual alarm devices*
- *Part 24: Sound-system loudspeakers*
- *Part 25: Components using radio transmission paths*
- *Part 27: Point-type fire detectors using a scattered-light, transmitted-light or ionization smoke sensor, an electrochemical-cell carbon-monoxide sensor and a heat sensor*
- *Part 28: Fire protection control equipment*

A Part 29 dealing with video fire detectors is under preparation.

## Introduction

This part of ISO 7240 has been prepared by ISO/TC 21/SC 3, the secretariat of which is held by SA and is based on ISO 7240-12:2006.

A fire detection and alarm system is required to function satisfactorily not only in the event of fire, but also during and after exposure to conditions likely to be met in practice, including corrosion, vibration, direct impact, indirect shock and electromagnetic interference. Specific tests are intended to assess the performance of the smoke detectors under such conditions.

This part of ISO 7240 is not intended to place any other restrictions on the design and construction of such detectors.

Currently in preview, click buy full version

# Australian Standard®

## Fire detection and alarm systems

### Part 12: Line type smoke detectors using a transmitted optical beam (ISO 7240-12:2014, MOD)

#### 1 Scope

**1.1** This part of ISO 7240 specifies requirements, test methods and performance criteria for line-type smoke detectors for use in fire detection systems installed in buildings. The detectors consist of at least a transmitter and a receiver and can include reflector(s), for the detection of smoke by the attenuation and/or changes in attenuation of an optical beam.

**1.2** This part of ISO 7240 does not cover

- line-type smoke detectors designed to operate with separations between opposed components of less than 1 m;
- line-type smoke detectors whose optical path length is defined or adjusted by an integral mechanical connection;
- line-type smoke detectors with special characteristics, which cannot be assessed by the test methods in this part of ISO 7240.

NOTE The term “optical” is used to describe that part of the electromagnetic spectrum produced by the transmitter to which the receiver is responsive; this is not restricted to visible wavelengths.

#### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 209, *Aluminium and aluminium alloys — Chemical composition*

ISO 7240-1, *Fire detection and alarm systems — Part 1: General and definitions*

IEC 60064, *Tungsten filament lamps for domestic and similar general lighting purposes — Performance requirements*

IEC 60068-1, *Environmental testing — Part 1: General and guidance*

IEC 60068-2-1, *Environmental testing — Part 2-1: Tests. Tests A: Cold*

IEC 60068-2-2, *Environmental testing — Part 2-2: Tests. Tests B: Dry heat*

IEC 60068-2-6, *Environmental testing — Part 2-6: Tests. Test Fc: Vibration (sinusoidal)*

IEC 60068-2-27, *Environmental testing — Part 2-27: Tests. Test Ea and guidance: Shock*

IEC 60068-2-42, *Environmental testing — Part 2-42: Tests. Test Kc: Sulphur dioxide test for contacts and connections*

IEC 60068-2-78, *Environmental testing — Part 2-78: Tests. Test Cab: Damp heat, steady state*

IEC 60081, *Double-capped fluorescent lamps — Performance specifications*

EN 50130-4:2011, *Alarm systems — Part 4: Electromagnetic compatibility — Product family standard: Immunity requirements for components of fire, intruder and social alarm systems*