

Australian Standard™

Fire detection and alarm systems

**Part 6: Carbon monoxide fire detectors
using electro-chemical cells**

STANDARDS
Australia



This Australian Standard was prepared by Committee FP-002, Fire Detection, Warning, Control and Intercom Systems. It was approved on behalf of the Council of Standards Australia on 20 September 2005.
This Standard was published on 9 March 2006.

The following are represented on Committee FP-002:

Audio Engineering Society
Australasian Fire Authorities Council
Australian Building Codes Board
Australian Chamber of Commerce and Industry
Australian Electrical and Electronic Manufacturers Association
Australian Government Analytical Laboratories, Scientific Services Laboratory
Australian Industry Group
Australian Institute of Building Surveyors
Deafness Forum of Australia
Department of Defence (Australia)
Fire Protection Association Australia
Institute of Security Executives
National Electrical and Communications Association
Property Council of Australia

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia, GPO Box 476, Sydney, NSW 2001.

This Standard was issued in draft form for comment as DR 03356.

Australian Standard™

Fire detection and alarm systems

**Part 6: Carbon monoxide fire detectors
using electro-chemical cells**

Originally as AS 1603.14—2001.
Revised and redesignated AS 7240.6—2006.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia GPO Box 476, Sydney, NSW 2001, Australia

ISBN 0 7337 7302 8

PREFACE

This Standard was prepared by the Standards Australia Committee, FP-002, Fire Detection, Warning, Control and Intercom Systems, to supersede AS 1603.14—2001, *Automatic fire detection and alarm systems*, Part 14: *Point type carbon monoxide (CO) fire detectors*, which will be withdrawn 12 months after the publication of this Standard.

This Standard is identical with, and has been reproduced from, ISO 7240-6:2004, *Fire detection and alarm systems*, Part 6: *Carbon monoxide fire detectors using electro-chemical cells*.

As this Standard is reproduced from an International Standard, the following applies:

- Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- In the source text ‘this International Standard’ should read ‘this Australian Standard’.
- A full point should be substituted for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to equivalent Australian or Australian/New Zealand Standards, as follows:

<i>References to International Standard or other Publication</i>		<i>Australian/New Zealand Standard</i>	
ISO		AS	
7240	Fire detection and alarm systems	7240	Fire detection and alarm systems
7240-7	Part 7: Point detectors using scattered light, transmitted light or ionization	7240.7	Part 7: Point detectors using scattered light, transmitted light or ionization (ISO 7240-7:2003, MOD)
IEC		AS	
60068	Environmental testing	60068	Environmental testing
60068-1	Part 1: General and guidance	60068.1	General and guidance
60068-2-1	Part 2: Tests—Test A: Cold	60068.2.1	Tests—Test A: Cold
60068-2-2	Part 2: Tests—Test B: Dry heat	60068.2.1	Tests—Test B: Dry heat
60068-2-6	Part 2: Tests—Test Fc: Vibration (sinusoidal)	60068.2.6	Tests—Test Fc: Vibration (sinusoidal)
60068-2-27	Part 2: Tests—Test Ea and guidance: Shock	60068.2.27	Tests—Test Ea and guidance: Shock
60068-2-30	Part 2: Tests—Test Db and guidance: Damp heat, cyclic (12 + 12-hour cycle)	60068.2.30	Tests—Test Db and guidance: Damp heat, cyclic (12 + 12-hour cycle)
60068-2-42	Part 2-42: Tests—Test Kc: Sulphur dioxide test for contacts and connections	60068.2.42	Tests—Test Kc: Sulphur dioxide test for contacts and connections
60068-2-78	Part 2-78: Tests—Test Cab: Damp heat, steady state	60068.2.78	Tests—Test Cab: Damp heat, steady state

The terms ‘normative’ and ‘informative’ are used to define the application of the annex to which they apply. A normative annex is an integral part of a standard, whereas an informative annex is only for information and guidance.

CONTENTS

Page

1	Scope.....	1
2	Normative references	1
3	Terms, definitions and symbols	2
4	General requirements	2
4.1	Compliance	2
4.2	Individual alarm indication.....	2
4.3	Connection of ancillary devices	3
4.4	Monitoring of detachable detectors	3
4.5	Manufacturer's adjustments	3
4.6	On-site adjustment of response behaviour.....	3
4.7	Rate-sensitive response behaviour	3
4.8	Marking.....	3
4.9	Data.....	4
4.10	Requirements for software controlled detectors.....	4
5	Tests	6
5.1	General	6
5.2	Repeatability	8
5.3	Directional dependence.....	9
5.4	Reproducibility	9
5.5	Cross sensitivity	10
5.6	Long-term stability.....	11
5.7	Saturation.....	11
5.8	Exposure to chemical agents associated with a fire.....	12
5.9	Variation in supply parameters	13
5.10	Air movement	13
5.11	Dry heat (operational).....	14
5.12	Cold (operational)	15
5.13	Damp heat, steady state (operational).....	16
5.14	Damp heat, steady state (endurance).....	17
5.15	Sulfur dioxide (SO ₂) corrosion (endurance)	17
5.16	Shock (operational).....	18
5.17	Impact (operational).....	19
5.18	Vibration, sinusoidal (operational).....	20
5.19	Vibration, sinusoidal (endurance).....	22
5.20	Electromagnetic compatibility (EMC) immunity test (operational).....	23
5.21	Fire sensitivity.....	23
6	Test report	25
Annex A (normative) Gas test chamber for response threshold value and cross-sensitivity measurements.....		26
Annex B (informative) Apparatus for impact test.....		27
Annex C (informative) Fire test room		29
Annex D (normative) Smouldering (pyrolysis) wood fire (TF2)		31
Annex E (normative) Glowing smouldering cotton fire (TF3).....		33
Annex F (normative) Deep-seated smouldering cotton fire (TF9).....		35
Annex G (informative) Information concerning the construction of the gas test chamber.....		37

INTRODUCTION

This part of ISO 7240 has been drawn up by the Sub-Committee ISO/TC 21/SC 3 and is based on a Standard prepared by Standards Australia International Technical Committee FP-002 "Fire detection, warning, control and intercom systems".

A fire detection and fire alarm system is required to function satisfactorily not only in the event of a fire, but also during and after exposure to conditions likely to be met in practice such as corrosion, vibration, direct impact, indirect shock and electromagnetic interference. Some tests specified are intended to assess the performance of the fire detectors under such conditions.

The performance of fire detectors is assessed from results obtained in specific tests; this part of ISO 7240 is not intended to place any other restrictions on the design and construction of such detectors.

Carbon monoxide (CO) fire detectors can react promptly to slow smouldering fires involving carbonaceous materials because CO does not depend solely on convection, but also moves by diffusion and CO fire detectors might be better suited to applications where other fire detection techniques are prone to false alarms, i.e. due to dust, steam and cooking vapours.

Whilst CO gas has greater mobility than smoke, it can be diluted by ventilation systems and be affected by convection currents. Hence the same considerations as for point smoke detectors should be taken into account. Recirculating systems confined to a single room have little effect on detection, as this is similar to the natural diffusion of the CO gas.

CO fire detectors might be less affected by stratification than other types of fire detectors.

It is important that the location of CO fire detectors take into account areas where false operation or non-operation is likely. CO fire detectors might not be suitable for detecting fires involving

- clean-burning liquids;
- PVC-insulated cables;
- combustible metals;
- certain self-oxidizing chemicals;
- non-carbonaceous materials.

Some typical locations where it is important to carefully evaluate the use of CO fire detectors are as follows:

- a) areas where CO gas may be present from exhausts and normal manufacturing processes.

EXAMPLES: car parks, car-park return air plenums, loading docks.

- b) General cigarette smoke will not have sufficient CO present to cause alarms even though smoke may be clearly visible. However, in heavy smoking or incense-burning areas, it is important to measure the CO concentration before installing CO fire detectors.

This part of ISO 7240 includes a number of Electromagnetic Compatibility (EMC) immunity requirements. The details for these requirements have been taken from European standard EN 50130-4 "Alarm Systems — Part 4: Electromagnetic compatibility — Product family standard: Immunity requirements for components of fire, intruder and social alarm systems".

STANDARDS AUSTRALIA

Australian Standard**Fire detection and alarm systems**
Part 6: Carbon monoxide fire detectors using electro-chemical cells

1 Scope

This part of ISO 7240 specifies requirements, test methods and performance criteria for point-type detectors using electro-chemical cells that operate using carbon monoxide detection principles for use in fire detection and alarm systems installed in buildings (see ISO 7240-1). CO fire detectors conforming to this part of ISO 7240 might not be suitable for other uses.

For the testing of other types of fire detectors, or smoke detectors working on different principles, this part of ISO 7240 should be used only for guidance. Fire detectors with special characteristics and developed for specific risks are not covered by this part of ISO 7240.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 209-1, *Wrought aluminium and aluminium alloys — Chemical composition and forms of products — Part 1: Chemical composition*

ISO 7240-1, *Fire detection and alarm systems — Part 1: General and definitions*

ISO 7240-7, *Fire detection and alarm systems — Part 7: Point-type smoke detectors using scattered light, transmitted light or ionization*

IEC 60068-1, *Environmental testing — Part 1: General and guidance*

IEC 60068-2-1, *Environmental testing — Part 2: Tests. Tests A: Cold*

IEC 60068-2-2, *Environmental testing — Part 2: Tests. Tests B: Dry heat*

IEC 60068-2-6, *Environmental testing — Part 2: Tests — Test Fc: Vibration (sinusoidal)*

IEC 60068-2-27, *Environmental testing. Part 2: Tests. Test Ea and guidance: Shock*

IEC 60068-2-30, *Environmental testing — Part 2: Tests. Test Db and guidance: Damp heat, cyclic (12 + 2-h cycle)*

IEC 60068-2-42, *Environmental testing — Part 2-42: Tests — Test Kc: Sulphur dioxide test for contacts and connections*

IEC 60068-2-78, *Environmental testing — Part 2-78: Tests — Test Cab: Damp heat, steady state*