

Australian Standard™

Programmable controllers

Part 2: Equipment requirements and tests



**STANDARDS
AUSTRALIA**

This Australian Standard was prepared by Committee IT-006, Information Technology for Industrial Automation. It was approved on behalf of the Council of Standards Australia on 15 January 2004 and published on 22 March 2004.

The following are represented on Committee IT-006:

Association of Consulting Engineers Australia
Australian Electrical and Electronic Manufacturers Association
CSIRO Centre for Planning and Design
DSIRO Manufacturing and Infrastructure Technology
Department of Defence, Australia
Institute of Instrumentation, Control and Automation, Australia
Institution of Engineers Australia
Monash University
RMIT University
The University of Melbourne

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australia Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

This Standard was issued in draft form for comment as DR 03588.

Australian Standard™

Programmable controllers

Part 2: Equipment requirements and tests

Formulated as AS 4168.2—1994.
Revised and redesignated as AS IEC 61131.2—2004.

COPYRIGHT

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 5771 5

PREFACE

This Standard was prepared by the Standards Australia Committee IT-006, Information Technology for Industrial Automation to supersede AS 4168.2—1994, *Programmable controllers, Part 2: requirements and tests*.

This Standard is identical with, and has been reproduced from, IEC 61131-2:2003, *Programmable controllers—Part 2: Equipment requirements and tests*.

The objective of this Standard is to specify requirements and related tests for programmable controllers (PLC) and their associated peripherals (for example, programming and debugging tools (PADTs), human-machine interfaces (HMIs), etc.) which have as their intended use the control and command of machines and industrial processes.

This Standard is Part 2 of AS IEC 61131 *Programmable controllers*, which consists of the following:

Part 1: General information

Part 2: Equipment requirements and tests (this Standard)

Part 3: Programming languages

Part 4: User guidelines

Part 5: Communications

Part 7: Fuzzy control programming

Part 8: Guidelines for the application and implementation of programming languages

AS IEC 61131 does not have a Part 6. A project to develop IEC 61131-6 *Programmable controller communications via field bus* was deleted in September 2000 by the IEC.

In this Standard, the following print types are used:

- requirements proper: in arial type;
- test specifications: in italic type;
- explanatory matter: in smaller arial type.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text ‘this part of IEC 61131’ should read ‘this part of AS IEC 61131’.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

CONTENTS

	<i>Page</i>
INTRODUCTION	ix
1 General.....	1
1.1 Scope and object	1
1.2 Compliance with this standard	2
1.3 Normative references.....	3
2 Type tests	5
2.1 Equipment to be tested (equipment under test/EUT)	5
2.2 Special features for immunity and EMC tests	7
2.3 Withstand test conditions	8
2.4 Verification procedure	8
2.5 Requirements for test programmes and proper functioning verification procedures (PFVPs) to be provided by the manufacturer	8
2.6 General conditions for tests	9
3 Terms and definitions.....	9
4 Normal service conditions and requirements	16
4.1 Climatic conditions and requirements.....	16
4.1.1 Operating ambient air temperature.....	16
4.1.2 Relative humidity.....	17
4.1.3 Altitude	17
4.1.4 Pollution degree	17
4.2 Mechanical service conditions and requirements.....	17
4.2.1 Vibrations.....	17
4.2.2 Shock.....	18
4.2.3 Free falls (portable and hand-held equipment)	18
4.3 Transport and storage conditions and requirements	18
4.3.1 Temperature	19
4.3.2 Altitude	19
4.3.3 Free falls (PLC units in manufacturer's original packaging)	19
4.3.4 Other conditions.....	19
4.4 Electrical service conditions and requirements.....	19
4.4.1 AC and d.c. mains power supply	19
4.4.2 Overvoltage category, control of transient overvoltages	19
4.4.3 Non-periodic overvoltages.....	20
4.5 Special conditions and requirements.....	20
5 Functional requirements.....	20
5.1 Functional power supply and memory back-up requirements.....	22
5.1.1 AC and d.c. power supply	22
5.1.2 Memory back-up	23
5.2 Digital I/Os.....	23
5.2.1 Digital inputs (current sinking).....	24
5.2.2 Terminology (U/I operation regions)	24
5.2.3 Standard operating ranges for digital inputs (current sinking)	26
5.2.4 Additional requirements	26
5.2.5 Digital outputs for alternating currents (current sourcing)	26
5.2.6 Digital outputs for direct current (current sourcing).....	29

	<i>Page</i>
5.3	Analogue I/Os 30
5.3.1	Analogue inputs 30
5.3.2	Analogue outputs 31
5.4	Communication interface requirements 31
5.5	Main processing unit(s) and memory(ies) of the PLC-system requirements 31
5.6	Remote input/output stations (RIOs) requirements 31
5.7	Peripherals (PADTs, TEs, HMIs) requirements 32
5.8	PLC-system self-tests and diagnostics requirements 32
5.9	Functional earthing 33
5.10	Mounting requirements 33
5.11	General marking requirements 33
5.11.1	Functional identifications 33
5.11.2	Module location and module identifications 33
5.11.3	Functional earth terminals markings 33
5.12	Requirements for normal service and functional type tests and verifications 34
5.13	Requirements for information on normal service and function 34
6	Normal service and functional type tests and verifications 34
6.1	Climatic tests 34
6.1.1	Dry-heat and cold withstand tests 34
6.1.2	Variation of temperature 35
6.1.3	Cyclic damp heat withstand test 35
6.2	Mechanical tests 36
6.2.1	Vibration (type test associated with normal service conditions) 36
6.2.2	Shock (type test associated with normal service conditions) 36
6.2.3	Free fall (type test associated with normal service conditions) 37
6.2.4	Free fall (type test associated with transport and storage conditions) 37
6.2.5	Plugging/unplugging of removable units 37
6.3	Verification of special functional requirements for power ports and memory back-up – Special immunity limits for power ports 37
6.3.1	Verification of functional mains power input port (a.c. or d.c.) 38
6.3.2	External energy supply variation tests (immunity tests) 40
6.3.3	Improper power supply connection tests 42
6.3.4	Verification of memory back-up requirements 42
6.4	Verification of input/output requirements 43
6.4.1	General 43
6.4.2	Verification of digital inputs 43
6.4.3	Verification of digital outputs 44
6.4.4	Verification of analogue I/Os 45
6.5	Verification of communication interface requirements 46
6.6	Verification of MPU requirements 46
6.7	Verification of remote I/O stations 46
6.7.1	Response time test 46
6.7.2	Loss of communication test 47
6.7.3	Verification of other requirements 47
6.8	Verification of peripheral (PADTs, TEs, HMIs) requirements 47
6.9	Verification of PLC-system self-tests and diagnostics 47
6.10	Verification of markings and manufacturer's documentation 47

	<i>Page</i>
7	General information to be provided by the manufacturer 47
7.1	Information on type and content of documentation 47
7.1.1	NOTE For the preparation of the instructions, see IEC 62079 and IEC 61506. Information on catalogues and datasheets 48
7.1.2	Information on user's manuals 48
7.1.3	Information on technical documentation 48
7.2	Information on compliance with this standard 48
7.3	Information on reliability 48
7.4	Information on other conditions 48
7.5	Information on shipping and storage 48
7.6	Information on a.c. and d.c. power supply 49
7.7	Information on digital inputs (current sinking) 49
7.8	Information on digital outputs for alternating currents (current sourcing) 50
7.9	Information on digital outputs for direct current (current sourcing) 50
7.10	Information on analogue inputs 50
7.10.1	Information on analogue input static characteristics 51
7.10.2	Information on analogue input dynamic characteristics 51
7.10.3	Information on analogue input general characteristics 51
7.10.4	Information on analogue input miscellaneous characteristics 51
7.11	Information on analogue outputs 52
7.11.1	Information on analogue output static characteristics 52
7.11.2	Information on analogue output dynamic characteristics 52
7.11.3	Information on analogue output general characteristics 52
7.11.4	Information on analogue output miscellaneous characteristics 52
7.12	Information on communication interfaces 53
7.13	Information on main processing unit(s) and memory(ies) of the PLC-system 53
7.14	Information on remote input/output stations (RIOs) 53
7.15	Information on peripherals (PACTs, TEs, HMIs) 54
7.16	Information on self-tests and diagnostics 55
8	Electromagnetic compatibility (EMC) requirements 55
8.1	General 55
8.2	Emission requirements 55
8.2.1	General requirements for emission 55
8.2.2	Emission limits in the low-frequency range 55
8.2.3	Emission limits in the high-frequency range 56
8.3	EMC immunity requirements 56
8.3.1	General 56
8.3.2	Performance criteria 58
8.3.3	General radiated immunity limits 59
8.3.4	Voltage drops and interruptions power ports 62
8.4	Requirements for EMC tests and verifications 62
8.5	Requirements for information on EMC 62

	<i>Page</i>
9	Electromagnetic compatibility (EMC) type tests and verifications 62
9.1	Electromagnetic compatibility-related tests 62
9.2	Test environment 63
9.3	Measurement of radiated interference 63
9.4	Measurement of conducted interference 63
9.5	Electrostatic discharge 64
9.6	Radiofrequency electromagnetic field – Amplitude modulated 65
9.7	Power-frequency magnetic fields 65
9.8	Fast transient bursts 66
9.9	High-energy surges 67
9.10	Conducted radiofrequency interference 68
9.11	Damped oscillatory wave (for zone C only) 69
9.12	Voltage drops and interruptions - Power port type tests and verifications 69
10	Electromagnetic compatibility (EMC) information to be provided by the manufacturer 70
11	Safety requirements 71
11.1	Protection against electrical shock 71
11.1.1	Permissible limits for accessible parts 71
11.1.2	Open PLC-system equipment 72
11.1.3	Enclosed PLC-system equipment 72
11.1.4	Dielectric strength 74
11.1.5	Operator accessibility 74
11.1.6	Protection in normal condition 75
11.1.7	Protection in single-fault condition 75
11.2	Protection against the spread of fire 76
11.3	Limited power circuits 76
11.4	Clearance and creepage distance requirements 77
11.4.1	Clearances relating to overvoltage category II 78
11.4.2	Clearances for non-environment where voltages are known and controlled 80
11.4.3	Creepage distances for basic and supplementary insulation 81
11.4.4	Creepage distances for double/reinforced insulation 84
11.4.5	Creepage for field-wiring terminals 84
11.5	Flame-retardant requirements for non-metallic materials 84
11.5.1	Non-metallic enclosure material 84
11.5.2	Non-metallic material supporting live parts 84
11.5.3	Components 85
11.6	Temperature limits 85
11.7	Enclosures 86
11.7.1	Open equipment 86
11.7.2	Enclosed equipment 86
11.8	Field-wiring terminals constructional requirements 86
11.9	Provisions for protective earthing 87
11.9.1	Protective earthing constructional requirements 87
11.9.2	Protective earthing terminal 87

	<i>Page</i>
11.10 Wiring	88
11.10.1 Internal wiring	88
11.10.2 Interconnection wiring	88
11.10.3 Mains power input cord	88
11.11 Switching devices	89
11.12 Components	89
11.13 Battery requirements	89
11.14 Maximum voltage and minimum voltage	89
11.15 Markings and identification	89
11.15.1 External wiring terminals identification	90
11.15.2 Live parts	90
11.15.3 Protective earth terminals markings	90
11.15.4 Equipment protected by double/reinforced insulation	91
11.15.5 Equipment supplied by SELV/PELV	91
11.15.6 Rating information	91
11.16 Requirements for safety type tests and verifications	91
11.17 Requirements for safety routine tests and verifications	91
11.17.1 Requirement for dielectric strength verification	91
11.17.2 Requirement for protective earthing verification	92
11.18 Requirements for information on safety	92
12 Safety type tests and verifications	92
12.1 Safety-related mechanical tests and verifications	92
12.1.1 Impact withstand test	92
12.1.2 Operator accessibility tests	93
12.1.3 General examination of openings	94
12.1.4 Wire flexing test	94
12.1.5 Temperature test	95
12.1.6 Protective coating test	95
12.1.7 Rigidity test	95
12.1.8 Clearance and creepage verification	95
12.1.9 Field-wiring terminals constructional verification	95
12.2 Safety-related electrical tests	95
12.2.1 Dielectric withstand verification test	96
12.2.2 Protective earthing continuity test	98
12.2.3 Stored energy injury risk test	98
12.2.4 Overload test	99
12.2.5 Endurance test	99
12.3 Single-fault condition test – General	99
12.3.1 Single-fault condition – Breakdown of components test	100
12.3.2 Single-fault condition – Protective impedance test	100
12.3.3 Single-fault condition – Mains transformers test	100
13 Safety routine tests	101
13.1 Dielectric withstand test	101
13.2 Dielectric withstand verification test	101
13.3 Protective earthing test	102

	<i>Page</i>
14 Safety information to be provided by the manufacturer	102
14.1 Information on evaluation of enclosures for open equipment (power dissipation)	103
14.2 Information on mechanical terminal connection	103
Annex A (informative) Illustration of PLC-system hardware definitions	104
Annex B (informative) Digital input standard operating range equations	105
Annex C (normative) Test tools	106
Annex D (informative) Zone C – EMC immunity levels	109
Annex E (informative) Overvoltage example	111
Bibliography	112

Currently in preview, click buy full version

INTRODUCTION

This part of IEC 61131 constitutes Part 2 of a series of standards on programmable controllers and the associated peripherals and should be read in conjunction with the other parts of the series.

Where a conflict exists between this and other IEC standards (except basic safety standards), the provisions of this standard should be considered to govern in the area of programmable controllers and their associated peripherals.

Compliance with Parts 1 and 2 of this standard cannot be claimed unless the requirements of 7.2 of this part are met.

Service and physical environment requirements are specified in Clause 4. Functional requirements are specified in Clause 5. Electromagnetic compatibility requirements are specified in Clause 8. Safety requirements are specified in Clause 11.

Terms of general use are defined in Part 1 of this standard. More specific terms are defined in each part.

X

NOTES

STANDARDS AUSTRALIA

Australian Standard**Programmable controllers****Part 2: Equipment requirements and tests**

1 General**1.1 Scope and object**

This Part of IEC 61131 specifies requirements and related tests for programmable controllers (PLC) and their associated peripherals (for example, programming and debugging tools (PADTs), human-machine interfaces (HMIs), etc.) which have as their intended use the control and command of machines and industrial processes.

PLCs and their associated peripherals are intended to be used in an industrial environment and may be provided as open or enclosed equipment. If a PLC or its associated peripherals are intended for use in other environments, then the specific requirements, standards and installation practices for those other environments must be additionally applied to the PLC and its associated peripherals.

This standard also applies to any products performing the function of PLCs and/or their associated peripherals.

Equipment covered in this standard is intended for use in overvoltage category II (IEC 60664-1) in low-voltage installations, where the rated mains supply voltage does not exceed a.c. 1 000 V r.m.s. (50/60 Hz), or d.c. 1 500 V. (If PLCs or their associated peripherals are applied in overvoltage category III installations, then additional analysis will be required to determine the suitability of the equipment for those applications.)

This standard does not deal with the functional safety or other aspects of the overall automated system. PLCs, their application programme and their associated peripherals are considered as components of a control system.

Since PLCs are component devices, safety considerations for the overall automated system including installation and application are beyond the scope of this standard. However, PLC safety as related to electric shock and fire hazards, electrical interference immunity and error detecting of the PLC-system operation (such as the use of parity checking, self-testing diagnostics, etc.), are addressed. Refer to IEC 60364 or applicable national/local regulations for electrical installation and guidelines.

The object of this standard is

- to establish the definitions and identify the principal characteristics relevant to the selection and application of PLCs and their associated peripherals;
- to specify the minimum requirements for functional, electrical, mechanical, environmental and construction characteristics, service conditions, safety, EMC, user programming and tests applicable to PLCs and the associated peripherals.