



Electric vehicle conductive charging system

Part 23: D.C. electric vehicle charging station

STANDARDS
Australia



This Australian Standard® was prepared by Committee EM-001, Electric Vehicle Operation. It was approved on behalf of the Council of Standards Australia on 3 June 2014. This Standard was published on 30 June 2014.

The following are represented on Committee EM-001:

- Australasian Road Rescue Organisation
 - Australian Automobile Association
 - Australian Electric Vehicle Association
 - Australian Industry Group
 - Auto Skills Australia
 - ChargePoint
 - Consumers Federation of Australia
 - Curtin University of Technology
 - Department of Resources, Energy and Tourism
 - Electrical Regulatory Authorities Council
 - Energy Networks Association
 - Federal Chamber of Automotive Industries
 - Motor Trades Association of Australia
 - National Association of Testing Authorities Australia
 - Transport for NSW
 - Tritium
 - Victorian Automobile Chamber of Commerce
-

This Standard was issued in draft form for comment as DR 102427.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

**Electric vehicle conductive charging
system**

**Part 23: D.C. electric vehicle charging
station**

First published as AS IEC 61851.23:2014.

COPYRIGHT

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

Published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 978 1 74342 786 6

PREFACE

This Standard was prepared by the Standards Australia Committee EM-001, Electric Vehicle Operation.

The objective of this Standard is to, together with IEC 61851-1, Ed. 2.0 (2010), give the requirements for d.c. electric vehicle (EV) charging stations, herein also referred to as ‘DC charger’, for conductive connection to the vehicle, with an a.c. or d.c. input voltage up to 1 000 V a.c. and up to 1 500 V d.c. according to IEC 60038.

This Standard is identical with, and has been reproduced from IEC 61851-23, Ed. 1.0 (2014), *Electric vehicle conductive charging system—Part 23: D.C. electric vehicle charging station*.

This Standard is to be read in conjunction with IEC 61851-1, Ed. 2.0 (2010).

The clauses of particular requirements in this Standard supplement or modify the corresponding clauses in IEC 61851-1, Ed. 2.0 (2010). Where the text of subsequent clauses indicates an ‘addition’ to or a ‘replacement’ of the relevant requirement, test specification or explanation of Part 1, these changes are made to the relevant text of Part 1, which then becomes part of this Standard. Where no change is necessary, the words ‘This clause of Part 1 is applicable’ are used. Additional clauses, tables and figures which are not included in Part 1 have a number starting from 101. Additional annexes are lettered AA, BB etc.

In this Standard, the following print types are used:

- test specifications and instructions regarding application of Part 1: *italic type*.
- notes: smaller roman type.

As this Standard is reproduced from an International Standard, the following applies:

- (a) In the source text ‘this part of IEC 61851’ should read ‘this Australian Standard’.
- (b) A full point substitutes for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to Australian or Australian/New Zealand Standards, as follows:

<i>Reference to International Standard</i>	<i>Australian/New Zealand Standard</i>
IEC	AS/NZS
60950 Information technology equipment— Safety	60950 Information technology equipment— Safety
60950-1 Part 1: General requirements	60950.1 Part 1: General requirements (IEC 60950-1, Ed. 2.0 (2005), MOD)
61558 Safety of power transformers, power supplies, reactors and similar products	61558 Safety of Power Transformers, Power Supplies, Reactors and Similar Products
61558-1 Part 1: General requirements and tests	61558.1 Part 1: General requirements and tests (IEC 61558-1 Ed 2.1, MOD)
	AS
62052 Electricity metering equipment (AC)—General requirements, tests and test conditions	62052 Electricity metering equipment (AC)— General requirements, tests and test conditions
62052-11 Part 11: Metering equipment	62052.11 Part 11: Metering equipment (IEC 62052-11, Ed.1.0 (2003) MOD)

IEC	AS
62053 Electricity metering equipment (a.c.)—Particular requirements	62053 Electricity metering equipment (AC)—Particular requirements
62053-21 Part 21: Static meters for active energy (classes 1 and 2)	62053.21 Part 21: Static meters for active energy (classes 1 and 2) (IEC 62053-21, Ed.1.0 (2003) MOD)

Only normative references that have been adopted as Australian or Australian/New Zealand Standards have been listed.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the annex to which they apply. A ‘normative’ annex is an integral part of a Standard, whereas an ‘informative’ annex is only for information and guidance.

CONTENTS

	<i>Page</i>
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	8
4 General requirements	10
5 Rating of the supply a.c. voltage.....	10
6 General system requirement and interface.....	10
7 Protection against electric shock	18
8 Connection between the power supply and the EV.....	19
9 Specific requirements for vehicle coupler.....	20
10 Charging cable assembly requirements	21
11 EVSE requirements	21
101 Specific requirements for d.c. EV charging station.....	24
102 Communication between EV and d.c. EV charging station	29
Annex AA (normative) DC EV charging station of system A.....	33
Annex BB (normative) DC EV charging station of system B.....	47
Annex CC (normative) DC EV charging station of system C (Combined charging system)	55
Annex DD (informative) Typical d.c. charging systems.....	70
Annex EE (informative) Typical configuration of d.c. charging system	75
Bibliography.....	76
Figure 101 – Overvoltage protection in case of earth fault	16
Figure 102 – Measuring network for touch current weighted for perception or reaction.....	23
Figure 103 – Step response for constant value control.....	26
Figure 104 – Current probe measurement equipment with capacitor	27
Figure 105 – Maximum ratings for voltage dynamics.....	28
Figure AA.1 – Overall schematic of system A station and EV	34
Figure AA.2 – Interface circuit for charging control of system A station	35
Figure AA.3 – Failure detection principle by detection of d.c. leakage current.....	38
Figure AA.4 – Example of vehicle connector latch and lock monitoring circuit.....	40
Figure AA.5 – State transition diagram of charging process for system A.....	43
Figure AA.6 – Sequence diagram of system A	44
Figure AA.7 – Charging current value requested by the vehicle	45
Figure AA.8 – Output response performance of d.c. EV charging station.....	46
Figure BB.1 – Schematic diagram for basic solution for d.c. charging system	47
Figure BB.2 – Sequence diagram of charging process	52
Figure BB.3 – Operation flow chart of start charging	53
Figure BB.4 – Operation flow chart of stop charging	54
Figure CC.1 – Sequence diagram for normal start up.....	57

Figure CC.2 – Sequence diagram and description for normal shutdown	59
Figure CC.3 – Sequence diagram for d.c. supply initiated emergency shutdown	61
Figure CC.4 – Sequence diagram for EV initiated emergency shutdown.....	63
Figure CC.5 – Special components for configurations CC and EE coupler	66
Figure CC.6 – System schematics of combined d.c. charging system.....	68
Figure D.1 – Example of typical isolated system	70
Figure D.2 – Example of typical non-isolated system	71
Figure D.3 – Example of simplified isolated system.....	71
Figure D.4 – Example of DC mains system	72
Figure E.1 – Typical configuration of d.c. charging system.....	75
Table 101 – Current ripple limit of d.c. EV charging station	27
Table 102 – Charging state of d.c. EV charging station	30
Table 103 – Charging control process of d.c. EV charging station at system action level	31
Table AA.1 – Definition of symbols in Figure AA.1 and Figure AA.2	36
Table AA.2 – Parameters and values for interface circuit in Figure AA.2	37
Table AA.3 – Principle of fault protection	37
Table AA.4 – Requirements for earth fault monitoring	39
Table AA.5 – Recommended specification of charging current requested by the vehicle	45
Table AA.6 – Requirements for the output response performance of d.c. EV charging station	45
Table BB.1 – Definitions of charging states.....	50
Table BB.2 – Recommended parameters of d.c. charging security system	51
Table CC.1 – DC couplers and maximum system output voltage for combined charging system.....	55
Table CC.2 – Definition of proximity resistor for configurations DD and FF	55
Table CC.3 – Sequence description for normal start up.....	58
Table CC.4 – Sequence description for normal shutdown	60
Table CC.5 – Definition and description of symbols / terms.....	69
Table D.1 – Example for categories of d.c. supply system to electric vehicles.....	73
Table D.2 – Typical voltage ranges for isolated d.c. EV charging stations	74

INTRODUCTION

The introduction and commercialisation of electric vehicles has been accelerated in the global market, responding to the global concerns on CO₂ reduction and energy security. Concurrently, the development of charging infrastructure for electric vehicles has also been expanding. As a complement to the a.c. charging system, d.c. charging is recognized as an effective solution to extend the available range of electric vehicles. The international standardization of charging infrastructure is indispensable for the diffusion of electric vehicles, and this standard is developed for the manufacturers' convenience by providing general and basic requirements for d.c. EV charging stations for conductive connection to the vehicle.

Currently in preview, click buy full version.

AUSTRALIAN STANDARD

Electric vehicle conductive charging system**Part 23:****D.C. electric vehicle charging station****1 Scope**

This part of IEC 61851, together with IEC 61851-1:2010, gives the requirements for d.c. electric vehicle (EV) charging stations, herein also referred to as "DC charger", for conductive connection to the vehicle, with an a.c. or d.c. input voltage up to 1 000 V a.c. and up to 1 500 V d.c. according to IEC 60038.

NOTE 1 This standard includes information on EV for conductive connection, but limited to the necessary content for describing the power and signaling interface.

This part covers d.c. output voltages up to 1 500 V.

Requirements for bi-directional power flow are under consideration.

NOTE 2 Typical diagrams and variation of d.c. charging systems are shown in Annex DD.

This standard does not cover all safety aspects related to maintenance.

This part specifies the d.c. charging systems A, B and C as defined in Annexes AA, BB and CC.

NOTE 3 Typical configuration of d.c. EV charging system is shown in Annex EE.

EMC requirements for d.c. EV charging stations are defined in IEC 61851-21-2.

This standard provides the general requirements for the control communication between a d.c. EV charging station and an EV. The requirements for digital communication between d.c. EV charging station and electric vehicle for control of d.c. charging are defined in IEC 61851-24.

2 Normative references

This clause of Part 1 is applicable except as follows:

Addition:

IEC 60364-5-54:2011, *Low-voltage electrical installations – Part 5-54: Selection and erection of electrical equipment – Earthing arrangements and protective conductors*

IEC 60479-1:2005, *Effects of current on human beings and livestock - Part 1: General aspects*

IEC 60950-1:2005, *Information technology equipment - Safety - Part 1: General requirements*
Amendment 1:2009
Amendment 2:2013

IEC 61140, *Protection against electric shock – Common aspects for installation and equipment*