



High-voltage switchgear and control gear

Part 105: Alternating current switch-fuse combinations for rated voltages above 1 kV up to and including 52 kV

STANDARDS
Australia



This Australian Standard® was prepared by Committee EL-007, Industrial Switchgear and Controlgear. It was approved on behalf of the Council of Standards Australia on 12 December 2014.

This Standard was published on 28 January 2015.

The following are represented on Committee EL-007:

- Australian Industry Group
 - Ausgrid
 - Energy Networks Association
 - Engineers Australia
 - University of New South Wales
-

This Standard was issued in draft form for comment as DRAFT IEC 62271.105:2014.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standards up-to-date

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using the current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting www.standards.org.au

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

High-voltage switchgear and control gear

Part 105: Alternating current switch-fuse combinations for rated voltages above 1 kV up to and including 52 kV

First published as AS IEC 62271.105:2015.

COPYRIGHT

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

Published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 978 1 74342 957 0

PREFACE

This Standard was prepared by the Standards Australia Committee EL-007, Industrial Switchgear and Controlgear.

The objective of this Standard is to specify requirements for three-pole units for public and industrial distribution systems, which are functional assemblies of switches including switch-disconnectors and current limiting fuses.

This Standard is identical with, and has been reproduced from IEC 62271-105 Ed.2.0 (2012), *High-voltage switchgear and controlgear, Part 105: Alternating current switch-fuse combinations for rated voltages above 1 kV up to and including 52 kV*.

This Standard is to be read in conjunction with IEC 62271-1 (which has been adopted as AS 62271.1) and to which it refers and which is applicable, unless otherwise specified in this Standard. In order to simplify the indication of corresponding requirements, the same numbering of clauses is used as in IEC 62271-1. Variations to these clauses are given under the same numbering while additional subclauses are numbered from 101.

As this Standard is reproduced from an International Standard, the following applies:

- (a) In the source text ‘this part of IEC 62271’ should read ‘this Australian Standard’.
- (b) A full point substitutes for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to Australian Standards, as follows:

<i>Reference to International Standard</i>		<i>Australian Standard</i>	
IEC		AS	
62271	High-voltage switchgear and controlgear	62271	High-voltage switchgear and controlgear
62271-1*	Part 1: Common specifications	62271.1*	Part 1: Common specifications
62271-100	Part 100: Alternating-current circuit-breakers	62271.100	Part 100: High-voltage alternating-current circuit-breakers (IEC 62271-100, Ed.1.2 (2006) MOD)
62271-102	Part 102: Alternating current disconnectors and earthing switches	62271.102	Part 102: Alternating current disconnectors and earthing switches (IEC 62271-102, Ed.1.0 (2003) MOD)

Only normative references that have been adopted as Australian or Australian/New Zealand Standard have been listed.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the annex to which they apply. A ‘normative’ annex is an integral part of a Standard, whereas an ‘informative’ annex is only for information and guidance.

* The source text specifically references the 2007 edition of IEC 62271-1. IEC released an Amendment to that edition in 2011 and incorporated it into IEC 62271-1 Ed.1.1 (2011). The IEC incorporated edition was adopted as AS 62271.1—2012. For the application of this Standard, the Australian adoption of IEC 62271-1 is recommended.

CONTENTS

1	General	7
1.1	Scope	7
1.2	Normative references	8
2	Normal and special service conditions	8
3	Terms and definitions	8
3.1	General terms	8
3.2	Assemblies of switchgear and controlgear	8
3.3	Parts of assemblies	8
3.4	Switching devices	8
3.5	Parts of switchgear and controlgear	9
3.6	Operation	10
3.7	Characteristic quantities	10
3.101	Fuses	14
4	Ratings	15
4.1	Rated voltage (U_r)	15
4.2	Rated insulation level	15
4.3	Rated frequency (f_r)	15
4.4	Rated normal current and temperature rise	15
4.4.1	Rated normal current (I_r)	15
4.4.2	Temperature rise	15
4.5	Rated short-time withstand current (I_k)	15
4.6	Rated peak withstand current (I_p)	15
4.7	Rated duration of short-circuit (t_p)	15
4.8	Rated supply voltage of closing and opening devices and of auxiliary and control circuits (U_a)	16
4.9	Rated supply frequency of closing and opening devices and of auxiliary circuits	16
4.10	Rated pressure of compressed gas supply for controlled pressure systems	16
4.11	Rated filling levels for insulation and/or operation	16
4.101	Rated short-circuit breaking current	16
4.102	Rated transient recovery voltage	16
4.103	Rated short-circuit making current	16
4.104	Rated transfer current (striker operation) ($I_{transfer}$)	17
4.105	Rated take-over current for release-operated combinations (I_{to})	17
5	Design and construction	17
5.1	Requirements for liquids in switch-fuse combinations	17
5.2	Requirements for gases in switch-fuse combinations	17
5.3	Earthing of switch-fuse combinations	17
5.4	Auxiliary and control equipment	17
5.5	Dependent power operation	17
5.6	Stored energy operation	17
5.7	Independent manual or power operation (independent unlatched operation)	17
5.8	Operation of releases	17
5.9	Low- and high-pressure interlocking and monitoring devices	17
5.10	Nameplates	17

5.11	Interlocking devices	18
5.12	Position indication	18
5.13	Degrees of protection provided by enclosures.....	18
5.14	Creepage distances for outdoor insulators	18
5.15	Gas and vacuum tightness.....	19
5.16	Liquid tightness	19
5.17	Fire hazard (flammability)	19
5.18	Electromagnetic compatibility (EMC).....	19
5.19	X-ray emission.....	19
5.20	Corrosion.....	19
5.101	Linkages between the fuse striker(s) and the switch release	19
5.102	Low over-current conditions (long fuse-pre-arcing time conditions)	19
6	Type tests	20
6.1	General	20
6.1.1	Grouping of tests	20
6.1.2	Information for identification of specimens	21
6.1.3	Information to be included in the type-test report	21
6.2	Dielectric tests.....	21
6.3	Radio interference voltage (r.i.v.) tests	21
6.4	Measurement of the resistance of circuits	21
6.5	Temperature-rise tests.....	21
6.6	Short-time withstand current and peak withstanding current tests	21
6.7	Verification of the protection	21
6.8	Tightness tests	21
6.9	Electromagnetic compatibility tests (EMC)	21
6.10	Additional tests on auxiliary and control circuits.....	21
6.11	X-radiation test procedure for vacuum interrupters.....	22
6.101	Making and breaking tests.....	22
6.101.1	General.....	22
6.101.2	Conditions for performing the tests.....	22
6.101.3	Test duty procedures	28
6.101.4	Behaviour of the combination during tests.....	33
6.101.5	Condition of the apparatus after testing.....	33
6.102	Mechanical operation tests	34
6.103	Mechanical shock tests on fuses.....	34
6.104	Thermal test with long pre-arcing time of fuse.....	35
6.105	Extension of validity of type tests.....	35
6.105.1	Dielectric.....	35
6.105.2	Temperature rise.....	35
6.105.3	Making and breaking	35
7	Routine tests	36
7.101	Mechanical operating tests	36
8	Guide for the selection of switch-fuse combinations.....	36
8.1	Selection of rated values	36
8.2	Continuous or temporary overload due to changed service conditions	37
8.101	Guide for the selection of switch-fuse combination for transformer protection	37
8.101.1	General.....	37
8.101.2	Rated short-circuit breaking current	37

8.101.3 Primary fault condition caused by a solid short-circuit on the transformer secondary terminals	37
8.102 Coordination of switch and fuses for extension of the reference list	38
8.102.1 General	38
8.102.2 Rated normal current	38
8.102.3 Low over-current performance	39
8.102.4 Transfer current	39
8.102.5 Take-over current	39
8.102.6 Extension of the validity of type tests	39
8.103 Operation	39
9 Information to be given with enquiries, tenders and orders	40
9.1 Information with enquiries and orders	40
9.2 Information with tenders	40
10 Transport, storage, installation, operation and maintenance	40
11 Safety	41
12 Influence of the product on the environment	41
Annex A (informative) Example of the coordination of fuses, switch and transformer	42
Annex B (normative) Procedure for determining transfer current	45
Annex C (normative) Tolerances on test quantities for type tests	50
Bibliography	51
Figure 1 – Arrangement of test circuits for test duties $TD_{I_{sc}}$ and $TD_{I_{Wmax}}$	23
Figure 2 – Arrangement of test circuits for test-duty $TD_{I_{transfer}}$	24
Figure 3 – Arrangement of test circuits for test-duty $TD_{I_{to}}$	24
Figure 4 – Determination of power-frequency recovery voltage	26
Figure 5 – Representation of a specified TRV by a two-parameter reference line and a delay line	27
Figure 6 – Example of a two-parameter reference line for a TRV	28
Figure 7 – Characteristics for determining take-over current	32
Figure 8 – Transfer current in relation to the primary fault current I_{sc} due to a solid short circuit in the transformer secondary terminal	38
Figure A.1 – Characteristics relating to the protection of an 11 kV – 400 kVA transformer	43
Figure A.2 – Discrimination between HV and LV fuses	44
Figure B.1 – Practical determination of the transfer current	46
Figure B.2 – Determination of the transfer current with the iterative method	48
Table 1 – Nameplate markings	18
Table 2 – Standard values of prospective TRV for test-duty $TD_{I_{transfer}}$ based on practice in Europe	30
Table 3 – Standard values of prospective TRV for test-duty $TD_{I_{transfer}}$ based on practice in the United States of America and Canada	31
Table 4 – Summary of test parameters for test duties	32
Table C.1 – Tolerances on test quantities for type tests	50

AUSTRALIAN STANDARD

High-voltage switchgear and control gear

Part 105:

Alternating current switch-fuse combinations for rated voltages above 1 kV up to and including 52 kV

1 General**1.1 Scope**

Subclause 1.1 of IEC 62271-1:2007 is not applicable, and is replaced as follows:

This part of IEC 62271 applies to three-pole units for public and industrial distribution systems which are functional assemblies of switches including switch-disconnectors and current-limiting fuses designed so as to be capable of

- breaking, at the rated recovery voltage, any current up to and including the rated short-circuit breaking current;
- making, at the rated voltage, circuits to which the rated short-circuit breaking current applies.

It does not apply to fuse-circuit-breakers, fuse-contactors, combinations for motor-circuits or to combinations incorporating single capacitor bank switches.

In this standard, the word “combination” is used for a combination in which the components constitute a functional assembly. Each association of a given type of switch and a given type of fuse defines one type of combination.

In practice, different types of fuses may be combined with one type of switch, which give several combinations with different characteristics, in particular concerning the rated currents. Moreover, for maintenance purposes, the user should know the types of fuses that can be combined to a given switch without impairing compliance to the standard, and the corresponding characteristics of the so-made combination.

A switch-fuse combination is then defined by its type designation and a list of selected fuses is defined by the manufacturer, the so-called “reference list of fuses”. Compliance with this standard of a given combination means that every combination using one of the selected fuses is proven to be in compliance with this standard.

The fuses are incorporated in order to extend the short-circuit breaking rating of the combination beyond that of the switch alone. They are fitted with strikers in order both to open automatically all three poles of the switch on the operation of a fuse and to achieve a correct operation at values of fault current above the minimum melting current but below the minimum breaking current of the fuses. In addition to the fuse strikers, the combination may be fitted with either an over-current release or a shunt release.

NOTE In this standard the term “fuse” is used to designate either the fuse or the fuse-link where the general meaning of the text does not result in ambiguity.

This standard applies to combinations designed with rated voltages above 1 kV up to and including 52 kV for use on three-phase alternating current systems of either 50 Hz or 60 Hz.

Fuses are covered by IEC 60282-1.

Devices that require dependent manual operation are not covered by this standard.