



**Management of alarm systems for the
process industries**

STANDARDS
Australia



This Australian Standard® was prepared by Committee IT-006, Industrial Process Measurement, Control and Automation. It was approved on behalf of the Council of Standards Australia on 2 March 2017.
This Standard was published on 23 March 2017.

The following are represented on Committee IT-006:

- Australia Safety Critical Systems Association
 - Australian Computer Society
 - Australian Industry Group
 - Australian Petroleum Production and Exploration Association
 - Engineers Australia
 - Institution of Chemical Engineers
 - Institute of Instrumentation, Control and Automation, Australia
 - ISACA
 - Process Control Society
 - University of Queensland
 - Workplace Health and Safety Queensland
-

This Standard was issued in draft form for comment as **DRAS IEC 62682:2016**.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

Keeping Standards up-to-date

Australian Standards are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting **www.standards.org.au**

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at **mail@standards.org.au**, or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

Australian Standard[®]

**Management of alarm systems for the
process industries**

First published as AS IEC 62682:2017.

COPYRIGHT

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

Published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 978 1 76035 705 4

PREFACE

This Standard was prepared by the Standards Australia Committee IT-006, Industrial Process Measurement, Control and Automation.

The objective of this Standard is to specify general principles and processes for the lifecycle management of alarm systems based on programmable electronic controller and computer-based human-machine interface (HMI) technology for facilities in the process industries. It covers all alarms presented to the operator, which includes alarms from basic process control systems, annunciator panels, safety instrumented systems, fire and gas systems, and emergency response systems manually.

This Standard is identical with, and has been reproduced from IEC 62682:2014, *Management of alarm systems for the process industries*.

As this Standard is reproduced from an International Standard, the following applies:

- (a) In the source text 'this International Standard' should read 'Australian Standard'.
- (b) A full point substitutes for a comma when referring to a decimal marker.

There are no normative references in the source document.

CONTENTS

1	Scope	12
1.1	General applicability	12
1.2	Exclusions and inclusions	13
1.2.1	Operators	13
1.2.2	Process sensors and final control elements	13
1.2.3	Safety instrumented systems	13
1.2.4	Event data	13
1.2.5	Alarm identification methods	14
1.2.6	Management of change	14
2	Normative references	14
3	Terms, definitions, and abbreviations	14
3.1	Terms and definitions	14
3.2	Abbreviations	22
4	Conformance to this standard	22
4.1	Conformance guidance	22
4.2	Existing systems	23
4.3	Responsibility	23
5	Alarm system models	23
5.1	Alarm systems	23
5.2	Alarm management lifecycle	23
5.2.1	Alarm management lifecycle model	23
5.2.2	Alarm management lifecycle stages	24
5.2.3	Alarm lifecycle entry points	27
5.2.4	Simultaneous and encompassing stages	27
5.2.5	Alarm management lifecycle loops	27
5.2.6	Alarm management lifecycle stage inputs and outputs	28
5.3	Alarm states	29
5.3.1	Alarm state transition diagram	29
5.3.2	Alarm state	30
5.3.3	Alarm state transition paths	31
5.4	Alarm response timeline	32
5.4.1	General	32
5.4.2	Normal (A)	33
5.4.3	Unacknowledged (B)	33
5.4.4	Acknowledged (C) and response	33
5.4.5	Return-to-normal (D)	34
5.4.6	Consequence threshold	34
5.5	Feedback model of operator-process interaction	34
5.5.1	General	34
5.5.2	Detect	35
5.5.3	Diagnose	35
5.5.4	Respond	35
5.5.5	Performance shaping factors	35
6	Alarm philosophy	35

6.1	Purpose	35
6.2	Alarm philosophy contents.....	35
6.2.1	General	35
6.2.2	Purpose of alarm system	36
6.2.3	Definitions	37
6.2.4	References	37
6.2.5	Roles and responsibilities for alarm management	37
6.2.6	Alarm design principles	37
6.2.7	Rationalization	37
6.2.8	Alarm class definition	37
6.2.9	Highly managed alarms	38
6.2.10	HMI design principles	38
6.2.11	Prioritization method	38
6.2.12	Alarm setpoint determination	39
6.2.13	Alarm system performance monitoring	39
6.2.14	Alarm system maintenance.....	39
6.2.15	Testing of the alarm system	39
6.2.16	Approved enhanced and advanced alarming techniques	39
6.2.17	Alarm documentation	39
6.2.18	Implementation guidance	40
6.2.19	Management of change	40
6.2.20	Training	40
6.2.21	Alarm history preservation.....	40
6.2.22	Related site procedures	40
6.2.23	Specific alarm design considerations	41
6.2.24	Alarm system audit	41
6.3	Alarm philosophy development and maintenance	41
7	Alarm system requirements specification.....	41
7.1	Purpose	41
7.2	Recommendations.....	42
7.3	Development.....	42
7.4	Systems evaluation	42
7.5	Customization	43
7.6	Alarm system requirements testing	43
8	Identification.....	43
8.1	Purpose	43
8.2	Alarm identification methods.....	43
8.3	Identification training	43
9	Rationalization.....	43
9.1	Purpose	43
9.2	Rationalization documentation	44
9.2.1	Rationalization documentation requirements	44
9.2.2	Rationalization documentation recommendations	44
9.3	Alarm justification.....	44
9.3.1	Alarm justification process.....	44
9.3.2	Justification approach	44
9.3.3	Individual alarm justification	45
9.3.4	Impact on alarm system	45
9.4	Alarm setpoint determination	45

9.5	Prioritization.....	45
9.6	Removal	45
9.7	Classification	46
9.8	Review.....	46
9.9	Use of documentation.....	46
10	Detailed design: Basic alarm design.....	46
10.1	Purpose	46
10.2	Usage of alarm states	46
10.2.1	Alarm state triggering.....	46
10.2.2	Alarm states and other logic functions	46
10.2.3	Alarm suppression and other logic functions	47
10.3	Alarm types.....	47
10.4	Alarm attributes.....	47
10.4.1	General	47
10.4.2	Alarm description	48
10.4.3	Alarm setpoints	48
10.4.4	Alarm priority	48
10.4.5	Alarm deadbands	48
10.4.6	Alarm on-delay and off-delay.....	48
10.5	Programmatic changes to alarm attributes	49
10.6	Review basic alarm design	49
11	Detailed design: Human-machine interface design for alarm systems.....	49
11.1	Purpose	49
11.2	HMI functions.....	49
11.2.1	General	49
11.2.2	HMI information requirements	49
11.2.3	HMI functional requirements	50
11.2.4	HMI display requirements	50
11.2.5	Alarm records requirements	50
11.2.6	Alarm records recommendations	50
11.3	Alarm states indications	50
11.3.1	General	50
11.3.2	Required alarm state indications.....	51
11.3.3	Recommended alarm state indications.....	51
11.3.4	Audible alarm state indications	52
11.4	Alarm priority indications	52
11.4.1	General	52
11.4.2	Alarm priority indication requirements.....	52
11.4.3	Colour alarm priority indications requirements	52
11.4.4	Recommended alarm priority indications.....	53
11.5	Alarm message indications	53
11.5.1	General	53
11.5.2	Recommended alarm message indications	53
11.6	Alarm displays	53
11.6.1	General	53
11.6.2	Alarm summary display	54
11.6.3	Alarm summary status.....	55
11.6.4	Alarm log displays.....	55
11.6.5	Process displays	56

11.6.6	Tag detail displays	56
11.6.7	Other display elements.....	56
11.7	Alarm shelving	56
11.7.1	General	56
11.7.2	Alarm shelving functional requirements.....	56
11.7.3	Alarm shelving functional recommendations.....	57
11.7.4	Shelved alarm displays	57
11.8	Out-of-service alarms	57
11.8.1	General	57
11.8.2	Out-of-service alarm functional requirements	58
11.8.3	Out-of-service alarm displays	58
11.9	Alarms suppressed by design	58
11.9.1	General	58
11.9.2	Designed suppression functional requirements	58
11.9.3	Design suppression functional recommendations	59
11.9.4	Suppressed-by-design displays	59
11.10	Alarm annunciator integration	59
11.10.1	General	59
11.10.2	Alarm annunciator integration recommendations	59
11.10.3	Alarm annunciator display integration recommendations	60
11.11	Safety alarm HMI	60
11.11.1	General	60
11.11.2	Independent safety alarm HMI	60
12	Detailed design: Enhanced and advanced alarm methods.....	60
12.1	Purpose	60
12.2	Basis of enhanced and advanced alarming	60
12.2.1	General	60
12.2.2	Effort, manpower requirements and complexity	60
12.3	Information linking.....	61
12.4	Logic-based alarming	61
12.4.1	General	61
12.4.2	Alarm attribute modification	61
12.4.3	Externally enabled systems	61
12.4.4	Logical alarm suppression and attribute modification	61
12.4.5	State-based alarming	61
12.5	Model-based alarming	61
12.6	Additional alarming considerations	62
12.6.1	General	62
12.6.2	Non-control room considerations	62
12.6.3	Remote alarm systems.....	62
12.6.4	Supplementary alarm systems.....	62
12.6.5	Batch process considerations.....	62
12.7	Training, testing, and auditing systems	63
12.8	Alarm attribute enforcement	63
13	Implementation	63
13.1	Purpose	63
13.2	Implementation planning	63
13.3	Implementation training	63
13.3.1	General	63

13.3.2	Implementation training	63
13.3.3	Implementation training requirements	64
13.3.4	Training documentation requirements for highly managed alarms	64
13.3.5	Training documentation recommendations	64
13.3.6	Implementation training requirements for new or modified alarm systems	64
13.3.7	Implementation training recommendations for new or modified alarm systems	64
13.4	Implementation testing and validation	64
13.4.1	General	64
13.4.2	Implementation testing requirements for highly managed alarms	64
13.4.3	Implementation testing recommendations for new or modified alarms	64
13.4.4	Implementation testing requirements for new or modified alarm systems	65
13.5	Implementation documentation	65
13.5.1	General	65
13.5.2	Documentation requirements	65
13.5.3	Implementation documentation recommendations	65
14	Operation	66
14.1	Purpose	66
14.2	Alarm response procedures	66
14.2.1	Alarm response procedures requirements	66
14.2.2	Alarm response procedure recommendations	66
14.3	Alarm shelving	66
14.3.1	Alarm shelving requirements	66
14.3.2	Alarm shelving for highly managed alarms	67
14.3.3	Alarm shelving recommendations	67
14.3.4	Alarm shelving record requirements	67
14.4	Refresher training for operators	67
14.4.1	Refresher training requirements for operators	67
14.4.2	Refresher training documentation for highly managed alarms	67
14.4.3	Refresher training content for highly managed alarms	67
14.4.4	Refresher training recommendations for alarms	67
15	Maintenance	68
15.1	Purpose	68
15.2	Periodic alarm testing	68
15.2.1	General	68
15.2.2	Periodic alarm testing requirements	68
15.2.3	Periodic alarm testing for highly managed alarms	68
15.2.4	Periodic alarm test procedure requirements	68
15.2.5	Periodic alarm test procedure recommendations	68
15.2.6	Periodic alarm testing recommendations	69
15.3	Out-of-service alarms	69
15.3.1	General	69
15.3.2	Out-of-service process requirements	69
15.3.3	Out-of-service highly managed alarms	69
15.3.4	Out-of-service process recommendations	69
15.3.5	Requirements for returning alarms to service	69
15.4	Equipment repair	69
15.5	Equipment replacement	70

15.6	Refresher training for maintenance	70
15.6.1	General requirements.....	70
15.6.2	Refresher training requirements for highly managed alarms	70
15.6.3	Refresher training recommendations for alarms	70
16	Monitoring and assessment	70
16.1	Purpose	70
16.2	Requirements.....	70
16.3	Monitoring, assessment, audit, and benchmark.....	70
16.4	Alarm system monitoring	71
16.5	Alarm system performance metrics	71
16.5.1	General	71
16.5.2	Average alarm rate per operator console	71
16.5.3	Peak alarm rate per operator console	72
16.5.4	Alarm floods.....	72
16.5.5	Frequently occurring alarms	73
16.5.6	Chattering and fleeting alarms.....	73
16.5.7	Stale alarms.....	73
16.5.8	Annunciated alarm priority distribution	73
16.5.9	Alarm priority distribution	74
16.6	Unauthorized alarm suppression.....	74
16.7	Alarm attribute monitoring	74
16.8	Reporting of alarm system analyses	74
16.9	Alarm performance metric summary.....	74
17	Management of change.....	75
17.1	Purpose	75
17.2	Changes subject to management of change	75
17.3	Change documentation requirements.....	76
17.4	Change documentation recommendations.....	76
17.5	Alarm removal recommendations.....	76
17.6	Alarm attribute modification recommendations	76
18	Audit	77
18.1	Purpose	77
18.2	Benchmark	77
18.2.1	General	77
18.2.2	Initial audit or benchmark requirements	77
18.3	Audit interviews.....	77
18.4	Audit recommendations	77
18.5	Action plans	78
	Bibliography	79
	Figure 1 – Alarm system dataflow.....	13
	Figure 2 – Alarm management lifecycle	24
	Figure 3 – Alarm state transition diagram	29
	Figure 4 – Alarm response timeline	33
	Figure 5 – Feedback model of operator-process interaction	35
	Table 1 – Alarm management lifecycle stage inputs and outputs	28

Table 2 – Alarm states31

Table 3 – Required and recommended alarm philosophy content36

Table 4 – Recommended alarm state indications52

Table 5 – Average alarm rates72

Table 6 – Annunciated alarm priority distribution73

Table 7 – Recommended alarm performance metrics summary75

INTRODUCTION

Purpose

This International Standard addresses the development, design, installation, and management of alarm systems in the process industries. Alarm management includes multiple work processes throughout the alarm system lifecycle. This standard defines the terminology and models to develop an alarm system, and it defines the work processes recommended to effectively maintain the alarm system throughout the lifecycle.

This standard was adapted from ANSI/ISA-18.2-2009, *Management of Alarm Systems for the Process Industries*, an International Society of Automation (ISA) standard, and with due consideration of other guidance documents that have been developed throughout industry. Ineffective alarm systems have often been cited as contributing factors in the investigation reports following major process incidents. This standard is intended to provide a methodology that will result in the improved safety of the process industries.

This standard is not the first effort to define terminology and practices for effective alarm systems. In 1999 the Engineering Equipment and Materials Users' Association (EEMUA) issued Publication 191, *Alarm Systems: A Guide to Design, Management and Procurement*. In 2003 the User Association of Process Control Technology in Chemical and Pharmaceutical Industries (NAMUR) issued worksheet NA 102, *Alarm Management*.

During the development of this standard every effort was made to keep terminology and practices consistent with the previous work of these respected organizations and committees.

This document provides requirements for alarm management and alarm systems. It is intended for those individuals and organizations that

- a) manufacture or implement embedded alarm systems,
- b) manufacture or implement third-party alarm system software,
- c) design or install alarm systems,
- d) operate and/or maintain alarm systems, and
- e) audit or assess alarm system performance.

Organization

This standard is organized in two parts. The first part is introductory in nature, (Clauses 1 to 5). The main body of the standard follows (Clauses 6 to 18).

AUSTRALIAN STANDARD

Management of alarm systems for the process industries**1 Scope****1.1 General applicability**

This International Standard specifies general principles and processes for the lifecycle management of alarm systems based on programmable electronic controller and computer-based human-machine interface (HMI) technology for facilities in the process industries. It covers all alarms presented to the operator, which includes alarms from basic process control systems, annunciator panels, safety instrumented systems, fire and gas systems, and emergency response systems.

The practices in this standard are applicable to continuous, batch, and discrete processes. There can be differences in implementation to meet the specific needs based on process type.

In jurisdictions where the governing authorities (e.g., national, federal, state, province, county, city) have established process safety design, process safety management, or other requirements, in addition to the requirements of this standard, these should be taken into consideration.

The primary function within the alarm system is to notify operators of abnormal process conditions or equipment malfunctions and support the response. The alarm systems can include both the basic process control system (BPCS) and the safety instrumented system (SIS), each of which uses measurements of process conditions and logic to generate alarms. Figure 1 illustrates the concepts of alarm and response dataflow through the alarm system. The alarm system also includes a mechanism for communicating the alarm information to the operator via an HMI, usually a computer screen or an annunciator panel. Additional functions of the alarm system are an alarm and event log, an alarm historian, and the generation of performance metrics for the alarm system. There are external systems that can use the data from the alarm system.